



Derek Clarke, Drinking Water Officer  
Office of Drinking Water, Manitoba Sustainable Development  
Box 6000  
Gimli, MB R0C 1B0

September 4, 2020

**RE: CORRECTIVE ACTION REPORT FOR WINNIPEG PUBLIC WATER SYSTEM, 252.00**

**Incident No:** CAR-14-2020-WMR

**Reported to ODW:** August 14, 2020

**Reported by:** Louis Rivard, Superintendent of Water Distribution

**Approved by:** Zeljko Bodiroga, Water Distribution Engineer

**Incident Date:** August 12, 2020

**Incident Location:** Winnipeg 3-Dist (WM Repair)

**Incident Type:** Low Positive Total Coliform (<10 per100mL), 2 MR 41/2007

**Description of Corrective Actions:**

Immediately made contact with ODW and Environmental Standards, flushed the isolated area and re-sampled original location. Tested the original location for bacteria, turbidity, and free chlorine until two consecutive negative bacteria results were obtained.

**Test Results:** See attached

**Reference No:** Job No. 568

**EMERGENCY REPORTING IS REQUIRED WHERE A POTENTIAL HEALTH RISK IS INVOLVED. FOLLOW THE INSTRUCTIONS OF YOUR DRINKING WATER OFFICER IN SITUATIONS REQUIRING IMMEDIATE REPORTING**

N:\Environmental Standards\Analytical Services\Government Agencies\Office of Drinking Water\Corrective Action Reports

