



Kale Black, Sr. Drinking Water Officer
Office of Drinking Water, Manitoba Sustainable Development
309 – 25 Tupper Street North
Portage La Prairie, MB R1N 3K1

July 6, 2023

RE: CORRECTIVE ACTION REPORT FOR WINNIPEG PUBLIC WATER SYSTEM, 252.00

Incident No: CAR-06-2023-WMR

Reported to ODW: June 3, 2023

Reported by: Louis Rivard, Superintendent of Water Distribution

Approved by: Louis Rivard, Superintendent of Water Distribution

Incident Date: June 1, 2023

Incident Location: Winnipeg 3-Dist (WM Repair)

Incident Type:

1. Low Positive Total Coliform (<10 per100mL), 3 MR 41/2007

Description of Corrective Actions:

Water Services:

IMMEDIATELY: Contacted the ODW and Environmental Standards, and flushed the isolated area. Re-sampled original location, and tested for; bacteria, turbidity, and free chlorine until one negative bacteria result was obtained.

Test Results: See attached

LIMS Reference No: N/A

EMERGENCY REPORTING IS REQUIRED WHERE A POTENTIAL HEALTH RISK IS INVOLVED. FOLLOW THE INSTRUCTIONS OF YOUR DRINKING WATER OFFICER IN SITUATIONS REQUIRING IMMEDIATE REPORTING

N:\Environmental Standards\Analytical Services\Government Agencies\Office of Drinking Water\Corrective Action Reports



Sample Name	Work Order Number	Date Sampled	E Coli (MPNU/100mL)	Total Coliform (MPNU/100mL)	Free Chlorine (mg/L)	Turbidity-field (ntu)	Time Sampled (hrs)
Hydrant - Chataway	2305899	1-Jun-23	<1	1	0.36	3.44	14:55
Hydrant - Chataway_Resample	2305899	3-Jun-23	<1	<1	0.65	4.19	14:10

NOTES/COMMENTS:

1. All microbiological tests performed by contract laboratory.
2. OL - Autosampler or Process Offline
3. NA - Not Applicable