



Water and Waste Department • Service des eaux et des déchets

September 4, 2015

Melanie Betsill
Office of Drinking Water
Manitoba Conservation and Water Stewardship
1007 Century Street
Winnipeg, Manitoba
R3H 0W4

Our File: 040-18-18-55-00

Dear Ms. Betsill:

**RE: AUGUST 2015 WATER QUALITY COMPLIANCE
SUBMISSION FOR THE CITY OF WINNIPEG WATER SUPPLY SYSTEM**

Please find attached on-line and grab turbidity summary reports, on-line and grab chlorine summary reports and the UV summary report for the Water Treatment Plant for August 2015. There are no corrective action reports to be submitted for August.

The August on-line and grab sampling turbidity reports include results obtained for the Water Treatment Plant raw water and the eight filters. The turbidity results for the effluent from the filters met the licence requirements.

The August on-line and grab sampling chlorine reports include results obtained for the Deacon Booster Pumping Station at the Water Treatment Plant. The free chlorine results at the Water Treatment Plant met the licence requirements.

The UV submission includes the summary report for August 2015 in accordance with Section 4.13, Table 2 of the Operating Licence. The UV licence requirement has been met in August.

Please let me know of any concerns or questions respecting this submission. I may be reached by telephone at 204-986-8359 or by e-mail at rgrosselle@winnipeg.ca.

Yours sincerely,

Original signed by:

R. Grosselle
Manager of Environmental Standards
Attachments

c:(e-mail)

Dr. L. Richards, Winnipeg Regional Health Authority
Dr. H. Chang, Winnipeg Regional Health Authority
Dr. S. Roberecki, Manitoba Health
D.P. Sacher, P.Eng.
G. Patton, P.Eng.
T. Shanks, P.Eng.
A. J. Weremy, P.Eng.
C. Diduck

N:\Compliance Reporting\Submittal Letters\2015\ODW- WQ Letters\Betsill Letter 2015-08.doc



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
WATER SERVICES

Water System Code: **252.00**
Licence Number: **PWS-09-412 AA**

WATER TREATMENT PLANT TURBIDITY ON-LINE MONITORING REPORT

August 2015 Turbidity (NTU)

Date	Raw		Filter #1		Filter #2		Filter #3		Filter #4		Filter #5		Filter #6		Filter #7		Filter #8	
	Avg	Avg	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max
1/08/2015	2.06	0.03	0.06		0.04	0.06	0.07	0.10	0.02	0.05	0.04	0.08	0.05	0.06	0.04	0.08	0.01	0.01
2/08/2015	2.14	0.04	0.05		0.04	0.07	0.07	0.13	0.03	0.05	0.05	0.08	0.06	0.09	0.05	0.06	0.01	0.04
3/08/2015	2.52	0.03	0.08		0.04	0.05	0.06	0.14	0.03	0.07	0.05	0.07	0.05	0.10	0.06	0.10	0.01	0.01
4/08/2015	2.23	0.04	0.05		0.04	0.09	0.08	0.10	0.03	0.07	0.05	0.09	0.06	0.08	0.05	0.08	0.01	0.01
5/08/2015	2.39	0.04	0.08		0.04	0.07	0.06	0.14	0.03	0.05	0.04	0.08	0.05	0.23	0.05	0.06	0.01	0.01
6/08/2015	2.26	0.03	0.08		0.04	0.07	0.07	0.09	0.03	0.06	0.05	0.07	0.05	0.09	0.05	0.09	0.01	0.01
7/08/2015	2.42	0.04	0.05		0.05	0.08	0.07	0.14	0.03	0.04	0.04	0.07	0.07	0.09	0.04	0.09	0.01	0.05
8/08/2015	2.45	0.04	0.08		0.05	0.13	0.06	0.17	0.04	0.08	0.03	0.06	0.07	0.12	0.05	0.07	0.01	0.01
9/08/2015	2.34	0.03	0.09		0.06	0.08	0.06	0.19	0.03	0.09	0.05	0.11	0.06	0.23	0.04	0.11	0.01	0.19
10/08/2015	2.32	0.03	0.09		0.06	0.13	0.08	0.11	0.03	0.08	0.04	0.11	0.07	0.10	0.04	0.12	0.01	0.11
11/08/2015	2.26	0.05	0.09		0.05	0.14	0.06	0.20	0.04	0.05	0.04	0.11	0.08	0.15	0.04	0.06	0.01	0.11
12/08/2015	2.16	0.04	0.10		0.05	0.08	0.06	0.21	0.04	0.08	0.05	0.07	0.07	0.17	0.06	0.13	0.02	0.03
13/08/2015	2.28	0.03	0.12		0.07	0.15	0.09	0.12	0.03	0.11	0.05	0.12	0.07	0.11	0.04	0.14	0.01	0.10
14/08/2015	2.25	0.05	0.07		0.04	0.14	0.07	0.22	0.05	0.06	0.04	0.12	0.08	0.15	0.05	0.07	0.01	0.12
15/08/2015	2.23	0.04	0.10		0.05	0.14	0.06	0.20	0.04	0.10	0.04	0.07	0.06	0.16	0.06	0.13	0.02	0.04
16/08/2015	2.38	0.04	0.10		0.06	0.08	0.06	0.10	0.04	0.10	0.05	0.10	0.06	0.14	0.05	0.13	0.01	0.10
17/08/2015	2.50	0.04	0.07		0.07	0.16	0.11	0.24	0.04	0.12	0.04	0.11	0.06	0.09	0.04	0.12	0.01	0.10
18/08/2015	2.56	0.07	0.12		0.06	0.18	0.08	0.25	0.07	0.09	0.04	0.23	0.06	0.14	0.05	0.09	0.01	0.04
19/08/2015	2.65	0.07	0.13		0.07	0.13	0.09	0.19	0.06	0.13	0.05	0.07	0.06	0.10	0.06	0.10	0.01	0.02
20/08/2015	2.64	0.06	0.08		0.09	0.14	0.11	0.13	0.05	0.13	0.04	0.08	0.07	0.08	0.04	0.09	0.01	0.06
21/08/2015	2.82	0.07	0.14		0.07	0.15	0.08	0.21	0.07	0.09	0.04	0.07	0.06	0.11	0.05	0.06	0.01	0.01
22/08/2015	2.77	0.06	0.13		0.08	0.09	0.09	0.10	0.05	0.12	0.04	0.06	0.05	0.10	0.04	0.09	0.01	0.05
23/08/2015	2.80	0.07	0.08		0.07	0.13	0.09	0.17	0.05	0.10	0.03	0.06	0.06	0.07	0.04	0.08	0.01	0.04
24/08/2015	2.96	0.06	0.11		0.06	0.11	0.08	0.16	0.06	0.08	0.03	0.06	0.05	0.09	0.05	0.06	0.01	0.01
25/08/2015	2.92	0.06	0.11		0.07	0.09	0.07	0.10	0.05	0.10	0.04	0.05	0.05	0.08	0.04	0.08	0.01	0.03
26/08/2015	2.76	0.07	0.08		0.06	0.12	0.09	0.16	0.04	0.06	0.03	0.05	0.06	0.07	0.04	0.08	0.01	0.03
27/08/2015	2.53	0.07	0.12		0.06	0.13	0.07	0.16	0.06	0.10	0.03	0.05	0.05	0.10	0.05	0.06	0.01	0.01
28/08/2015	2.51	0.06	0.14		0.08	0.11	0.09	0.12	0.05	0.12	0.04	0.07	0.06	0.11	0.04	0.08	0.01	0.05
29/08/2015	2.42	0.09	0.11		0.07	0.13	0.08	0.16	0.06	0.07	0.03	0.09	0.05	0.10	0.05	0.06	0.01	0.01
30/08/2015	2.33	0.07	0.13		0.07	0.08	0.07	0.10	0.05	0.09	0.04	0.05	0.05	0.09	0.04	0.07	0.01	0.04
31/08/2015	2.38	0.10	0.14		0.07	0.14	0.09	0.16	0.05	0.09	0.03	0.07	0.07	0.15	0.04	0.07	0.01	0.23

Total Number of Measurements Taken, A: 15849 13569 14529 13109 16314 16285 15006 15887
Turbidity Standard for Monitoring Location (NTU): 0.30 0.30 0.30 0.30 0.30 0.30 0.30 0.30
Number of Measurements Meeting Standard, B: 15849 13569 14529 13109 16314 16285 15006 15887
Compliance with Turbidity Standard, C = B/A X 100%: 100.00% 100.00% 100.00% 100.00% 100.00% 100.00% 100.00% 100.00%

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Turbidity\2015\08-August

Submitted By (Print): D.Merredew

Signature: Original signed by D.Merredew



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENVIRONMENTAL STANDARDS DIVISION

WATER TREATMENT PLANT TURBIDITY GRAB MONITORING REPORT

Water System Code: 252.00 Licence No. PWS-09-412 AA	Turbidity (NTU)																	
	Raw Water		Filter 1		Filter 2		Filter 3		Filter 4		Filter 5		Filter 6		Filter 7		Filter 8	
Date	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser
01-Aug-2015	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
02-Aug-2015	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
03-Aug-2015	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
04-Aug-2015	1.75	2.24	0.08	0.03	0.10	0.06	0.11	0.07	0.09	<0.02	0.09	0.05	0.09	0.05	0.10	0.04	0.09	<0.02
05-Aug-2015	1.62	2.30	0.08	0.04	0.07	0.04	0.13	0.09	0.08	0.02	0.07	0.05	0.10	0.07	0.09	0.05	0.08	<0.02
06-Aug-2015	1.89	2.17	0.06	0.02	0.07	0.05	0.08	<0.02	0.08	0.05	0.08	0.05	0.07	0.05	0.09	0.06	0.08	<0.02
07-Aug-2015	1.84	2.31	0.10	0.03	0.11	0.06	0.11	0.07	0.09	<0.02	0.10	0.05	0.09	0.05	0.08	0.04	0.09	<0.02
08-Aug-2015	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
09-Aug-2015	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
10-Aug-2015	1.95	2.17	0.06	0.03	0.06	0.07	0.08	0.07	0.06	<0.02	0.08	0.05	0.08	0.08	0.12	0.11	0.09	0.03
11-Aug-2015	2.13	2.24	0.08	0.04	0.10	0.09	0.12	0.08	0.07	0.02	0.07	0.04	0.09	0.08	0.08	0.04	0.07	0.02
12-Aug-2015	2.00	2.11	0.12	0.06	0.08	0.08	0.09	0.07	0.10	0.04	0.08	0.05	0.11	0.09	0.09	0.06	0.10	0.02
13-Aug-2015	1.91	2.20	0.09	0.04	0.09	0.09	0.11	0.08	0.09	0.02	0.09	0.07	0.10	0.09	0.13	0.08	0.11	0.04
14-Aug-2015	2.05	2.31	0.09	0.04	0.12	0.08	0.21	0.19	0.09	0.04	0.08	0.04	0.10	0.08	0.10	0.05	0.09	0.03
15-Aug-2015	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
16-Aug-2015	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
17-Aug-2015	1.82	2.45	0.10	0.05	0.11	0.09	0.12	0.09	0.08	0.03	0.08	0.05	0.09	0.06	0.08	0.04	0.10	0.03
18-Aug-2015	1.98	2.49	0.12	0.06	0.17	0.10	0.18	0.14	0.17	0.06	0.08	0.05	0.10	0.07	0.12	0.05	0.12	0.02
19-Aug-2015	2.10	2.54	0.13	0.08	0.10	0.08	0.11	0.08	0.16	0.06	0.11	0.04	0.09	0.06	0.09	0.05	0.08	0.02
20-Aug-2015	1.90	2.81	0.13	0.06	0.14	0.10	0.16	0.09	0.12	0.04	0.11	0.05	0.10	0.06	0.09	0.04	0.12	0.03
21-Aug-2015	2.30	2.78	0.12	0.07	0.09	0.08	0.17	0.11	0.11	0.06	0.07	0.03	0.09	0.07	0.07	0.05	0.07	0.02
22-Aug-2015	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
23-Aug-2015	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
24-Aug-2015	2.23	2.79	0.09	0.06	0.08	0.07	0.12	0.08	0.09	0.03	0.06	0.02	0.08	0.06	0.07	0.04	0.08	<0.02
25-Aug-2015	2.15	2.84	0.09	0.05	0.10	0.07	0.11	0.07	0.13	0.06	0.07	0.03	0.07	0.05	0.09	0.05	0.07	<0.02
26-Aug-2015	2.30	2.71	0.08	0.06	0.09	0.08	0.11	0.07	0.07	0.03	0.08	0.03	0.06	0.05	0.04	<0.05	<0.02	
27-Aug-2015	2.01	2.46	0.10	0.07	0.07	0.08	0.09	0.06	0.09	0.04	0.08	0.03	0.09	0.06	0.06	0.04	0.06	<0.02
28-Aug-2015	2.17	2.49	0.09	0.07	0.10	0.08	0.12	0.07	0.09	0.03	0.08	0.03	0.14	0.05	0.08	0.06	0.11	0.02
29-Aug-2015	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
30-Aug-2015	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
31-Aug-2015	2.14	2.26	0.09	0.08	0.10	0.09	0.10	0.08	0.07	0.03	0.08	0.05	0.05	0.05	0.03	0.08	<0.02	
Total number of measurements taken, A:			20		20		20		20		20		20		20		20	
Turbidity Standard for Monitoring Location (NTU):			0.30		0.30		0.30		0.30		0.30		0.30		0.30		0.30	
Number of measurements meeting standard, B:			20		20		20		20		20		20		20		20	
Compliance with Turbidity Standard, C= B/A X 100%:			100%		100%		100%		100%		100%		100%		100%		100%	

NS: No Sample NA: Not Analyzed OL: Off-Line

Comments:

Report Compiled By: H.Demchenko

Approved in LIMS By: C.Diduck



City of Winnipeg

Water and Waste Department

Water Services

WATER TREATMENT PLANT FREE CHLORINE ON-LINE MONITORING REPORT

Deacon Booster Pumping Station

Water System Code: **252.00**Licence Number: **PWS-09-412 AA**Report Created: **01 September 2015**

Report Period: August 2015

Date	BRANCH 1 [mg/L]		BRANCH 2 [mg/L]	
	Average	Minimum	Average	Minimum
1/08/2015	1.17	1.10	1.08	1.01
2/08/2015	1.13	1.05	1.05	0.95
3/08/2015	1.11	1.03	1.01	0.88
4/08/2015	1.15	0.83	1.08	0.80
5/08/2015	1.12	0.90	1.06	0.83
6/08/2015	1.14	0.83	1.05	0.81
7/08/2015	1.20	1.05	1.12	1.01
8/08/2015	1.14	1.00	1.06	0.94
9/08/2015	1.09	0.99	1.05	0.97
10/08/2015	1.13	0.99	1.09	1.00
11/08/2015	1.15	1.05	1.12	1.00
12/08/2015	1.22	1.10	1.15	0.97
13/08/2015	1.13	1.02	1.01	0.87
14/08/2015	1.15	1.02	1.03	0.95
15/08/2015	1.14	1.02	1.08	0.94
16/08/2015	1.18	0.96	1.10	0.88
17/08/2015	1.04	0.91	0.89	0.81
18/08/2015	1.09	0.98	0.95	0.83
19/08/2015	1.14	0.96	1.02	0.90
20/08/2015	1.16	1.04	1.12	0.98
21/08/2015	1.11	0.99	1.13	1.03
22/08/2015	1.15	1.09	1.08	0.98
23/08/2015	1.14	1.07	1.10	0.97
24/08/2015	1.12	1.01	1.11	1.00
25/08/2015	1.06	0.97	1.12	1.02
26/08/2015	1.08	0.94	1.16	1.03
27/08/2015	1.06	0.99	1.02	0.95
28/08/2015	1.05	0.97	1.05	0.93
29/08/2015	1.08	0.94	1.10	0.96
30/08/2015	1.08	1.01	1.05	0.96
31/08/2015	1.01	0.74	1.03	0.74

Total Number of Measurements, A: **21587**Minimum Free Chlorine Standard: **0.50**Number of Measurements Meeting Standard, B: **21587**COMPLIANCE, C = B/A X 100%: **100**

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Chlorine\2015\08-August

Submitted By (Print): D.MerredewSignature: Original signed by D.Merredew



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENVIRONMENTAL STANDARDS DIVISION

WATER TREATMENT PLANT CHLORINE GRAB MONITORING REPORT

Water System Code: 252.00	Deacon Booster Pumping Station Branch 1			Deacon Booster Pumping Station Branch 2		
Licence No. PWS-09-412 AA	Date	Free Chlorine (mg/L)	Total Chlorine (mg/L)	Free Chlorine (mg/L)	Total Chlorine (mg/L)	
		Analyser	Grab	Grab	Analyser	Grab
	01-Aug-2015	NS	NS	NS	NS	NS
	02-Aug-2015	NS	NS	NS	NS	NS
	03-Aug-2015	NS	NS	NS	NS	NS
	04-Aug-2015	0.87	1.16	1.35	0.86	1.03
	05-Aug-2015	1.17	1.19	1.37	1.04	1.07
	06-Aug-2015	1.11	1.20	1.40	1.04	1.12
	07-Aug-2015	1.20	1.26	1.43	1.15	1.10
	08-Aug-2015	NS	NS	NS	NS	NS
	09-Aug-2015	NS	NS	NS	NS	NS
	10-Aug-2015	1.46	1.25	1.40	1.06	1.14
	11-Aug-2015	1.19	1.19	1.35	1.16	1.15
	12-Aug-2015	1.28	1.30	1.45	1.22	1.17
	13-Aug-2015	1.14	1.12	1.28	1.02	1.10
	14-Aug-2015	1.14	1.19	1.42	1.02	1.16
	15-Aug-2015	NS	NS	NS	NS	NS
	16-Aug-2015	NS	NS	NS	NS	NS
	17-Aug-2015	1.08	1.14	1.29	0.93	1.07
	18-Aug-2015	1.10	1.21	1.40	0.91	1.05
	19-Aug-2015	1.04	1.13	1.30	0.94	1.07
	20-Aug-2015	1.22	1.24	1.41	1.12	1.20
	21-Aug-2015	1.12	1.19	1.35	1.12	1.15
	22-Aug-2015	NS	NS	NS	NS	NS
	23-Aug-2015	NS	NS	NS	NS	NS
	24-Aug-2015	1.15	1.20	1.34	1.05	1.11
	25-Aug-2015	1.08	1.18	1.31	1.13	1.23
	26-Aug-2015	1.09	1.17	1.37	1.20	1.24
	27-Aug-2015	1.09	1.18	1.35	1.03	1.12
	28-Aug-2015	1.06	1.06	1.22	1.08	1.08
	29-Aug-2015	NS	NS	NS	NS	NS
	30-Aug-2015	NS	NS	NS	NS	NS
	31-Aug-2015	0.96	1.03	1.17	1.01	1.17
Total number of measurements taken, A:		20			20	
Chlorine Standard for Monitoring Location (mg/L):		0.50			0.50	
Number of measurements meeting standard, B:		20			20	
Compliance with Chlorine Standard, C= B/A X 100%:		100%			100%	

NS: No Sample NA: Not Analyzed OL: Off-Line

Comments:

Report Compiled By: H.Demchenko

Approved in LIMS By: C.Diduck



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
WATER SERVICES

Water System Code: **252.00**
Licence Number: **PWS-09-412 AA**

Report Period: August 2015

Report Created: **Tuesday, September 01, 2015**

Date	Transmittance %	UVR-D100A				UVR-D200A				UVR-D300A				UVR-D400A				UVR-D500A				UVR-D600A				Total				% Volume Treated To Dose		
		Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]						
	Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	To	Total				
01/08/2015	96.14	0.00	0.00	70.16	70.16	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.11	76.47	76.58	0.00	0.00	0.00	0.00	0.00	0.19	68.10	68.29	0.00	0.30	214.73	215.03	99.86			
02/08/2015	95.98	0.00	0.00	67.42	67.42	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	72.75	72.75	0.00	0.00	0.00	0.00	0.00	0.00	65.76	65.76	0.00	0.00	205.93	205.93	100.00		
03/08/2015	96.00	0.00	0.00	63.06	63.06	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	69.02	69.02	0.00	0.00	0.00	0.00	0.00	0.00	62.60	62.60	0.00	0.00	194.69	194.69	100.00		
04/08/2015	95.96	0.00	0.00	67.93	67.93	0.00	0.00	0.00	0.00	0.55	0.55	29.38	30.48	0.00	0.03	35.46	35.48	0.02	0.02	6.05	6.09	0.00	0.20	58.15	58.35	0.58	0.81	196.96	198.34	99.30		
05/08/2015	96.09	0.00	0.00	67.99	67.99	0.00	0.00	0.00	0.00	0.00	0.00	48.43	48.43	0.00	0.00	27.34	27.34	0.00	0.00	16.55	16.55	0.00	0.14	44.16	44.30	0.00	0.14	204.47	204.61	99.93		
06/08/2015	96.11	0.00	0.00	66.55	66.55	0.00	0.00	0.00	0.00	0.00	0.00	19.26	19.26	0.17	0.17	53.84	54.18	0.00	0.00	0.00	0.00	0.00	0.00	66.08	66.08	0.17	0.17	205.73	206.07	99.84		
07/08/2015	96.10	0.00	0.00	67.27	67.27	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	72.82	72.82	0.00	0.00	0.00	0.00	0.00	0.00	64.97	64.97	0.00	0.00	205.06	205.06	100.00		
08/08/2015	96.12	0.00	0.00	66.23	66.23	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	71.58	71.58	0.00	0.00	0.00	0.00	0.00	0.00	64.21	64.21	0.00	0.00	202.02	202.02	100.00		
09/08/2015	95.99	0.00	0.00	65.67	65.67	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	71.43	71.43	0.00	0.00	0.00	0.00	0.00	0.00	64.17	64.17	0.00	0.00	201.26	201.26	100.00		
10/08/2015	95.91	0.00	0.00	64.92	64.92	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	70.81	70.81	0.00	0.00	0.00	0.00	0.00	0.00	63.79	63.79	0.00	0.00	199.51	199.51	100.00		
11/08/2015	95.78	0.00	0.00	67.36	67.36	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	73.01	73.01	0.00	0.00	0.00	0.00	0.00	0.00	65.27	65.27	0.00	0.00	205.65	205.85	100.00		
12/08/2015	95.68	0.00	0.00	67.34	67.34	0.00	0.00	0.00	0.00	0.00	0.00	12.42	12.42	0.00	0.31	60.81	61.11	0.00	0.00	0.00	0.00	0.00	0.00	66.11	66.11	0.00	0.31	206.68	206.98	99.85		
13/08/2015	95.53	0.00	0.00	64.45	64.45	0.00	0.00	0.00	0.00	0.00	0.00	73.25	73.25	0.00	0.00	0.25	0.25	0.00	0.00	0.00	0.00	0.00	0.05	68.96	69.01	0.00	0.05	206.92	206.97	99.97		
14/08/2015	95.51	0.00	0.00	66.35	66.35	0.00	0.00	0.00	0.00	0.00	0.00	75.52	75.52	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	70.89	70.89	0.00	0.00	212.77	212.77	100.00		
15/08/2015	95.61	0.00	0.00	64.77	64.77	0.00	0.00	0.00	0.00	0.00	0.00	73.94	73.94	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.10	70.36	70.46	0.00	0.10	209.06	209.16	99.95		
16/08/2015	95.46	0.00	0.00	64.57	64.57	0.00	0.00	0.00	0.00	0.00	0.00	73.38	73.38	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	69.05	69.05	0.00	0.00	207.00	207.00	100.00		
17/08/2015	95.58	0.10	0.10	68.94	69.14	0.00	0.00	0.00	0.00	0.00	0.00	67.32	67.32	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	70.49	70.54	0.10	0.14	206.76	207.00	99.88		
18/08/2015	95.57	0.00	0.00	81.09	81.09	0.00	0.00	0.00	0.00	0.00	0.00	54.83	54.83	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	71.84	71.84	0.00	0.00	207.76	207.76	100.00		
19/08/2015	95.67	0.00	0.00	55.43	55.43	0.00	0.00	0.00	0.00	0.00	0.00	63.06	63.06	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	43.26	43.26	0.00	0.05	48.17	48.22	99.98		
20/08/2015	95.75	0.00	1.13	63.04	64.17	0.00	0.00	0.00	0.00	0.00	0.00	63.93	63.93	0.00	0.00	24.43	24.43	0.00	0.00	59.51	59.51	0.00	0.00	0.00	0.00	1.13	210.90	212.04	99.47			
21/08/2015	95.82	0.00	0.13	20.03	20.15	0.00	0.00	0.00	0.00	0.00	0.00	76.56	76.56	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	55.79	55.79	0.00	0.13	214.88	215.01	99.94		
22/08/2015	95.83	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	81.71	81.71	0.00	0.00	1.44	1.44	0.00	0.06	67.27	67.33	0.00	0.05	61.95	62.00	0.00	0.11	212.36	212.47	99.95		
23/08/2015	95.97	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	82.61	82.61	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	45.00	45.00	0.00	0.00	206.85	206.85	100.00		
24/08/2015	96.26	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	71.18	71.18	0.00	0.00	20.23	20.23	0.00	0.00	78.83	78.83	0.00	0.00	0.00	0.00	29.77	29.77	0.00	0.00	200.01	200.01	100.00
25/08/2015	96.28	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	55.12	55.12	0.00	0.00	59.74	59.74	0.00	0.00	85.13	85.13	0.00	0.00	0.00	0.00	0.00	0.00	199.99	199.99	100.00		
26/08/2015	96.23	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	54.31	54.31	0.00	0.00	61.42	61.42	0.64	0.64	49.89	51.16	0.00	0.00	33.18	33.18	0.64	0.64	198.80	200.07	99.36		
27/08/2015	96.26	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	55.42	55.42	0.00	0.00	70.65	70.65	0.00	0.00	0.00	0.00	0.00	0.16	73.75	73.91	0.00	0.16	199.83	199.98	99.92		
28/08/2015	96.15	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	55.94	55.94	0.00	0.00	71.01	71.01	0.00	0.00	0.00	0.00	0.00	0.00	73.02	73.02	0.00	0.00	199.96	199.96	100.00		
29/08/2015	96.12	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	56.20	56.20	0.00	0.00	70.85	70.85	0.00	0.00	0.00	0.00	0.00	0.00	73.01	73.01	0.00	0.00	200.07	200.07	100.00		
30/08/2015	96.18	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	56.14	56.14	0.00	0.00	70.43	70.43	0.00	0.00	0.00	0.00	0.00	0.00	73.04	73.04	0.00	0.00	199.61	199.61	100.00		
31/08/2015	95.32	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.02	0.02	54.82	54.82	0.01	0.01	66.40	66.43	0.00	0.00	0.00	0.00	0.02	0.07	70.21	70.29	0.06	0.11	191.43	191.59	99.91

Water Volume [%]:

Untreated: 0.02 %

Below Dose 0.07 %

To Dose 99.91 %

Note: UVR-D200A offline, pending mechanical upgrades

Submitted By (Print): D.Merredew

Signature: Original signed by D.Merredew