



Water and Waste Department • Service des eaux et des déchets

April 7, 2015

Our File: 040-18-18-55-00

Melanie Betsill
Office of Drinking Water
Manitoba Conservation and Water Stewardship
1007 Century Street
Winnipeg, Manitoba
R3H 0W4

Dear Ms. Betsill:

**RE: MARCH 2015 WATER QUALITY COMPLIANCE
SUBMISSION FOR THE CITY OF WINNIPEG WATER SUPPLY SYSTEM**

Please find attached on-line and grab turbidity summary reports, on-line and grab chlorine summary reports and the UV summary report for the Water Treatment Plant for March 2015. We have included one corrective action report for a low free chlorine residual in the distribution system.

The March on-line and grab sampling turbidity reports include results obtained for the Water Treatment Plant raw water and the eight filters. The turbidity results for the effluent from the filters are in compliance with the licence requirements. We continue to have filter 8 out of service for maintenance issues. There is currently no impact on any of the treatment process at this time.

The March on-line and grab sampling chlorine reports include results obtained for the Deacon Booster Pumping Station at the Water Treatment Plant. The free chlorine results at the Water Treatment Plant have met the licence requirements. On March 5, a distribution system low free chlorine result was reported during resampling for a high HPC result [REDACTED]

[REDACTED] As corrective actions to the low free chlorine result, we sampled various locations around the area, flushed the area, and checked the infrastructure for possible closed and broken valves. Chlorine levels were monitored until results for free chlorine were reported acceptable. Please see the attached corrective action report for additional details.

The UV submission includes the summary report for March 2015 in accordance with Section 4.13, Table 2 of the Operating Licence. The UV licence requirement has been met for March.

Please let me know of any concerns or questions respecting this submission. I may be reached by telephone at 204-986-8359 or by e-mail at rgrosselle@winnipeg.ca.

Thanks for your ongoing cooperation and understanding in this matter.

Yours sincerely,

Original Signed by:

R. Grosselle
Manager of Environmental Standards
Attachments

c:(e-mail)

Dr. L. Richards, Winnipeg Regional Health Authority
Dr. H. Chang, Winnipeg Regional Health Authority
Dr. S. Roberecki, Manitoba Health
D.P. Sacher, P.Eng.
G. Patton, P.Eng.
T. Shanks, P.Eng.
A. J. Weremy, P.Eng.
C. Diduck

N:\Compliance Reporting\Submittal Letters\2015\ODW- Letters\Betsill Water 2015-03.doc



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
WATER SERVICES

Water System Code: **252.00**
Licence Number: **PWS-09-412 AA**

WATER TREATMENT PLANT TURBIDITY ON-LINE MONITORING REPORT

March 2015 Turbidity (NTU)

Date	Raw		Filter #1		Filter #2		Filter #3		Filter #4		Filter #5		Filter #6		Filter #7		Filter #8	
	Avg	Avg	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max
1/03/2015	0.65	0.04	0.10		0.05	0.10	0.08	0.15	0.05	0.10	0.03	0.07	0.04	0.08	0.07	0.09	OL	OL
2/03/2015	0.66	0.06	0.10		0.07	0.16	0.10	0.18	0.06	0.13	0.05	0.07	0.05	0.11	0.08	0.13	OL	OL
3/03/2015	0.67	0.07	0.13		0.06	0.12	0.10	0.19	0.07	0.10	0.04	0.10	0.05	0.10	0.07	0.14	OL	OL
4/03/2015	0.67	0.03	0.14		0.07	0.12	0.12	0.30	0.07	0.13	0.04	0.09	0.04	0.12	0.07	0.13	OL	OL
5/03/2015	0.66	0.07	0.13		0.07	0.12	0.10	0.20	0.07	0.15	0.05	0.13	0.08	0.10	0.10	0.12	OL	OL
6/03/2015	0.67	0.06	0.12		0.07	0.13	0.10	0.20	0.08	0.20	0.07	0.10	0.08	0.15	0.11	0.18	OL	OL
7/03/2015	0.66	0.06	0.08		0.06	0.11	0.09	0.17	0.06	0.09	0.06	0.12	0.07	0.13	0.09	0.16	OL	OL
8/03/2015	0.67	0.06	0.11		0.06	0.08	0.08	0.18	0.07	0.26	0.06	0.11	0.07	0.14	0.09	0.16	OL	OL
9/03/2015	0.67	0.06	0.12		0.06	0.12	0.10	0.14	0.06	0.13	0.05	0.11	0.06	0.09	0.08	0.16	OL	OL
10/03/2015	0.67	0.05	0.11		0.06	0.12	0.09	0.18	0.06	0.12	0.05	0.07	0.08	0.14	0.10	0.12	OL	OL
11/03/2015	0.67	0.06	0.08		0.06	0.12	0.09	0.18	0.06	0.09	0.07	0.12	0.07	0.14	0.09	0.16	OL	OL
12/03/2015	0.68	0.06	0.12		0.06	0.08	0.09	0.17	0.07	0.14	0.06	0.12	0.07	0.14	0.08	0.15	OL	OL
13/03/2015	0.69	0.05	0.11		0.06	0.15	0.10	0.13	0.06	0.12	0.05	0.11	0.06	0.08	0.08	0.16	OL	OL
14/03/2015	0.68	0.05	0.10		0.05	0.11	0.08	0.15	0.06	0.13	0.05	0.07	0.07	0.13	0.11	0.13	OL	OL
15/03/2015	0.68	0.06	0.08		0.05	0.10	0.08	0.16	0.06	0.12	0.06	0.10	0.07	0.13	0.10	0.19	OL	OL
16/03/2015	0.67	0.05	0.10		0.05	0.07	0.08	0.16	0.06	0.12	0.05	0.10	0.06	0.13	0.09	0.15	OL	OL
17/03/2015	0.66	0.05	0.10		0.04	0.08	0.09	0.12	0.04	0.11	0.05	0.11	0.05	0.08	0.08	0.14	OL	OL
18/03/2015	0.66	0.04	0.08		0.03	0.05	0.06	0.12	0.03	0.07	0.03	0.07	0.05	0.09	0.07	0.09	OL	OL
19/03/2015	0.67	0.04	0.08		0.03	0.07	0.07	0.12	0.03	0.08	0.04	0.06	0.04	0.08	0.08	0.11	OL	OL
20/03/2015	0.67	0.05	0.07		0.03	0.05	0.07	0.12	0.03	0.05	0.04	0.08	0.04	0.09	0.07	0.12	OL	OL
21/03/2015	0.69	0.04	0.08		0.03	0.04	0.07	0.14	0.04	0.07	0.04	0.07	0.04	0.08	0.07	0.12	OL	OL
22/03/2015	0.70	0.05	0.10		0.03	0.07	0.09	0.13	0.04	0.09	0.03	0.07	0.03	0.05	0.06	0.11	OL	OL
23/03/2015	0.71	0.05	0.28		0.04	0.36	0.08	0.40	0.03	0.15	0.03	0.07	0.04	0.09	0.07	0.11	OL	OL
24/03/2015	0.70	0.05	0.07		0.03	0.07	0.08	0.29	0.03	0.09	0.04	0.07	0.03	0.07	0.06	0.11	OL	OL
25/03/2015	0.67	0.04	0.21		0.03	0.16	0.08	0.30	0.03	0.14	0.03	0.14	0.02	0.08	0.04	0.11	OL	OL
26/03/2015	0.68	0.04	0.08		0.02	0.05	0.07	0.11	0.03	0.07	0.03	0.07	0.04	0.05	0.06	0.08	OL	OL
27/03/2015	0.69	0.04	0.06		0.02	0.06	0.07	0.15	0.03	0.08	0.04	0.05	0.03	0.07	0.07	0.10	OL	OL
28/03/2015	0.68	0.05	0.09		0.03	0.05	0.11	0.40	0.03	0.06	0.04	0.08	0.04	0.08	0.06	0.11	OL	OL
29/03/2015	0.67	0.04	0.08		0.03	0.04	0.08	0.22	0.04	0.07	0.04	0.07	0.04	0.08	0.06	0.12	OL	OL
30/03/2015	0.67	0.04	0.08		0.03	0.06	0.09	0.15	0.03	0.07	0.04	0.07	0.04	0.05	0.06	0.11	OL	OL
31/03/2015	0.68	0.04	0.08		0.03	0.06	0.07	0.21	0.03	0.19	0.03	0.05	0.04	0.08	0.07	0.09	OL	OL

Total Number of Measurements Taken, A: 15682
Turbidity Standard for Monitoring Location (NTU): 0.30
Number of Measurements Meeting Standard, B: 15682
Compliance with Turbidity Standard, C = B/A X 100%: 100.00%

0.30 0.30 0.30 0.30 0.30 0.30 0.30 0.30 0.30 0.30 0.30 0.30 0.30 0.30 0.30 0.30 0.30 0.30 0.30

15757 15455 14416 16793 16674 15100 0.30
15742 15426 14416 16793 16674 15100 0.30
99.91% 99.81% 100.00% 100.00% 100.00% 100.00% 0.30

OL: Offline

Note: Filter 8 is offline for maintenance

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Turbidity\2015\03-March

Submitted By (Print) M.Szmon for A.Weremy

Signature Original signed by M.Szmon for A.Weremy



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENVIRONMENTAL STANDARDS DIVISION

WATER TREATMENT PLANT TURBIDITY GRAB MONITORING REPORT

Water System Code: 252.00	Turbidity (NTU)									
Licence No. PWS-09-412 AA	Date	Raw Water	Filter 1	Filter 2	Filter 3	Filter 4	Filter 5	Filter 6	Filter 7	Filter 8
	01-Mar-2015	NS	NS	NS	NS	NS	NS	NS	NS	OL
	02-Mar-2015	0.59	0.09	0.09	0.18	0.06	0.08	0.12	0.09	OL
	03-Mar-2015	0.56	0.11	0.11	0.12	0.17	0.12	0.08	0.17	OL
	04-Mar-2015	0.57	0.17	0.11	0.15	0.13	0.07	0.07	0.10	OL
	05-Mar-2015	0.53	0.13	0.13	0.17	0.12	0.11	0.18	0.12	OL
	06-Mar-2015	0.55	0.12	0.20	0.22	0.12	0.17	0.23	0.13	OL
	07-Mar-2015	NS	NS	NS	NS	NS	NS	NS	NS	OL
	08-Mar-2015	NS	NS	NS	NS	NS	NS	NS	NS	OL
	09-Mar-2015	0.82	0.18	0.18	0.14	0.16	0.14	0.13	0.18	OL
	10-Mar-2015	0.58	0.10	0.14	0.16	0.15	0.19	0.13	0.18	OL
	11-Mar-2015	0.75	0.17	0.10	0.13	0.15	0.13	0.13	0.14	OL
	12-Mar-2015	0.52	0.12	0.09	0.11	0.16	0.15	0.12	0.10	OL
	13-Mar-2015	0.66	0.13	0.14	0.16	0.16	0.18	0.18	0.14	OL
	14-Mar-2015	NS	NS	NS	NS	NS	NS	NS	NS	OL
	15-Mar-2015	NS	NS	NS	NS	NS	NS	NS	NS	OL
	16-Mar-2015	0.54	0.09	0.08	0.14	0.24	0.23	0.20	0.15	OL
	17-Mar-2015	0.54	0.12	0.09	0.10	0.17	0.09	0.13	0.08	OL
	18-Mar-2015	0.55	0.15	0.09	0.11	0.06	0.13	0.08	0.18	OL
	19-Mar-2015	0.58	0.07	0.07	0.12	0.09	0.08	0.11	0.08	OL
	20-Mar-2015	0.56	0.14	0.08	0.07	0.14	0.08	0.10	0.12	OL
	21-Mar-2015	NS	NS	NS	NS	NS	NS	NS	NS	OL
	22-Mar-2015	NS	NS	NS	NS	NS	NS	NS	NS	OL
	23-Mar-2015	0.67	0.09	0.08	0.12	0.17	0.13	0.18	0.19	OL
	24-Mar-2015	0.66	0.10	0.08	0.19	0.06	0.09	0.09	0.18	OL
	25-Mar-2015	0.76	0.12	0.12	0.18	0.12	0.15	0.13	0.08	OL
	26-Mar-2015	0.53	0.06	0.08	0.09	0.07	0.07	0.07	0.06	OL
	27-Mar-2015	0.63	0.09	0.19	0.11	0.14	0.16	0.11	0.08	OL
	28-Mar-2015	NS	NS	NS	NS	NS	NS	NS	NS	OL
	29-Mar-2015	NS	NS	NS	NS	NS	NS	NS	NS	OL
	30-Mar-2015	0.53	0.14	0.12	0.24	0.08	0.08	0.08	0.07	OL
	31-Mar-2015	0.51	0.07	0.07	0.13	0.09	0.08	0.08	0.09	OL
Total number of measurements taken, A:		22	22	22	22	22	22	22	22	0
Turbidity Standard for Monitoring Location (NTU):		0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30
Number of measurements meeting standard, B:		22	22	22	22	22	22	22	22	0
Compliance with Turbidity Standard, C= B/A X 100%:		100%	100%	100%	100%	100%	100%	100%	100%	OL

NS: No Sample NA: Not Analyzed OL: Off-Line

Comments:

Effective, December 22, 2014, filter 8 has been put offline for maintenance issues.

Report Compiled By: H.Demchenko

Approved in LIMS By: C.Diduck

Date Approved: 1-Apr-15



City of Winnipeg

Water and Waste Department

Water Services

WATER TREATMENT PLANT FREE CHLORINE ON-LINE MONITORING REPORT
Deacon Booster Pumping Station

Water System Code: **252.00**

Licence Number: **PWS-09-412 AA**

Report Created: **01 April 2015**

Report Period: March 2015

Date	BRANCH 1 [mg/L]		BRANCH 2 [mg/L]	
	Average	Minimum	Average	Minimum
1/03/2015	1.04	0.99	1.01	0.96
2/03/2015	1.02	0.95	1.01	0.96
3/03/2015	1.01	0.92	0.98	0.94
4/03/2015	1.06	0.97	1.05	0.95
5/03/2015	1.05	0.96	1.14	1.05
6/03/2015	1.06	1.00	1.16	1.11
7/03/2015	1.05	1.01	1.13	1.08
8/03/2015	1.00	0.94	1.07	1.02
9/03/2015	0.98	0.95	1.05	1.01
10/03/2015	0.96	0.91	1.02	0.96
11/03/2015	0.98	0.92	1.02	0.88
12/03/2015	1.00	0.94	1.00	0.90
13/03/2015	1.00	0.95	0.96	0.88
14/03/2015	1.05	0.98	1.11	0.99
15/03/2015	1.04	0.98	1.10	1.04
16/03/2015	1.05	1.01	1.09	1.06
17/03/2015	1.02	0.96	0.99	0.92
18/03/2015	1.07	0.97	1.06	0.97
19/03/2015	1.07	1.01	1.17	1.06
20/03/2015	1.02	0.98	1.18	1.10
21/03/2015	1.05	0.96	1.18	1.07
22/03/2015	1.07	1.01	1.19	1.12
23/03/2015	1.05	0.77	1.06	0.86
24/03/2015	1.02	0.96	1.15	1.07
25/03/2015	0.95	0.63	1.05	0.72
26/03/2015	0.93	0.87	1.28	1.15
27/03/2015	0.96	0.87	1.17	1.03
28/03/2015	1.00	0.94	1.10	1.04
29/03/2015	0.99	0.94	1.08	1.01
30/03/2015	0.96	0.91	1.06	1.01
31/03/2015	1.00	0.95	1.02	0.92

Total Number of Measurements, A: **21571** 21568

Minimum Free Chlorine Standard: **0.50** 0.50

Number of Measurements Meeting Standard, B: **21571** 21568

COMPLIANCE, C = B/A X 100%: **100** 100

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Chlorine\2015\03-March

Submitted By (Print): M.Szmon for A.Weremy

Signature: Original signed by M.Szmon for A.Weremy



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENVIRONMENTAL STANDARDS DIVISION

WATER TREATMENT PLANT CHLORINE GRAB MONITORING REPORT				
Water System Code: 252.00	Deacon Booster Pumping Station Branch 1		Deacon Booster Pumping Station Branch 2	
Licence No. PWS-09-412 AA	Date	Free Chlorine (mg/L)	Total Chlorine (mg/L)	Free Chlorine (mg/L)
	01-Mar-2015	NS	NS	NS
	02-Mar-2015	1.05	1.21	1.07
	03-Mar-2015	1.10	1.21	1.02
	04-Mar-2015	1.02	1.21	1.07
	05-Mar-2015	1.11	1.26	1.16
	06-Mar-2015	1.13	1.31	1.15
	07-Mar-2015	NS	NS	NS
	08-Mar-2015	NS	NS	NS
	09-Mar-2015	1.02	1.15	1.13
	10-Mar-2015	1.02	1.20	1.06
	11-Mar-2015	0.98	1.17	0.96
	12-Mar-2015	1.09	1.23	1.08
	13-Mar-2015	1.11	1.24	1.06
	14-Mar-2015	NS	NS	NS
	15-Mar-2015	NS	NS	NS
	16-Mar-2015	1.03	1.20	1.14
	17-Mar-2015	1.09	1.25	1.04
	18-Mar-2015	1.02	1.17	1.01
	19-Mar-2015	1.08	1.24	1.11
	20-Mar-2015	1.10	1.23	1.15
	21-Mar-2015	NS	NS	NS
	22-Mar-2015	NS	NS	NS
	23-Mar-2015	1.12	1.26	1.13
	24-Mar-2015	1.01	1.17	1.12
	25-Mar-2015	0.92	1.12	0.99
	26-Mar-2015	1.07	1.18	1.13
	27-Mar-2015	1.00	1.19	1.10
	28-Mar-2015	NS	NS	NS
	29-Mar-2015	NS	NS	NS
	30-Mar-2015	0.99	1.18	1.02
	31-Mar-2015	1.06	1.20	1.07
Total number of measurements taken, A:	22		22	
Chlorine Standard for Monitoring Location (mg/L):	0.50		0.50	
Number of measurements meeting standard, B:	22		22	
Compliance with Chlorine Standard, C= B/A X 100%:	100%		100%	

NS: No Sample NA: Not Analyzed OL: Off-Line

Comments:

Report Compiled By: H.Demchenko

Approved in LIMS By: C.Diduck



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
WATER SERVICES

Water System Code: 252.00
Licence Number: PWS-09-412 AA

WATER TREATMENT PLANT UV REPORT

Report Period: March 2015

Report Created: Wednesday, April 01, 2015

Date	Transmittance %	UVR-D100A				UVR-D200A				UVR-D300A				UVR-D400A				UVR-D500A				UVR-D600A				Total Water Volume [ML]				% Volume Treated To Dose		
		Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]						
		Untreated	Below T	o	Total	Untreated	Below	To	Total	Untreated	Below	To	Total																			
01/03/2015	92.96	0.00	0.00	63.02	63.02	0.00	0.00	0.00	0.00	0.00	0.00	60.06	60.06	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	69.93	69.98	0.00	0.05	193.01	193.06	99.97		
02/03/2015	92.52	0.00	0.00	63.00	63.00	0.00	0.00	0.00	0.00	0.00	0.00	60.09	60.09	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	69.94	69.94	0.00	0.00	193.03	193.03	100.00	
03/03/2015	92.46	0.00	0.00	63.19	63.19	0.00	0.00	0.00	0.00	0.00	0.00	60.17	60.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	70.13	70.13	0.00	0.00	193.49	193.49	100.00	
04/03/2015	92.43	0.00	0.00	64.61	64.61	0.00	0.00	0.00	0.00	0.00	0.00	61.08	61.08	0.00	0.00	0.00	0.00	0.00	0.00	30.60	30.60	0.00	0.00	40.71	40.71	0.00	0.00	197.00	197.00	100.00		
05/03/2015	92.00	0.00	0.45	64.69	65.14	0.00	0.00	0.00	0.00	0.00	0.00	60.22	60.22	0.00	0.00	0.00	0.00	0.00	0.00	71.08	71.08	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.45	195.99	196.44	99.77
06/03/2015	91.90	0.00	0.39	62.62	63.01	0.00	0.00	1.19	1.19	0.00	0.00	59.68	59.68	0.00	0.00	1.37	1.37	0.00	0.00	68.74	68.74	0.00	0.00	0.00	0.00	0.00	0.39	193.61	194.00	99.80		
07/03/2015	92.29	0.00	0.00	61.00	61.00	0.00	0.00	0.00	0.00	0.00	0.00	60.50	60.50	0.00	0.00	0.00	0.00	0.00	0.00	72.52	72.52	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	194.02	194.02	100.00
08/03/2015	92.27	0.00	0.00	59.99	59.99	0.00	0.00	0.00	0.00	0.00	0.00	60.84	60.84	0.00	0.00	0.00	0.00	0.00	0.00	73.10	73.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	193.94	193.94	100.00
09/03/2015	92.24	0.00	0.13	59.87	59.99	0.00	0.00	0.00	0.00	0.00	0.00	61.04	61.04	0.00	0.00	0.00	0.00	0.00	0.00	72.96	72.96	0.00	0.00	0.00	0.00	0.00	0.13	193.86	193.99	99.93		
10/03/2015	92.24	0.07	0.20	38.00	38.26	0.00	0.00	24.02	24.02	0.00	0.00	60.42	60.42	0.00	0.00	0.00	0.00	0.00	0.00	71.26	71.26	0.00	0.00	0.00	0.00	0.07	0.20	193.71	193.97	99.86		
11/03/2015	92.22	0.00	0.00	0.00	0.00	0.00	0.00	66.51	66.51	0.00	0.00	58.85	58.85	0.00	0.00	0.00	0.00	0.00	0.00	67.52	67.52	0.00	0.02	1.08	1.11	0.00	0.02	193.97	194.00	99.99		
12/03/2015	92.23	0.00	0.00	0.00	0.00	0.00	0.00	69.71	69.71	0.00	0.00	55.03	55.03	0.00	0.00	0.00	0.00	0.00	0.00	45.95	45.95	0.00	0.00	26.07	26.07	0.00	0.00	196.76	196.77	100.00		
13/03/2015	92.54	0.00	0.00	0.00	0.00	0.00	0.00	72.45	72.45	0.00	0.00	25.09	25.09	0.00	0.03	26.27	26.30	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	73.15	73.15	0.00	0.03	196.95	196.98	99.98
14/03/2015	92.49	0.00	0.00	0.00	0.00	0.00	0.00	69.59	69.59	0.00	0.00	0.00	0.00	0.00	0.00	60.25	60.25	0.00	0.00	47.97	47.97	0.00	0.05	19.12	19.17	0.00	0.05	196.92	196.97	99.98		
15/03/2015	92.55	0.00	0.00	0.00	0.00	0.00	0.00	69.40	69.40	0.00	0.00	0.00	0.00	0.00	0.00	60.19	60.19	0.00	0.00	66.86	66.86	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	196.45	196.45	100.00
16/03/2015	92.68	0.00	0.00	0.00	0.00	0.00	0.00	69.20	69.20	0.00	0.00	0.00	0.00	0.00	0.00	60.17	60.17	0.00	0.00	66.62	66.62	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	195.99	195.99	100.00
17/03/2015	92.78	0.00	0.00	0.00	0.00	0.00	0.00	64.51	64.51	0.00	0.00	0.00	0.00	0.00	0.00	62.08	62.08	0.00	0.00	10.25	10.25	0.00	0.03	51.39	51.42	0.00	0.03	188.23	188.26	99.98		
18/03/2015	93.32	0.00	0.00	0.00	0.00	0.00	0.00	67.01	67.01	0.00	0.00	0.00	0.00	0.00	0.00	65.81	65.81	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	64.13	64.13	0.00	0.00	196.95	196.95	100.00
19/03/2015	93.10	0.00	0.00	0.00	0.00	0.00	0.00	67.14	67.14	0.00	0.00	0.00	0.00	0.00	0.00	65.78	65.78	0.00	0.00	34.65	34.65	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	198.44	198.44	100.00
20/03/2015	93.02	0.00	0.00	0.00	0.00	0.00	0.00	69.06	69.06	0.00	0.00	0.00	0.00	0.00	0.00	65.93	65.93	0.00	0.00	68.57	68.57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	203.57	203.57	100.00
21/03/2015	93.07	0.00	0.00	0.00	0.00	0.00	0.00	66.43	66.43	0.00	0.00	0.00	0.00	0.00	0.00	63.83	63.83	0.00	0.00	65.84	65.84	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	196.11	196.11	100.00
22/03/2015	93.05	0.00	0.00	0.00	0.00	0.00	0.00	66.22	66.22	0.00	0.00	0.00	0.00	0.00	0.00	64.22	64.22	0.00	0.00	65.56	65.56	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	196.00	196.00	100.00
23/03/2015	92.92	0.00	0.00	0.00	0.00	0.02	0.02	66.93	66.98	0.00	0.00	0.00	0.00	0.01	0.01	50.50	50.53	0.01	0.01	60.58	60.60	0.00	0.00	0.00	0.00	0.05	0.05	0.00	0.00	178.01	178.11	99.95
24/03/2015	93.09	0.00	0.00	0.00	0.00	0.00	0.00	27.08	27.08	0.00	0.00	35.24	35.24	0.00	0.00	53.77	53.77	0.00	0.00	80.04	80.04	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	196.13	196.13	100.00
25/03/2015	92.63	0.00	0.00	0.00	0.00	0.06	29.21	29.27	0.01	0.01	17.45	17.47	0.20	0.20	46.47	46.87	0.09	0.13	52.01	52.23	0.00	0.00	0.00	0.01	0.31	0.41	145.14	145.85	99.51			
26/03/2015	93.19	0.00	0.00	0.00	0.00	0.00	63.09	63.09	0.00	0.00	0.00	0.00	0.00	0.00	62.73	62.73	0.00	0.00	60.11	60.11	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	185.94	185.94	100.00	
27/03/2015	93.12	0.00	0.00	0.00	0.00	0.00	0.00	65.81	65.81	0.00	0.00	0.00	0.00	0.00	0.00	65.63	65.63	0.00	0.00	62.43	62.43	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	193.86	193.86	100.00
28/03/2015	92.98	0.00	0.00	0.00	0.00	0.00	0.00	78.73	78.73	0.00	0.00	0.00	0.00	0.00	0.00	57.28	57.28	0.00	0.00	61.99	61.99	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	198.00	198.00	100.00
29/03/2015	93.07	0.00	0.00	0.00	0.00	0.00	0.00	75.26	75.26	0.00	0.00	0.00	0.00	0.00	0.00	54.81	54.81	0.00	0.00	63.03	63.03	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	193.10	193.10	100.00
30/03/2015	93.21	0.00	0.00	0.00	0.00	0.00	0.00	69.10	69.10	0.00	0.00	0.00	0.00	0.00	0.00	57.99	57.99	0.00	0.00	66.10	66.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	193.19	193.19	100.00
31/03/2015	93.22	0.00	0.00	0.00	0.00	0.00	0.00	48.29	48.29	0.00	0.00	38.45	38.45	0.00	0.00	37.75	37.7															



Water and Waste Department • Service des eaux et des déchets

Tuesday, March 31, 2015

Our Incident/Report No: 02-2015

LIMS Reference No: 41862

Ms. Melanie Betsill
Drinking Water Officer
Manitoba Water Stewardship, Office of Drinking Water
1007 Century Street
Winnipeg MB R3H 0W4

RE: CORRECTIVE ACTION REPORT

WATER SYSTEM	Winnipeg Public Water System
WATER SYSTEM CODE	252.00
LOCATION OF NON-COMPLIANT INCIDENT	Winnipeg 3-Dist WC05
OPERATOR IN CHARGE	NA
INCIDENT REPORTED BY	Courtney Diduck, Analytical Services Branch Head
TYPE OF NON-COMPLIANT INCIDENT	Low disinfection residual in the distribution system, 22(1) MR 40/2007
INCIDENT DATE	March 5, 2015
DESCRIPTION OF CORRECTIVE ACTIONS	IMMEDIATELY: Re-sampled original location and tested additional samples upstream and downstream for free/total chlorine, bacteria, and temperature, and contacted the ODW. Water Services Division was contacted and the area was checked for closed valves and spot flushed. All closed valves were located and opened and free chlorine residuals were re-established to acceptable levels.
TEST RESULTS	See Attached

NOTES/COMMENTS:

1. All microbiological tests performed by contract laboratory.
2. UP/DOWN STREAM testing performed when EC is >0 /100mL, TC is >10 /100mL or when sample/consecutive sample is positive for EC or TC or as directed by the Manager of Environmental Standards Division and/or the Office of Drinking Water
3. INITIAL chlorine, turbidity and temperature only tested at the required 39 sample locations.
4. NR-No Result due to laboratory/analyst error.
5. NA-Not Analyzed.

EMERGENCY REPORTING IS REQUIRED WHERE A POTENTIAL HEALTH RISK IS INVOLVED. FOLLOW THE INSTRUCTIONS OF YOUR DRINKING WATER OFFICER ON SITUATIONS REQUIRING IMMEDIATE REPORTING

DISTRIBUTION

FORWARD THE ORIGINAL TO THE DRINKING WATER OFFICER WITH THE MONTHLY COMPLIANCE SUBMISSIONS.

Contact the Drinking Water Officer for any comments, questions or concerns

REFERENCE: ODW-RF-016

Embrace the spirit • Vivez l'esprit

Environmental Standards Division • Division des normes environnementales
2230 Main Street • 2230, rue Main • Winnipeg • Manitoba R2V 4T8
fax/téléc. (204) 339-2147 • www.winnipeg.ca

Sample Name	Sample Number	Date Sampled	bacColiEsch-QT (MPNU/100mL)	bacColiTotal-QT (MPNU/100mL)	bacHPC (cfu/mL)	Chlorine, Free (mg/L)	Chlorine, Total (mg/L)	Temperature (°C)	Turbidity (ntu)	Time Sampled (hrs)
WC05_	425812	05-Mar-15	<1	<1	>3000	0.09	0.17	6.9	0.50	11:56
WC05_	425821	05-Mar-15	<1	<1	>3000	0.05	0.15	4.7	0.52	12:57
WC05_	425822	05-Mar-15	<1	<1	<10	0.04	0.17	4.0	0.64	12:33
WC05_	426404	06-Mar-15	NA	NA	NA	0.53	0.68	5.6	NA	14:01
WC05_	426405	06-Mar-15	NA	NA	NA	0.59	0.76	4.1	NA	14:22
WC05_	426406	06-Mar-15	NA	NA	NA	0.54	0.72	6.5	NA	14:12