



Water and Waste Department • Service des eaux et des déchets

September 7, 2016

Melanie Betsill
Office of Drinking Water
Manitoba Sustainable Development
1007 Century Street
Winnipeg, Manitoba R3H 0W4

Our File: 040-18-18-55-00

Dear Ms. Betsill:

**RE: AUGUST 2016 WATER QUALITY COMPLIANCE
SUBMISSION FOR THE CITY OF WINNIPEG WATER SUPPLY SYSTEM**

Please find attached on-line and grab turbidity summary reports, on-line and grab chlorine summary reports and the UV summary report for the Water Treatment Plant for August 2016. We have included one corrective action report for a positive total coliform in the distribution system.

The August on-line and grab sampling turbidity reports include results obtained for the Water Treatment Plant raw water and the eight filters. Please note that on August 10, the maximum turbidity for Filter 3 was greater than 0.3 NTU, and on August 25, the maximum turbidities on Filters 2, 3, 5, 6, and 8 were greater than 0.3 NTU; the elevated turbidities occurred for short periods of time which did not exceed 12 consecutive hours. The turbidity results for the effluent from the filters met the licence requirements.

The August on-line and grab sampling chlorine reports include results obtained for the Deacon Booster Pumping Station at the Water Treatment Plant. The free chlorine results at the Water Treatment Plant met the licence requirements.

On August 16th, a positive total coliform result was reported for a routine sample at the NW03 location. On August 17th and 18th, the location was resampled and results were reported to be negative. Our resampling also indicated that the chlorine levels at the location were normal and provided adequate disinfection. Please see the attached corrective action report for additional details.

The August UV summary report includes results obtained for the six UV reactors at the Water Treatment Plant. The UV disinfection results met the licence requirements.

Please let me know of any concerns or questions respecting this submission. I may be reached by telephone at 204-986-8359 or by e-mail at rgrosselle@winnipeg.ca.

Yours sincerely,

Original signed by:

R. Grosselle
Manager of Environmental Standards
Attachments

c:(e-mail)

Dr. L. Richards, Winnipeg Regional Health Authority
Dr. H. Chang, Winnipeg Regional Health Authority
Dr. S. Roberecki, Manitoba Health, Healthy Living and Seniors
M. L. Geer, CPA, CA
G. Patton, P.Eng.
T. Shanks, P.Eng.
M. Szmon, P.Eng.
C. Diduck

N:\Compliance Reporting\Submittal Letters\2016\ODW - Monthly Compliance Letters\ODW Letter 2016-08.doc



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
WATER SERVICES

Water System Code: **252.00**
Licence Number: **PWS-09-412-01**

WATER TREATMENT PLANT TURBIDITY ON-LINE MONITORING REPORT

August 2016 Turbidity (NTU)

Date	Raw		Filter #1		Filter #2		Filter #3		Filter #4		Filter #5		Filter #6		Filter #7		Filter #8	
	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max
1/08/2016	2.24	0.06	0.14	0.10	0.15	0.10	0.21	0.07	0.18	0.06	0.12	0.08	0.09	0.03	0.08	0.02	0.07	
2/08/2016	2.37	0.06	0.14	0.09	0.16	0.13	0.17	0.07	0.14	0.05	0.11	0.07	0.12	0.03	0.07	0.02	0.03	
3/08/2016	2.95	0.08	0.12	0.08	0.15	0.11	0.18	0.06	0.09	0.06	0.12	0.08	0.19	0.04	0.07	0.03	0.07	
4/08/2016	2.73	0.10	0.17	0.09	0.14	0.11	0.26	0.09	0.14	0.07	0.11	0.07	0.14	0.03	0.08	0.02	0.07	
5/08/2016	2.85	0.09	0.16	0.09	0.16	0.12	0.14	0.07	0.14	0.06	0.11	0.09	0.10	0.03	0.09	0.02	0.08	
6/08/2016	2.90	0.10	0.12	0.08	0.16	0.11	0.21	0.06	0.14	0.06	0.11	0.08	0.15	0.04	0.05	0.03	0.08	
7/08/2016	1.54	0.10	0.18	0.08	0.11	0.10	0.21	0.08	0.15	0.06	0.10	0.08	0.12	0.03	0.10	0.02	0.09	
8/08/2016	1.85	0.08	0.17	0.07	0.12	0.11	0.13	0.05	0.10	0.05	0.08	0.10	0.14	0.02	0.07	0.02	0.03	
9/08/2016	3.05	0.11	0.14	0.07	0.14	0.11	0.21	0.05	0.11	0.11	0.07	0.09	0.14	0.03	0.04	0.02	0.06	
10/08/2016	2.89	0.07	0.23	0.06	0.30	0.08	0.41	0.03	0.22	OL	OL	0.08	0.22	0.02	0.21	0.01	0.15	
11/08/2016	2.60	0.08	0.19	0.05	0.16	0.11	0.19	0.06	0.16	0.05	0.17	0.09	0.17	0.02	0.10	0.02	0.04	
12/08/2016	3.00	0.08	0.20	0.05	0.15	0.10	0.23	0.06	0.15	0.04	0.09	0.10	0.19	0.03	0.05	0.03	0.11	
13/08/2016	3.10	0.12	0.15	0.05	0.16	0.10	0.25	0.05	0.09	0.04	0.10	0.10	0.21	0.04	0.11	0.03	0.12	
14/08/2016	3.27	0.12	0.24	0.07	0.11	0.11	0.27	0.06	0.16	0.04	0.11	0.12	0.16	0.03	0.15	0.03	0.15	
15/08/2016	3.55	0.11	0.24	0.06	0.19	0.12	0.18	0.05	0.17	0.06	0.10	0.09	0.23	0.04	0.08	0.04	0.10	
16/08/2016	3.20	0.05	0.15	0.07	0.13	0.09	0.16	0.07	0.13	0.05	0.09	0.02	0.06	0.03	0.05	0.02	0.05	
17/08/2016	3.26	0.08	0.12	0.03	0.10	0.09	0.18	0.07	0.10	0.06	0.11	0.02	0.07	0.02	0.05	0.01	0.06	
18/08/2016	3.41	0.07	0.14	OL	OL	0.08	0.18	0.08	0.14	0.06	0.12	0.02	0.04	0.02	0.04	0.01	0.06	
19/08/2016	3.11	0.07	0.16	0.03	0.14	0.07	0.21	0.07	0.15	0.07	0.12	0.03	0.06	0.02	0.06	0.01	0.10	
20/08/2016	3.61	0.06	0.15	0.07	0.09	0.10	0.14	0.06	0.14	0.05	0.09	0.03	0.09	0.02	0.07	0.01	0.02	
21/08/2016	3.53	0.06	0.09	0.07	0.14	0.07	0.18	0.05	0.08	0.05	0.09	0.02	0.09	0.02	0.03	0.02	0.07	
22/08/2016	3.92	0.06	0.14	0.06	0.14	0.07	0.09	0.07	0.13	0.06	0.09	0.03	0.05	0.02	0.10	0.01	0.08	
23/08/2016	3.45	0.06	0.17	0.08	0.09	0.10	0.16	0.07	0.16	0.06	0.11	0.04	0.10	0.03	0.04	0.03	0.04	
24/08/2016	4.09	0.09	0.10	0.09	0.16	0.09	0.22	0.08	0.11	0.05	0.12	0.04	0.11	0.04	0.11	0.03	0.11	
25/08/2016	4.58	0.04	0.24	0.06	0.32	0.08	0.35	0.06	0.29	0.04	0.49	0.04	0.35	0.02	0.18	0.02	0.38	
26/08/2016	4.59	0.11	0.20	0.11	0.19	0.11	0.23	0.09	0.20	0.08	0.15	0.05	0.14	0.05	0.07	0.02	0.12	
27/08/2016	4.30	0.08	0.18	0.09	0.18	0.10	0.14	0.10	0.15	0.07	0.14	0.05	0.07	0.04	0.13	0.01	0.08	
28/08/2016	3.70	0.07	0.10	0.10	0.12	0.11	0.21	0.09	0.18	0.05	0.12	0.04	0.12	0.03	0.10	0.01	0.03	
29/08/2016	3.47	0.07	0.18	0.08	0.19	0.09	0.17	0.07	0.12	0.06	0.12	0.03	0.09	0.03	0.07	0.01	0.09	
30/08/2016	3.99	0.06	0.14	0.07	0.15	0.09	0.11	0.08	0.16	0.05	0.08	0.04	0.05	0.02	0.08	0.01	0.01	
31/08/2016	4.20	0.06	0.10	0.08	0.11	0.09	0.17	0.06	0.17	0.04	0.08	0.04	0.09	0.02	0.03	0.01	0.05	

Total Number of Measurements Taken, A: 16251 13102 15870 13099 15651 16256 14893 15885
Turbidity Standard for Monitoring Location (NTU): 0.30 0.30 0.30 0.30 0.30 0.30 0.30 0.30
Number of Measurements Meeting Standard, B: 16251 13099 15866 13099 15650 16255 14893 15883
Compliance with Turbidity Standard, C = B/A X 100%: 100.00% 99.98% 99.98% 100.00% 99.99% 99.99% 100.00% 99.99%

OL: Offline

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Turbidity\2016\08-August

Submitted By (Print): D. Minor

Signature: Original signed by D. Minor



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENVIRONMENTAL STANDARDS DIVISION

WATER TREATMENT PLANT TURBIDITY GRAB MONITORING REPORT

Water System Code: 252.00	Turbidity (NTU)																	
	Raw Water		Filter 1		Filter 2		Filter 3		Filter 4		Filter 5		Filter 6		Filter 7		Filter 8	
Date	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser
01-Aug-2016	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
02-Aug-2016	1.94	2.30	0.13	0.05	0.19	0.12	0.15	0.12	0.11	0.05	0.13	0.08	0.08	0.07	0.06	0.02	0.07	0.03
03-Aug-2016	1.94	NA	0.12	0.04	0.10	0.07	0.17	0.13	0.10	0.04	0.09	0.07	0.10	0.09	0.11	0.06	0.12	0.07
04-Aug-2016	2.07	2.71	0.16	0.10	0.13	0.09	0.13	0.11	0.13	0.06	0.06	0.05	0.09	0.08	0.09	0.04	0.28	0.03
05-Aug-2016	1.95	NA	0.12	0.08	0.15	0.10	0.14	0.12	0.19	0.04	0.15	0.08	0.08	<0.02	0.12	0.02	0.10	0.03
06-Aug-2016	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
07-Aug-2016	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
08-Aug-2016	2.20	2.61	0.09	0.07	0.11	0.07	0.12	0.10	0.15	0.07	0.10	0.06	0.13	0.08	0.06	0.02	0.06	0.03
09-Aug-2016	2.42	3.12	0.11	0.09	0.13	0.07	0.16	0.13	0.10	0.03	0.08	0.04	0.09	0.10	0.07	0.02	0.09	0.04
10-Aug-2016	2.64	2.99	0.15	0.14	0.12	0.10	0.16	0.14	0.11	0.05	OL	OL	0.09	0.09	OL	OL	0.08	0.03
11-Aug-2016	2.47	3.15	0.09	0.09	0.14	0.08	0.11	0.12	0.11	0.10	0.12	0.07	0.07	0.12	0.06	0.03	0.24	0.05
12-Aug-2016	2.48	3.15	0.10	0.11	0.09	0.06	0.12	0.14	0.27	0.05	0.11	0.06	0.24	0.13	0.27	0.03	0.06	0.05
13-Aug-2016	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
14-Aug-2016	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
15-Aug-2016	2.55	3.34	0.17	0.19	0.22	0.10	0.18	0.17	0.16	0.08	0.18	0.07	0.09	0.16	0.09	0.03	0.08	0.05
16-Aug-2016	2.71	3.09	0.11	0.05	0.11	0.06	0.13	0.09	0.11	0.06	0.29	0.04	0.10	0.02	0.07	0.03	0.07	0.05
17-Aug-2016	2.72	4.68	0.14	0.06	0.14	0.08	0.14	0.09	0.14	0.06	0.06	0.04	0.09	0.02	0.08	0.02	0.09	0.03
18-Aug-2016	2.70	2.92	0.16	0.08	OL	OL	0.14	0.09	0.17	0.07	0.13	0.06	0.08	0.02	0.09	0.02	0.11	0.04
19-Aug-2016	2.76	3.01	0.20	0.10	0.16	0.08	0.14	0.09	0.16	0.08	0.12	0.08	0.09	0.03	0.10	0.02	0.08	0.03
20-Aug-2016	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
21-Aug-2016	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
22-Aug-2016	3.19	3.13	0.15	0.06	0.10	0.06	0.14	0.07	0.11	0.04	0.11	0.05	0.10	0.02	0.10	0.03	0.07	0.03
23-Aug-2016	2.56	3.20	0.13	0.06	0.14	0.08	0.16	0.10	0.13	0.04	0.10	0.06	0.12	0.05	0.09	0.02	0.10	0.04
24-Aug-2016	3.24	NA	0.16	0.08	0.19	0.12	0.14	0.09	0.14	0.07	0.07	0.05	0.11	0.04	0.12	0.04	0.11	0.05
25-Aug-2016	3.22	NA	0.15	0.08	0.15	0.11	0.16	0.13	0.15	0.08	OL	OL	0.09	0.05	OL	OL	0.09	0.04
26-Aug-2016	3.10	NA	0.18	0.11	0.19	0.12	0.19	0.11	0.16	0.08	0.09	0.06	0.11	0.04	0.11	0.04	0.16	0.10
27-Aug-2016	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
28-Aug-2016	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
29-Aug-2016	3.34	3.12	0.14	0.07	0.18	0.10	0.14	0.08	0.14	0.05	0.10	0.03	0.10	0.03	0.11	0.02	0.11	0.02
30-Aug-2016	3.26	3.35	0.12	0.04	0.13	0.08	0.16	0.09	0.15	0.07	0.10	0.04	0.08	0.03	0.10	0.03	0.07	<0.02
31-Aug-2016	3.05	NA	0.13	0.02	0.14	0.06	0.18	0.08	0.15	0.02	0.10	0.03	0.12	0.04	0.13	0.02	0.13	<0.02
Total number of measurements taken, A:			22		21		22		22		20		22		20		22	
Turbidity Standard for Monitoring Location (NTU):			0.30		0.30		0.30		0.30		0.30		0.30		0.30		0.30	
Number of measurements meeting standard, B:			22		21		22		22		20		22		20		22	
Compliance with Turbidity Standard, C= B/A X 100%:			100%		100%		100%		100%		100%		100%		100%		100%	

NS: No Sample NA: Not Analyzed OL: Off-Line

Comments:

Analyser reading was unstable at time of sample collection for the raw on August 3, 5, 24, 25, 26 and 31.

Report Compiled By: _____ H.Demchenko _____

Approved in LIMS By: _____ C.Diduck _____



WATER TREATMENT PLANT FREE CHLORINE ON-LINE MONITORING REPORT
Deacon Booster Pumping Station

Water System Code: **252.00**

Licence Number: **PWS-09-412-01**

Report Created: 01 September 2016

Report Period: August 2016

Date	BRANCH 1 [mg/L]		BRANCH 2 [mg/L]	
	Average	Minimum	Average	Minimum
01/08/2016	1.17	1.05	1.12	1.03
02/08/2016	1.11	0.91	1.05	0.90
03/08/2016	1.21	1.02	1.04	0.79
04/08/2016	1.02	0.96	0.94	0.79
05/08/2016	1.17	1.08	1.01	0.94
06/08/2016	1.18	1.06	0.99	0.90
07/08/2016	1.10	1.05	0.91	0.84
08/08/2016	1.30	1.00	0.97	0.81
09/08/2016	1.39	1.13	1.07	0.95
10/08/2016	1.37	0.68	1.36	0.86
11/08/2016	1.10	0.97	1.07	0.94
12/08/2016	1.09	1.01	1.16	1.02
13/08/2016	1.05	0.96	1.13	0.97
14/08/2016	1.06	0.96	1.05	0.96
15/08/2016	0.99	0.86	1.06	0.96
16/08/2016	1.00	0.88	1.08	1.02
17/08/2016	1.04	0.90	1.06	0.97
18/08/2016	0.98	0.88	1.00	0.86
19/08/2016	0.96	0.82	0.92	0.77
20/08/2016	1.13	0.98	1.10	1.02
21/08/2016	1.10	0.97	1.12	1.04
22/08/2016	1.16	1.05	1.19	1.10
23/08/2016	1.27	0.81	1.24	1.05
24/08/2016	1.26	1.00	1.23	1.08
25/08/2016	1.05	0.61	1.08	0.68
26/08/2016	1.02	0.53	1.06	0.85
27/08/2016	1.18	1.09	1.17	1.07
28/08/2016	1.21	1.05	1.26	1.11
29/08/2016	1.07	1.02	1.10	0.99
30/08/2016	1.08	1.02	1.11	1.03
31/08/2016	1.07	0.99	1.09	0.99

Total Number of Measurements, A: 21605 21603

Minimum Free Chlorine Standard: 0.5 0.5

Number of Measurements Meeting Standard, B: 21605 21603

COMPLIANCE, C = B/A X 100%: 100 100

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Chlorine\2016\08-August

Submitted By (Print): D. Minor

Signature: Original signed by D. Minor



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENVIRONMENTAL STANDARDS DIVISION

WATER TREATMENT PLANT CHLORINE GRAB MONITORING REPORT

Water System Code: 252.00	Deacon Booster Pumping Station Branch 1			Deacon Booster Pumping Station Branch 2		
Licence No. PWS-09-412-01	Free Chlorine (mg/L)		Total Chlorine (mg/L)	Free Chlorine (mg/L)		Total Chlorine (mg/L)
Date	Analyser	Grab	Grab	Analyser	Grab	Grab
01-Aug-2016	NS	NS	NS	NS	NS	NS
02-Aug-2016	1.09	1.07	1.27	1.02	1.08	1.27
03-Aug-2016	1.22	1.19	1.37	1.14	1.13	1.39
04-Aug-2016	1.02	1.10	1.32	0.93	0.93	1.08
05-Aug-2016	1.16	1.17	1.32	1.02	0.99	1.27
06-Aug-2016	NS	NS	NS	NS	NS	NS
07-Aug-2016	NS	NS	NS	NS	NS	NS
08-Aug-2016	1.24	1.22	1.34	0.97	1.10	1.24
09-Aug-2016	1.17	1.20	1.45	0.99	1.05	1.26
10-Aug-2016	1.96	1.89	2.12	1.68	1.75	1.89
11-Aug-2016	1.09	1.05	1.29	1.12	1.12	1.27
12-Aug-2016	1.07	1.02	1.26	OL	1.23	1.38
13-Aug-2016	NS	NS	NS	NS	NS	NS
14-Aug-2016	NS	NS	NS	NS	NS	NS
15-Aug-2016	1.00	1.10	1.25	1.09	1.12	1.25
16-Aug-2016	0.94	1.04	1.24	1.04	1.00	1.17
17-Aug-2016	1.06	1.16	1.32	1.11	1.12	1.30
18-Aug-2016	0.95	1.02	1.14	0.98	0.99	1.15
19-Aug-2016	0.94	1.00	1.16	0.85	0.94	1.09
20-Aug-2016	NS	NS	NS	NS	NS	NS
21-Aug-2016	NS	NS	NS	NS	NS	NS
22-Aug-2016	1.15	1.22	1.43	1.18	1.28	1.43
23-Aug-2016	1.33	1.31	1.60	1.29	1.31	1.48
24-Aug-2016	1.25	1.38	1.55	1.21	1.31	1.49
25-Aug-2016	1.23	1.33	1.50	1.18	1.28	1.49
26-Aug-2016	1.27	1.26	1.46	1.13	1.18	1.39
27-Aug-2016	NS	NS	NS	NS	NS	NS
28-Aug-2016	NS	NS	NS	NS	NS	NS
29-Aug-2016	1.10	1.11	1.24	1.08	1.13	1.30
30-Aug-2016	1.17	1.13	1.28	1.21	1.13	1.26
31-Aug-2016	1.14	1.18	1.36	1.14	1.18	1.34
Total number of measurements taken, A:		22			22	
Chlorine Standard for Monitoring Location (mg/L):		0.50			0.50	
Number of measurements meeting standard, B:		22			22	
Compliance with Chlorine Standard, C= B/A X 100%:		100%			100%	

NS: No Sample NA: Not Analyzed OL: Off-Line

Comments:

Report Compiled By: _____ H.Demchenko

Approved in LIMS By: _____ C.Diduck



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
WATER SERVICES

WATER TREATMENT PLANT UV REPORT

Report Period: August 2016

Report Created: Thursday, September 01, 2016

Water System Code: 252.00
Licence Number: PW-S-09412-01

Date	Transmittance %	UVR-D100A			UVR-D200A			UVR-D300A			UVR-D400A			UVR-D500A			UVR-D600A		
		Untreated	Below	To Total	Untreated	Below	To Total	Untreated	Below	To Total	Untreated	Below	To Total	Untreated	Below	To Total	Untreated	Below	To Total
01/08/2016	93.46	0.00	0.00	75.46	75.46	0.00	0.00	0.00	0.00	48.26	48.26	0.00	0.00	0.00	0.00	78.30	0.00	0.00	0.00
02/08/2016	93.68	0.00	0.00	75.55	75.55	0.00	0.00	0.00	0.00	48.34	48.34	0.00	0.00	0.00	0.00	78.12	0.00	0.00	0.00
03/08/2016	93.47	0.00	0.00	75.37	75.37	0.00	0.00	0.00	0.00	48.08	48.08	0.00	0.00	0.00	0.00	44.01	0.00	0.05	34.47
04/08/2016	93.13	0.00	0.01	75.93	75.93	0.00	0.00	0.00	0.00	47.87	47.87	0.00	0.00	0.00	0.00	79.11	0.00	0.00	202.01
05/08/2016	93.59	0.00	0.00	74.85	74.85	0.00	0.00	0.00	0.00	47.96	47.96	0.00	0.00	0.00	0.00	79.22	0.00	0.00	202.04
06/08/2016	93.64	0.00	0.00	75.01	75.01	0.00	0.00	0.00	0.00	48.29	48.29	0.00	0.00	0.00	0.00	79.40	0.00	0.00	202.70
07/08/2016	93.59	0.00	0.00	76.81	76.81	0.00	0.00	0.00	0.00	49.50	49.50	0.00	0.00	0.00	0.00	81.27	0.00	0.00	207.58
08/08/2016	93.90	0.00	0.00	79.39	79.39	0.00	0.00	0.00	0.00	50.64	50.64	0.00	0.00	0.00	0.00	83.01	0.00	0.00	213.04
09/08/2016	93.71	0.00	0.00	79.36	79.36	0.00	0.00	0.00	0.00	50.66	50.66	0.00	0.00	0.00	0.00	82.98	0.00	0.00	213.00
10/08/2016	92.63	0.00	0.01	27.89	27.90	0.00	0.00	24.77	24.77	40.32	40.32	0.00	0.00	0.10	0.22	22.11	0.14	0.18	28.34
11/08/2016	94.01	0.00	0.00	0.00	0.00	0.00	0.00	74.20	74.20	0.00	0.00	76.76	76.76	0.00	0.00	75.54	0.00	0.00	0.00
12/08/2016	94.03	0.00	0.00	0.00	0.00	0.00	0.00	63.58	63.58	0.00	0.00	74.83	74.83	0.05	9.97	10.02	0.00	0.05	40.99
13/08/2016	93.92	0.00	0.00	0.00	0.00	0.00	0.00	70.61	70.61	0.00	0.00	72.68	72.68	0.00	0.00	0.00	0.00	0.00	0.00
14/08/2016	93.96	0.00	0.00	0.00	0.00	0.00	0.00	68.25	68.25	0.00	0.00	70.77	70.77	0.00	0.00	0.00	0.00	70.98	0.00
15/08/2016	93.86	0.00	0.00	0.00	0.00	0.00	0.00	67.72	67.72	0.00	0.00	70.71	70.71	0.00	0.00	0.00	0.00	71.59	0.00
16/08/2016	93.74	0.00	0.00	0.00	0.00	0.00	0.00	67.57	67.57	0.00	0.00	70.57	70.57	0.00	0.00	0.00	0.00	71.85	0.00
17/08/2016	93.37	0.00	0.00	0.00	0.00	0.00	0.00	67.35	67.35	0.00	0.00	70.49	70.49	0.00	0.00	0.00	0.00	72.17	0.00
18/08/2016	93.42	0.00	0.00	0.00	0.00	0.00	0.00	68.55	68.55	0.00	0.00	71.58	71.58	0.00	0.00	0.00	0.00	72.30	0.00
19/08/2016	93.39	0.00	0.00	0.00	0.00	0.00	0.00	84.16	84.16	0.00	0.00	84.93	84.93	0.00	0.24	0.24	0.00	0.00	81.43
20/08/2016	93.58	0.00	0.00	0.00	0.00	0.00	0.00	84.99	84.99	0.00	0.00	84.98	84.98	0.00	0.00	0.00	0.00	82.04	0.00
21/08/2016	93.68	0.00	0.00	0.00	0.00	0.00	0.00	84.98	84.98	0.00	0.00	84.98	84.98	0.00	0.00	0.00	0.00	82.04	0.00
22/08/2016	93.76	0.00	0.00	0.00	0.00	0.00	0.00	85.02	85.02	0.00	0.00	84.92	84.92	0.00	0.00	0.00	0.00	82.09	0.00
23/08/2016	93.18	0.12	0.12	59.98	59.92	0.03	0.03	24.42	24.48	0.00	0.00	49.79	49.79	0.00	0.00	0.04	61.75	61.80	0.00
24/08/2016	92.81	0.00	0.00	72.28	72.28	0.09	0.09	0.35	0.52	0.00	0.00	62.78	62.78	0.00	0.03	0.03	76.16	76.23	0.00
25/08/2016	91.56	0.01	0.01	19.55	19.57	0.00	0.00	22.29	22.29	0.01	0.01	34.94	34.96	0.00	0.00	0.00	37.14	0.00	0.02
26/08/2016	92.41	0.00	0.00	8.73	8.73	0.00	0.00	76.21	76.21	0.00	0.09	19.21	19.30	0.00	0.00	0.02	24.54	0.00	0.00
27/08/2016	92.94	0.00	0.00	0.00	0.00	0.00	0.00	84.99	84.99	0.00	0.00	49.71	49.71	0.00	0.00	0.00	80.28	0.00	0.00
28/08/2016	93.25	0.00	0.00	0.00	0.00	0.00	0.00	85.01	85.01	0.00	0.00	49.60	49.60	0.00	0.00	0.00	80.39	0.00	0.00
29/08/2016	93.54	0.00	0.00	0.00	0.00	0.00	0.00	85.01	85.01	0.00	0.00	49.74	49.74	0.00	0.00	0.00	80.23	0.00	0.00
30/08/2016	93.81	0.00	0.00	0.00	0.00	0.00	0.00	85.01	85.01	0.00	0.00	49.64	49.64	0.00	0.00	0.00	80.23	0.00	0.00
31/08/2016	93.81	0.12	0.14	87.36	87.46	0.12	0.12	1460.04	1460.29	0.00	0.10	1421.05	1421.05	0.00	0.05	280.84	280.89	0.05	0.25

Water Volume [%]:

Untreated: 0.01 %

Below Dose: 0.01 %

To Dose: 99.98 %

Total Water Volume [ML]: 1806.59

Untreated: 0.00

Below: 0.00

To: 1806.59

Total: 1806.59

Water Volume [ML]: 6398.55

Untreated: 0.44

Below: 0.00

To: 6398.55

Total: 6398.55

% Volume Treated To Dose:

Original signed by D. Minor



Water and Waste Department • Service des eaux et des déchets

Wednesday, August 31, 2016

Our Incident/Report No: 02-2016

LIMS Reference No: 47126

Incident Date: **August 16, 2016**

Ms. Melanie Betsill
Drinking Water Officer
Manitoba Sustainable Development, Office of Drinking Water
1007 Century Street
Winnipeg MB R3H 0W4

RE: CORRECTIVE ACTION REPORT

WATER SYSTEM, CODE	Winnipeg Public Water System, 252.00
LOCATION OF NON-COMPLIANT INCIDENT	Winnipeg 3-Dist NW03
INCIDENT REPORTED BY	Courtney Diduck, Analytical Services Branch Head
TYPE OF NON-COMPLIANT INCIDENT	Low positive Total Coliform (<10 per100mL), 3 MR 41/2007
DESCRIPTION OF CORRECTIVE ACTIONS	<u>Environmental Standards:</u> AS SOON AS POSSIBLE: Re-sampled original location until two consecutive negative results were reported. Also tested for turbidity, free/total chlorine, temperature and contacted the ODW.
TEST RESULTS	See Attached

NOTES/COMMENTS:

1. UP/DOWN STREAM testing performed when EC is >0 /100mL, TC is >10 /100mL or when resample/consecutive sample is positive for EC or TC or as directed by the Manager of Environmental Standards Division and/or the Office of Drinking Water

EMERGENCY REPORTING IS REQUIRED WHERE A POTENTIAL HEALTH RISK IS INVOLVED. FOLLOW THE INSTRUCTIONS OF YOUR DRINKING WATER OFFICER ON SITUATIONS REQUIRING IMMEDIATE REPORTING

N:\Environmental Standards\Analytical Services\Government Agencies\Office of Drinking Water\Corrective Action Reports



Water and Waste Department • Service des eaux et des déchets

Sample Name	Sample Number	Date Sampled	bacColiEsch-QT (MPNU/100mL)	bacColiTotal-QT (MPNU/100mL)	bacHPC (cfu/mL)	Chlorine, Free (mg/L)	Chlorine, Total (mg/L)	Temperature (°C)	Turbidity-field (ntu)	Time Sampled (hrs)
NW03	482401	16-Aug-16	<1	1	<1	1.16	1.46	17.1	2.36	09:20
NW03_Resample 1	482992	17-Aug-16	<1	<1	<1	0.77	0.99	16.7	0.95	15:50
NW03_Resample 1 Duplicate	483042	17-Aug-16	<1	<1	<1	NA	NA	NA	NA	NA
NW03_Resample 2	483046	18-Aug-16	<1	<1	<1	0.79	1.02	17.2	0.35	15:56
NW03_Resample 2 Duplicate	483047	18-Aug-16	<1	<1	<1	NA	NA	NA	NA	NA

NOTES/COMMENTS:

1. All microbiological tests performed by contract laboratory.
2. N/R-No Result due to laboratory/analyst error.
3. N/A-Not Analyzed.