



Water and Waste Department • Service des eaux et des déchets

February 5, 2016

Melanie Betsill
Office of Drinking Water
Manitoba Conservation and Water Stewardship
1007 Century Street
Winnipeg, Manitoba
R3H 0W4

Our File: 040-18-18-55-00

Dear Ms. Betsill:

**RE: JANUARY 2016 WATER QUALITY COMPLIANCE
SUBMISSION FOR THE CITY OF WINNIPEG WATER SUPPLY SYSTEM**

Please find attached on-line and grab turbidity summary reports, on-line and grab chlorine summary reports and the UV summary report for the Water Treatment Plant for January 2016. There are no corrective action reports to be submitted for January 2016.

The January on-line and grab sampling turbidity reports include results obtained for the Water Treatment Plant raw water and the eight filters. The turbidity results for the effluent from the filters met the licence requirements.

The January on-line and grab sampling chlorine reports include results obtained for the Deacon Booster Pumping Station at the Water Treatment Plant. The free chlorine results at the Water Treatment Plant met the licence requirements.

The January UV summary report includes results obtained for the six UV reactors at the Water Treatment Plant. The UV disinfection results met the licence requirements.

Please let me know of any concerns or questions respecting this submission. I may be reached by telephone at 204-986-8359 or by e-mail at rgrosselle@winnipeg.ca.

Yours sincerely,

Original signed by M. Marsland for:

R. Grosselle
Manager of Environmental Standards
Attachments

c:(e-mail)

Dr. L. Richards, Winnipeg Regional Health Authority
Dr. H. Chang, Winnipeg Regional Health Authority
Dr. S. Roberecki, Manitoba Health, Healthy Living and Seniors
D.P. Sacher, P.Eng.
G. Patton, P.Eng.
T. Shanks, P.Eng.
A. J. Weremy, P.Eng.
C. Diduck

N:\Compliance Reporting\Submittal Letters\2016\ODW - Monthly Compliance Letters\ODW Letter 2016-01.doc



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
WATER SERVICES

Water System Code: **252.00**
Licence Number: **PWS-09-412 AA**

WATER TREATMENT PLANT TURBIDITY ON-LINE MONITORING REPORT

January 2016 Turbidity (NTU)

Date	Raw		Filter #1		Filter #2		Filter #3		Filter #4		Filter #5		Filter #6		Filter #7		Filter #8	
	Avg	Avg	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max
1/01/2016	0.56	0.03	0.10		0.05	0.13	0.05	0.14	0.04	0.06	0.03	0.08	0.07	0.09	0.02	0.08	0.02	0.07
2/01/2016	0.55	0.05	0.10		0.05	0.14	0.04	0.15	0.05	0.13	0.03	0.05	0.05	0.14	0.02	0.04	0.01	0.08
3/01/2016	0.55	0.04	0.11		0.08	0.11	0.05	0.07	0.04	0.15	0.04	0.09	0.05	0.14	0.02	0.09	0.01	0.03
4/01/2016	0.54	0.03	0.05		0.06	0.12	0.04	0.11	0.04	0.06	0.03	0.07	0.07	0.10	0.02	0.08	OL	OL
5/01/2016	0.53	0.04	0.10		0.05	0.12	0.03	0.13	0.04	0.12	0.02	0.04	0.08	0.13	0.02	0.03	OL	OL
6/01/2016	0.54	0.03	0.09		0.06	0.08	0.03	0.04	0.04	0.12	0.04	0.07	0.08	0.16	0.02	0.08	OL	OL
7/01/2016	0.53	0.03	0.05		0.05	0.12	0.04	0.13	0.05	0.06	0.02	0.08	0.11	0.13	0.01	0.08	0.02	0.10
8/01/2016	0.51	0.05	0.11		0.06	0.09	0.03	0.18	0.05	0.14	0.04	0.07	0.07	0.18	0.03	0.06	0.02	0.08
9/01/2016	0.51	0.03	0.09		0.06	0.13	0.03	0.05	0.03	0.06	0.03	0.08	0.07	0.10	0.01	0.07	0.02	0.07
10/01/2016	0.49	0.03	0.06		0.04	0.09	0.01	0.13	0.04	0.13	0.02	0.05	0.06	0.15	0.01	0.02	0.01	0.04
11/01/2016	0.49	0.02	0.06		0.04	0.06	0.01	0.08	OL	OL	0.02	0.04	0.06	0.28	0.01	0.04	0.01	0.03
12/01/2016	0.50	0.04	0.12		0.07	0.09	0.02	0.04	OL	OL	0.04	0.07	0.07	0.16	0.02	0.08	0.02	0.03
13/01/2016	0.51	0.05	0.06		0.07	0.12	0.05	0.13	OL	OL	0.03	0.08	0.10	0.12	0.02	0.09	0.02	0.08
14/01/2016	0.51	0.05	0.11		0.06	0.08	0.04	0.14	0.02	0.16	0.04	0.07	0.09	0.17	0.03	0.06	0.01	0.09
15/01/2016	0.49	0.03	0.30		0.08	0.30	0.03	0.05	0.07	0.30	0.03	0.09	0.06	0.11	0.02	0.09	0.03	0.07
16/01/2016	0.49	0.06	0.08		0.05	0.15	0.04	0.18	0.05	0.17	0.03	0.06	0.10	0.18	0.02	0.03	0.02	0.09
17/01/2016	0.48	0.05	0.12		0.08	0.11	0.04	0.15	0.05	0.08	OL	OL	0.08	0.17	0.03	0.12	0.02	0.04
18/01/2016	0.47	0.04	0.13		0.07	0.15	0.05	0.07	0.07	0.15	OL	OL	0.09	0.11	0.02	0.10	0.03	0.09
19/01/2016	0.47	0.07	0.08		0.06	0.10	0.06	0.15	0.07	0.15	OL	OL	0.11	0.17	0.03	0.04	0.02	0.08
20/01/2016	0.47	0.05	0.15		0.10	0.16	0.05	0.14	0.07	0.12	0.04	0.14	0.08	0.19	0.04	0.10	0.03	0.06
21/01/2016	0.48	0.07	0.14		0.07	0.21	0.09	0.19	0.07	0.17	0.03	0.07	0.08	0.13	0.02	0.11	0.02	0.08
22/01/2016	0.48	0.08	0.16		0.09	0.12	0.06	0.19	0.06	0.18	0.06	0.11	0.04	0.13	0.05	0.06	0.01	0.02
23/01/2016	0.48	0.06	0.17		0.09	0.17	0.07	0.09	0.08	0.11	0.04	0.11	0.04	0.07	0.03	0.13	0.02	0.08
24/01/2016	0.47	0.10	0.12		0.09	0.17	0.09	0.19	0.07	0.17	0.04	0.06	OL	OL	0.04	0.14	0.02	0.10
25/01/2016	0.50	0.09	0.19		0.10	0.13	0.09	0.21	0.08	0.19	0.06	0.12	OL	OL	0.05	0.07	0.02	0.09
26/01/2016	0.51	0.08	0.15		0.10	0.20	0.07	0.19	0.06	0.11	0.04	0.11	OL	OL	0.05	0.13	0.02	0.03
27/01/2016	0.52	0.05	0.08		0.05	0.12	0.06	0.11	0.05	0.17	0.03	0.07	OL	OL	0.03	0.07	0.01	0.08
28/01/2016	0.51	0.04	0.10		0.04	0.06	0.03	0.15	0.03	0.10	0.03	0.06	0.01	0.11	0.02	0.04	0.00	0.02
29/01/2016	0.51	0.02	0.07		0.03	0.09	0.01	0.04	0.02	0.05	0.02	0.05	0.01	0.22	0.01	0.05	0.01	0.01
30/01/2016	0.50	0.03	0.04		0.02	0.08	0.03	0.10	0.03	0.09	0.02	0.04	0.01	0.05	0.00	0.02	0.00	0.02
31/01/2016	0.51	0.02	0.06		0.03	0.05	0.02	0.09	0.02	0.08	0.02	0.04	0.01	0.02	OL	OL	0.01	0.02

Total Number of Measurements Taken, A: 15002
Turbidity Standard for Monitoring Location (NTU): 0.30
Number of Measurements Meeting Standard, B: 15002
Compliance with Turbidity Standard, C = B/A X 100%: 100.00%

10587 15461 10341 14022 13204 13287 13372
0.30 0.30 0.30 0.30 0.30 0.30 0.30
10587 15461 10341 14022 13204 13287 13372
100.00% 100.00% 100.00% 100.00% 100.00% 100.00% 100.00%

OL = Offline

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Turbidity\2016\01-January

Submitted By (Print): D.Merredew

Signature: Original signed by D.Merredew



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENVIRONMENTAL STANDARDS DIVISION

WATER TREATMENT PLANT TURBIDITY GRAB MONITORING REPORT

Water System Code: 252.00 Licence No. PWS-09-412 AA	Turbidity (NTU)																		
	Date	Raw Water		Filter 1		Filter 2		Filter 3		Filter 4		Filter 5		Filter 6		Filter 7		Filter 8	
		Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser
01-Jan-2016		0.53	0.55	0.17	0.03	0.14	0.08	0.17	0.06	0.13	0.03	0.18	0.06	0.12	0.06	0.12	<0.02	0.13	0.04
02-Jan-2016		NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
03-Jan-2016		NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	0.13	0.07	
04-Jan-2016		0.57	0.53	0.11	0.02	0.14	0.08	0.16	0.05	0.12	0.03	0.08	0.02	0.14	0.06	0.10	0.02	O/L	O/L
05-Jan-2016		0.58	0.52	0.13	0.03	0.17	0.06	0.13	0.03	0.16	0.03	0.11	0.03	0.14	0.10	0.12	<0.02	O/L	O/L
06-Jan-2016		0.55	0.53	0.14	0.04	0.11	0.06	0.13	0.03	0.17	0.02	0.12	0.03	0.15	0.08	0.17	0.03	O/L	O/L
07-Jan-2016		0.55	0.52	0.13	0.02	0.20	0.11	0.17	0.05	0.12	0.03	0.09	0.02	0.12	0.09	0.10	0.06	0.16	0.07
08-Jan-2016		0.59	0.50	0.16	0.05	0.13	0.07	0.15	0.04	0.18	0.05	0.12	0.04	0.18	0.12	0.13	0.02	0.11	0.04
09-Jan-2016		NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	0.09	0.03
10-Jan-2016		NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
11-Jan-2016		0.51	0.47	0.10	0.02	0.09	0.05	0.10	<0.02	O/L	O/L	0.09	<0.02	0.10	0.07	0.08	<0.02	0.09	<0.02
12-Jan-2016		0.54	0.50	0.11	0.03	0.14	0.08	0.15	0.03	O/L	O/L	0.13	0.05	0.13	0.08	0.15	0.03	0.10	0.04
13-Jan-2016		0.51	0.50	0.13	0.04	0.16	0.09	0.19	0.05	O/L	O/L	0.12	0.03	0.13	0.06	0.12	<0.02	0.14	0.05
14-Jan-2016		0.49	0.50	0.16	0.06	0.13	0.07	0.24	0.09	0.19	0.16	0.12	0.04	0.20	0.14	0.13	0.02	0.10	0.03
15-Jan-2016		0.54	0.49	0.12	0.03	0.15	0.09	0.15	0.03	0.14	0.04	0.19	0.08	0.13	0.09	0.17	0.04	0.13	0.04
16-Jan-2016		NS	NS	NS	NS	NS	NS	NS	NS	0.15	0.08	NS							
17-Jan-2016		NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	O/L	O/L	NS	NS	NS	NS	NS	NS
18-Jan-2016		0.55	0.46	0.13	0.04	0.19	0.10	0.18	0.05	0.17	0.06	O/L	O/L	0.12	0.09	0.11	<0.02	0.15	0.06
19-Jan-2016		0.49	0.46	0.14	0.04	0.13	0.07	0.23	0.08	0.21	0.09	O/L	O/L	0.14	0.10	0.12	<0.02	0.11	0.03
20-Jan-2016		0.51	0.48	0.24	0.11	0.22	0.11	0.22	0.07	0.19	0.06	0.18	0.07	0.15	0.10	0.19	0.05	0.16	0.05
21-Jan-2016		0.57	0.45	0.17	0.05	0.25	0.14	0.24	0.08	0.26	0.09	0.14	0.04	0.11	0.10	0.14	<0.02	0.22	0.06
22-Jan-2016		0.53	0.46	0.21	0.11	0.17	0.11	0.22	0.12	0.17	0.04	0.14	0.05	0.20	0.09	0.15	0.04	0.13	0.02
23-Jan-2016		NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
24-Jan-2016		NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	O/L	O/L	NS	NS	NS	NS	NS
25-Jan-2016		0.51	0.49	0.23	0.12	0.18	0.11	0.24	0.11	0.19	0.06	0.15	0.05	O/L	O/L	0.14	0.04	0.13	0.02
26-Jan-2016		0.53	0.50	0.15	0.07	0.17	0.11	0.19	0.07	0.15	0.04	0.16	0.06	O/L	O/L	0.16	0.06	0.13	0.03
27-Jan-2016		0.46	0.50	0.14	0.04	0.16	0.07	0.18	0.06	0.15	0.05	0.09	0.02	O/L	O/L	0.09	0.02	0.12	0.03
28-Jan-2016		0.47	0.50	0.13	0.04	0.11	0.05	0.28	0.15	0.12	0.02	0.08	0.02	0.10	0.02	0.09	<0.02	0.08	<0.02
29-Jan-2016		0.45	0.47	0.08	<0.02	0.12	0.04	0.11	0.02	0.09	<0.02	0.12	0.05	0.13	0.03	0.10	<0.02	0.08	<0.02
30-Jan-2016		NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
31-Jan-2016		NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	O/L	O/L	NS	NS	NS	NS
Total number of measurements taken, A:				21		21		21		19		19		18		21		20	
Turbidity Standard for Monitoring Location (NTU):				0.30		0.30		0.30		0.30		0.30		0.30		0.30		0.30	
Number of measurements meeting standard, B:				21		21		19		19		18		21		20		20	
Compliance with Turbidity Standard, C= B/A X 100%:				100%		100%		100%		100%		100%		100%		100%		100%	

NS: No Sample NA: Not Analyzed OL: Off-Line

Comments:

Report Compiled By: H.Demchenko

Approved in LIMS By: C.Diduck



City of Winnipeg

Water and Waste Department

Water Services

WATER TREATMENT PLANT FREE CHLORINE ON-LINE MONITORING REPORT
Deacon Booster Pumping Station

Water System Code: 252.00

Licence Number: PWS-09-412 AA

Report Created: 01 February 2016

Report Period: January 2016

Date	BRANCH 1 [mg/L]		BRANCH 2 [mg/L]	
	Average	Minimum	Average	Minimum
1/01/2016	1.09	1.04	1.06	1.02
2/01/2016	1.09	1.07	1.04	1.01
3/01/2016	1.10	1.06	1.02	0.98
4/01/2016	1.03	0.90	1.01	0.86
5/01/2016	1.03	0.98	1.01	0.96
6/01/2016	1.07	1.00	1.06	0.93
7/01/2016	1.04	1.00	1.07	1.02
8/01/2016	1.26	0.94	1.01	0.91
9/01/2016	1.04	0.98	1.00	0.98
10/01/2016	1.08	1.03	1.05	0.98
11/01/2016	1.10	1.01	1.12	1.07
12/01/2016	1.05	0.92	1.17	1.11
13/01/2016	1.13	0.93	1.20	1.14
14/01/2016	1.16	0.94	1.13	1.04
15/01/2016	1.08	0.98	1.09	1.05
16/01/2016	0.99	0.78	1.00	0.82
17/01/2016	0.98	0.91	1.04	0.96
18/01/2016	1.01	0.87	1.17	0.98
19/01/2016	1.08	0.96	1.09	1.02
20/01/2016	1.03	0.87	1.07	0.98
21/01/2016	0.94	0.87	0.98	0.90
22/01/2016	1.01	0.92	1.06	0.97
23/01/2016	1.00	0.91	1.09	1.01
24/01/2016	0.99	0.94	1.10	1.04
25/01/2016	1.08	0.92	1.11	1.05
26/01/2016	1.14	1.05	1.13	1.06
27/01/2016	1.10	1.01	1.14	1.05
28/01/2016	1.05	0.97	1.06	1.00
29/01/2016	1.00	0.93	1.01	0.95
30/01/2016	0.99	0.93	1.00	0.96
31/01/2016	0.95	0.88	1.02	0.95

Total Number of Measurements, A: 21599 21599

Minimum Free Chlorine Standard: 0.50 0.50

Number of Measurements Meeting Standard, B: 21599 21599

COMPLIANCE, C = B/A X 100%: 100 100

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Chlorine\2016\01-January

Submitted By (Print): D.MerredewSignature: Original signed by D.Merredew



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENVIRONMENTAL STANDARDS DIVISION

WATER TREATMENT PLANT CHLORINE GRAB MONITORING REPORT

Water System Code: 252.00	Deacon Booster Pumping Station Branch 1			Deacon Booster Pumping Station Branch 2		
Licence No. PWS-09-412 AA	Date	Free Chlorine (mg/L)	Total Chlorine (mg/L)	Free Chlorine (mg/L)	Total Chlorine (mg/L)	
		Analyser	Grab	Grab	Grab	Grab
01-Jan-2016		1.13	1.11	1.30	1.08	1.09
02-Jan-2016		NS	NS	NS	NS	NS
03-Jan-2016		NS	NS	NS	NS	NS
04-Jan-2016		1.06	1.06	1.26	1.05	1.09
05-Jan-2016		1.05	1.11	1.26	1.07	1.05
06-Jan-2016		1.00	1.09	1.25	1.07	1.21
07-Jan-2016		1.05	1.05	1.23	1.09	1.16
08-Jan-2016		1.01	1.07	1.21	1.02	1.11
09-Jan-2016		NS	NS	NS	NS	NS
10-Jan-2016		NS	NS	NS	NS	NS
11-Jan-2016		1.17	1.26	1.39	1.10	1.18
12-Jan-2016		1.06	1.12	1.28	1.21	1.21
13-Jan-2016		O/L	1.02	1.18	1.15	1.08
14-Jan-2016		O/L	1.02	1.21	1.15	1.12
15-Jan-2016		1.09	1.09	1.24	1.13	1.13
16-Jan-2016		NS	NS	NS	NS	NS
17-Jan-2016		NS	NS	NS	NS	NS
18-Jan-2016		1.00	1.00	1.22	1.08	1.13
19-Jan-2016		1.11	1.11	1.36	1.13	1.14
20-Jan-2016		1.07	1.20	1.34	1.11	1.21
21-Jan-2016		0.88	0.97	1.12	0.91	0.99
22-Jan-2016		1.03	1.08	1.26	1.05	1.07
23-Jan-2016		NS	NS	NS	NS	NS
24-Jan-2016		NS	NS	NS	NS	NS
25-Jan-2016		1.06	1.11	1.29	1.12	1.12
26-Jan-2016		1.16	1.08	1.36	1.17	1.24
27-Jan-2016		1.09	1.20	1.33	1.12	1.13
28-Jan-2016		1.06	1.18	1.30	1.07	1.13
29-Jan-2016		1.01	1.16	1.28	1.02	1.07
30-Jan-2016		NS	NS	NS	NS	NS
31-Jan-2016		NS	NS	NS	NS	NS
Total number of measurements taken, A:		21			21	
Chlorine Standard for Monitoring Location (mg/L):		0.50			0.50	
Number of measurements meeting standard, B:		21			21	
Compliance with Chlorine Standard, C= B/A X 100%:		100%			100%	

NS: No Sample NA: Not Analyzed OL: Off-Line

Comments:

The free chlorine for DBPS I analyser on January 13 and 14 was recorded as offline due to maintenance.

Report Compiled By: _____ H.Demchenko

Approved in LIMS By: _____ C.Diduck



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
WATER SERVICES

Water System Code: 252.00
Licence Number: PWS-09-412 AA

WATER TREATMENT PLANT UV REPORT

Report Period: January 2016

Report Created: Monday, February 01, 2016

Date	Transmittance	UVR-D100A				UVR-D200A				UVR-D300A				UVR-D400A				UVR-D500A				UVR-D600A				Total				% Volume Treated To Dose				
		Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]								
	%	Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	To	Total					
01/01/2016	94.45	0.00	0.00	55.06	55.06	0.00	0.00	0.00	0.00	0.00	0.00	63.61	63.61	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	60.36	60.36	0.00	0.00	179.03	179.03	100.00					
02/01/2016	94.37	0.00	0.00	54.52	54.52	0.00	0.00	0.00	0.00	0.00	0.00	62.98	62.98	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	61.49	61.49	0.00	0.00	178.99	178.99	100.00					
03/01/2016	94.41	0.00	0.00	54.01	54.01	0.00	0.00	0.00	0.00	0.00	0.00	57.07	57.07	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	60.66	60.66	0.00	0.00	171.74	171.74	100.00					
04/01/2016	94.78	0.00	0.00	58.95	58.95	0.00	0.00	0.00	0.00	0.00	0.00	48.80	48.80	0.00	0.00	40.69	40.69	0.00	0.00	0.00	0.00	0.00	0.00	24.12	24.12	0.00	0.00	172.56	172.56	100.00				
05/01/2016	94.78	0.00	0.00	63.04	63.04	0.00	0.00	0.00	0.00	0.00	0.00	45.87	45.87	0.00	0.00	68.04	68.04	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	176.95	176.95	100.00				
06/01/2016	94.61	0.00	0.00	50.38	50.38	0.00	0.08	36.93	37.01	0.13	0.13	15.80	16.06	0.00	0.00	73.66	73.66	0.00	0.00	0.00	0.00	0.00	0.00	0.13	0.21	176.77	177.11	99.81						
07/01/2016	94.62	0.00	0.00	44.21	44.21	0.00	0.08	56.31	56.39	0.04	0.04	0.01	0.09	0.00	0.00	76.37	76.37	0.00	0.00	0.00	0.00	0.00	0.00	0.04	0.12	176.90	177.06	99.91						
08/01/2016	93.67	0.00	0.00	45.89	45.89	0.00	0.16	57.89	58.05	0.00	0.00	0.00	0.00	0.00	0.00	24.75	24.75	0.00	0.00	50.14	50.14	0.00	0.00	0.00	0.00	0.00	0.16	178.68	178.84	99.91				
09/01/2016	94.63	0.00	0.00	46.54	46.54	0.00	0.08	58.59	58.67	0.00	0.00	0.00	0.00	0.00	0.00	73.81	73.81	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.08	178.94	179.02	99.95						
10/01/2016	93.99	0.00	0.00	46.52	46.52	0.00	0.08	58.57	58.65	0.00	0.00	0.00	0.00	0.00	0.00	73.82	73.82	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.08	178.91	178.99	99.95						
11/01/2016	93.82	0.00	0.00	28.59	28.59	0.16	0.20	52.67	53.03	0.03	5.90	5.93	0.00	0.00	22.99	22.99	0.00	0.00	68.57	68.57	0.00	0.00	0.00	0.00	0.16	0.24	178.72	179.12	99.78					
12/01/2016	94.29	0.00	0.04	0.02	0.06	0.00	0.00	63.97	63.97	0.00	0.00	29.09	29.09	0.00	0.00	63.21	63.21	0.00	0.00	22.47	22.47	0.00	0.05	0.17	0.22	0.00	0.09	178.92	179.01	99.95				
13/01/2016	94.72	0.00	0.00	0.00	0.00	0.00	0.00	64.35	64.35	0.00	0.00	45.92	45.92	0.00	0.00	68.74	68.74	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	179.01	179.01	100.00				
14/01/2016	94.64	0.00	0.00	0.00	0.00	0.00	0.00	64.31	64.31	0.00	0.00	45.98	45.98	0.00	0.00	68.68	68.68	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	178.97	178.97	100.00				
15/01/2016	94.61	0.00	0.00	0.00	0.00	0.00	0.00	64.90	64.90	0.00	0.00	46.09	46.09	0.00	0.00	68.82	68.82	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	179.81	179.81	100.00				
16/01/2016	94.48	0.00	0.00	0.00	0.00	0.00	0.00	64.70	64.70	0.00	0.00	46.20	46.20	0.00	0.00	69.09	69.09	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	179.99	179.99	100.00				
17/01/2016	93.77	0.00	0.00	0.00	0.00	0.00	0.00	65.89	65.89	0.00	0.00	45.73	45.73	0.00	0.00	68.38	68.38	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	180.01	180.01	100.00				
18/01/2016	93.47	0.00	0.00	22.27	22.27	0.00	0.00	43.92	43.92	0.00	0.00	29.31	29.31	0.00	0.00	65.59	65.59	0.00	0.03	0.00	0.03	0.00	0.00	21.61	21.61	0.00	0.03	182.70	182.74	99.98				
19/01/2016	93.13	0.00	0.00	30.47	30.47	0.00	0.00	31.59	31.59	0.00	0.00	0.00	0.00	0.00	0.00	55.38	55.38	0.00	0.00	0.00	0.00	0.00	0.00	62.55	62.55	0.00	0.00	180.00	180.00	100.00				
20/01/2016	92.67	0.00	0.00	0.00	0.00	0.00	0.00	64.49	64.49	0.00	0.00	0.00	0.00	0.00	0.00	52.78	52.78	0.00	0.00	0.00	0.00	0.00	0.00	62.68	62.68	0.00	0.00	179.96	179.96	100.00				
21/01/2016	92.70	0.00	0.00	0.00	0.00	0.00	0.00	62.50	62.50	0.00	0.18	27.26	27.44	0.00	0.00	27.73	27.73	0.00	0.00	44.55	44.55	0.00	0.00	19.32	19.32	0.00	0.18	181.35	181.54	99.90				
22/01/2016	92.64	0.00	0.00	0.00	0.00	0.00	0.00	64.13	64.13	0.00	0.04	37.23	37.27	0.00	0.00	16.85	16.85	0.00	0.00	65.89	65.89	0.00	0.00	0.00	0.00	0.00	0.04	184.11	184.15	99.98				
23/01/2016	92.11	0.00	0.00	0.00	0.00	0.00	0.00	63.04	63.04	0.00	0.00	55.05	55.05	0.00	0.00	0.00	0.00	0.00	0.00	66.97	66.97	0.00	0.00	0.00	0.00	0.00	0.00	185.05	185.05	100.00				
24/01/2016	91.10	0.00	0.00	0.00	0.00	0.00	0.00	62.96	62.96	0.00	0.00	54.97	54.97	0.00	0.00	0.00	0.00	0.00	0.00	67.06	67.06	0.00	0.00	0.00	0.00	0.00	0.00	185.00	185.00	100.00				
25/01/2016	90.28	0.00	0.00	18.18	18.18	0.00	0.04	44.21	44.21	0.00	0.04	54.88	54.92	0.00	0.00	0.00	0.00	0.00	0.00	67.72	67.72	0.00	0.00	0.00	0.00	0.00	0.04	184.99	185.04	99.98				
26/01/2016	92.21	0.00	0.00	0.00	0.00	0.00	0.00	62.91	62.91	0.00	0.00	55.01	55.01	0.00	0.00	0.00	0.00	0.00	0.00	67.09	67.09	0.00	0.00	0.00	0.00	0.00	0.00	185.01	185.01	100.00				
27/01/2016	93.30	0.00	0.00	0.00	0.00	0.00	0.09	61.66	61.75	0.00	0.00	54.42	54.42	0.00	0.00	5.35	5.35	0.19	0.23	59.32	59.74	0.00	0.00	0.00	0.00	0.19	0.31	180.74	181.25	99.72				
28/01/2016	95.32	0.00	0.00	0.00	0.00	0.00	0.00	61.00	61.00	0.00	0.00	54.06	54.06	0.00	0.00	0.00	0.00	0.00	0.00	63.26	63.26	0.00	0.00	0.00	0.00	0.00	0.00	178.32	178.32	100.00				
29/01/2016	95.38	0.00	0.00	0.00	0.00	0.00	0.00	59.83	59.83	0.00	0.00	55.07	55.07	0.00	0.00	0.00	0.00	0.00	0.00	63.10	63.10	0.00	0.00	0.00	0.00	0.00	0.00	178.00	178.00	100.00				
30/01/2016	95.10	0.00	0.00	0.00	0.00	0.00	0.00	60.03	60.03	0.00	0.00	54.75	54.75	0.00	0.00	0.00	0.00	0.00	0.00	63.24	63.24	0.00	0.00	0.00	0.00	0.00	0.00	177.97	177.97	100.00				
31/01/2016	95.17	0.00	0.00	0.00	0.00	0.00	0.00	618.67	618.71	0.16	0.77	1511.16	1512.09	0.17	0.46	1145.95	1146.58	0.00	0.00	937.11	937.11	0.19	0.26	980.28	980.73	0.00	0.06	372.96	373.02	0.53	1.59	5566.13	5568.25	100.00

Water Volume [%]:

Untreated: 0.01 %

Below Dose 0.03 %

To Dose 99.96 %

Submitted By (Print): D.Merredew

Signature: