



Water and Waste Department • Service des eaux et des déchets

October 7, 2016

Melanie Betsill
Office of Drinking Water
Manitoba Sustainable Development
1007 Century Street
Winnipeg, Manitoba R3H 0W4

Our File: 040-18-18-55-00

Dear Ms. Betsill:

**RE: SEPTEMBER 2016 WATER QUALITY COMPLIANCE
SUBMISSION FOR THE CITY OF WINNIPEG WATER SUPPLY SYSTEM**

Please find attached on-line and grab turbidity summary reports, on-line and grab chlorine summary reports and the UV summary report for the Water Treatment Plant for September 2016. We have included one corrective action report for a positive total coliform in the distribution system.

The September on-line and grab sampling turbidity reports include results obtained for the Water Treatment Plant raw water and the eight filters. Please note that on September 9th, there was no average turbidity reported for the raw analyzer due to an instrument error and no result for the raw analyzer on September 21st and 22nd due to the equipment requiring maintenance. The turbidity results for the effluent from the filters met the licence requirements.

The September on-line and grab sampling chlorine reports include results obtained for the Deacon Booster Pumping Station at the Water Treatment Plant. The free chlorine results at the Water Treatment Plant met the licence requirements.

On September 28th, a positive total coliform result was reported for a routine sample at the NE05 location. On September 29th and 30th, the location was resampled and results were reported to be negative. Our resampling also indicated that the chlorine levels at the location were normal and provided adequate disinfection. Please see the attached corrective action report for additional details.

The September UV summary report includes results obtained for the six UV reactors at the Water Treatment Plant. The UV disinfection results met the licence requirements.

Please let me know of any concerns or questions respecting this submission. I may be reached by telephone at 204-986-8359 or by e-mail at rgrosselle@winnipeg.ca.

Yours sincerely,

Original signed by:

R. Grosselle
Manager of Environmental Standards
Attachments

c:(e-mail)

Dr. L. Richards, Winnipeg Regional Health Authority
Dr. H. Chang, Winnipeg Regional Health Authority
Dr. S. Roberecki, Manitoba Health, Healthy Living and Seniors
M. L. Geer, CPA, CA
G. Patton, P.Eng.
T. Shanks, P.Eng.
M. Szmon, P.Eng.
C. Diduck

N:\Compliance Reporting\Submittal Letters\2016\ODW - Monthly Compliance Letters\ODW Letter 2016-09.doc



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
WATER SERVICES

Water System Code: 252.00
Licence Number: PWS-09-412-01

WATER TREATMENT PLANT TURBIDITY ON-LINE MONITORING REPORT

September 2016 Turbidity (NTU)

Date	Raw		Filter #1		Filter #2		Filter #3		Filter #4		Filter #5		Filter #6		Filter #7		Filter #8	
	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max
1/09/2016	3.66	0.07	0.14	0.09	0.17	0.09	0.20	0.09	0.11	0.06	0.08	0.04	0.05	0.03	0.08	0.01	0.08	
2/09/2016	2.90	0.06	0.15	0.08	0.11	0.12	0.15	0.08	0.18	0.05	0.13	0.04	0.10	0.02	0.08	0.01	0.01	
3/09/2016	2.99	0.07	0.11	0.10	0.17	0.10	0.20	0.07	0.16	0.05	0.09	0.04	0.11	0.02	0.03	0.01	0.07	
4/09/2016	3.15	0.06	0.13	0.07	0.16	0.10	0.11	0.08	0.10	0.05	0.09	0.05	0.06	0.02	0.09	0.01	0.06	
5/09/2016	3.20	0.06	0.08	0.09	0.10	0.09	0.18	0.06	0.16	0.04	0.09	0.05	0.11	0.02	0.03	0.01	0.02	
6/09/2016	2.99	0.06	0.13	0.08	0.16	0.08	0.18	0.08	0.10	0.06	0.09	0.05	0.06	0.03	0.09	0.01	0.07	
7/09/2016	3.64	0.04	0.09	0.07	0.09	0.09	0.12	0.05	0.14	0.04	0.09	0.05	0.11	0.02	0.08	0.01	0.01	
8/09/2016	3.47	0.04	0.11	0.05	0.12	0.06	0.14	0.04	0.05	0.05	0.07	0.05	0.11	0.02	0.03	0.01	0.06	
9/09/2016	2.36	0.03	0.09	0.04	0.11	0.06	0.08	0.04	0.09	0.04	0.08	0.06	0.07	0.02	0.07	0.01	0.01	
10/09/2016	2.34	0.03	0.05	0.06	0.07	0.05	0.13	0.04	0.09	0.04	0.08	0.05	0.11	0.02	0.03	0.01	0.05	
11/09/2016	2.56	0.03	0.14	0.05	0.12	0.05	0.10	0.04	0.07	0.05	0.10	0.06	0.12	0.02	0.08	0.01	0.04	
12/09/2016	NR	0.04	0.07	0.07	0.10	0.09	0.16	0.05	0.11	0.04	0.08	0.06	0.11	0.02	0.07	0.01	0.01	
13/09/2016	1.97	0.05	0.15	0.06	0.14	0.07	0.16	0.04	0.06	0.05	0.07	0.06	0.11	0.03	0.04	0.01	0.05	
14/09/2016	1.68	0.04	0.11	0.06	0.16	0.09	0.11	0.06	0.10	0.05	0.08	0.07	0.08	0.02	0.07	0.01	0.01	
15/09/2016	1.67	0.07	0.09	0.11	0.13	0.10	0.20	0.06	0.16	0.04	0.09	0.06	0.11	0.03	0.03	0.01	0.05	
16/09/2016	1.31	0.04	0.14	0.07	0.22	0.07	0.11	0.07	0.08	0.06	0.09	0.06	0.08	0.03	0.08	0.01	0.09	
17/09/2016	1.64	0.04	0.07	0.08	0.11	0.11	0.27	0.05	0.21	0.04	0.10	0.05	0.15	0.02	0.14	0.01	0.02	
18/09/2016	1.48	0.06	0.13	0.08	0.21	0.08	0.24	0.04	0.16	0.04	0.09	0.05	0.16	0.04	0.05	0.01	0.11	
19/09/2016	1.73	0.05	0.12	0.07	0.20	0.08	0.15	0.07	0.10	0.06	0.13	0.07	0.09	0.03	0.14	0.01	0.11	
20/09/2016	1.81	0.02	0.08	0.06	0.10	0.11	0.26	0.04	0.15	0.04	0.11	0.07	0.17	0.03	0.13	0.01	0.02	
21/09/2016	NR	0.04	0.12	0.08	0.15	0.09	0.22	0.04	0.12	0.05	0.12	0.06	0.15	0.04	0.11	0.02	0.11	
22/09/2016	NR	0.02	0.11	0.06	0.20	0.09	0.14	0.06	0.08	0.12	0.16	0.06	0.09	0.04	0.12	0.02	0.11	
23/09/2016	1.30	0.02	0.09	0.07	0.10	0.07	0.23	0.03	0.13	0.07	0.16	0.04	0.14	0.03	0.12	0.03	0.04	
24/09/2016	1.39	0.03	0.05	0.09	0.19	0.02	0.13	0.04	0.12	0.07	0.12	0.02	0.11	0.04	0.05	0.02	0.12	
25/09/2016	1.18	0.03	0.09	0.06	0.18	0.02	0.11	0.05	0.07	0.10	0.16	0.02	0.05	0.03	0.12	0.02	0.11	
26/09/2016	1.13	0.02	0.07	0.06	0.09	0.02	0.05	0.04	0.11	0.06	0.15	0.03	0.10	0.03	0.12	0.02	0.03	
27/09/2016	1.09	0.01	0.03	0.07	0.14	0.00	0.08	0.02	0.09	0.06	0.12	0.02	0.08	0.03	0.05	0.02	0.11	
28/09/2016	1.00	0.01	0.04	0.05	0.11	0.00	0.05	0.03	0.04	0.09	0.11	0.01	0.06	0.03	0.09	0.02	0.06	
29/09/2016	1.02	0.01	0.03	0.04	0.10	0.00	0.01	0.03	0.17	0.06	0.11	0.04	0.30	0.02	0.08	0.02	0.26	
30/09/2016	1.19	0.01	0.02	0.07	0.11	0.01	0.04	0.03	0.08	0.06	0.11	0.02	0.07	0.03	0.06	0.01	0.06	

Total Number of Measurements Taken, A: 14828
Turbidity Standard for Monitoring Location (NTU): 0.3
Number of Measurements Meeting Standard, B: 14828
Compliance with Turbidity Standard, C = B/A X 100%: 100.000%

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Turbidity\2016\09-September

NR - No Result

Submitted By (Print): D. Merredew

Signature: Original signed by D. Merredew



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENVIRONMENTAL STANDARDS DIVISION

WATER TREATMENT PLANT TURBIDITY GRAB MONITORING REPORT

Water System Code: 252.00	Turbidity (NTU)																	
	Raw Water		Filter 1		Filter 2		Filter 3		Filter 4		Filter 5		Filter 6		Filter 7		Filter 8	
Date	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser
01-Sep-2016	3.16	3.43	0.21	0.09	0.19	0.12	0.15	0.10	0.16	0.07	0.09	0.04	0.09	0.03	0.09	0.02	0.09	<0.02
02-Sep-2016	2.92	3.42	0.15	0.05	0.17	0.09	0.17	0.11	0.19	0.08	0.10	0.05	0.16	0.04	0.09	0.02	0.08	<0.02
03-Sep-2016	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
04-Sep-2016	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
05-Sep-2016	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
06-Sep-2016	2.47	2.78	0.17	0.07	0.17	0.11	0.15	0.09	0.14	0.06	0.09	0.06	0.07	0.05	0.07	0.02	0.06	<0.02
07-Sep-2016	2.48	2.59	0.12	0.04	0.13	0.08	0.14	0.10	0.13	0.09	0.10	0.06	0.10	0.05	0.08	<0.02	0.09	<0.02
08-Sep-2016	2.35	NA	0.11	0.03	0.12	0.07	0.10	0.06	0.09	0.02	0.09	0.04	0.07	0.05	0.07	<0.02	0.08	0.02
09-Sep-2016	2.35	NA	0.09	0.02	0.09	0.05	0.10	0.06	0.09	0.02	0.07	0.04	0.07	0.05	0.08	0.02	0.06	<0.02
10-Sep-2016	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
11-Sep-2016	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
12-Sep-2016	1.70	1.81	0.12	0.04	0.12	0.08	0.13	0.10	0.16	0.05	0.07	0.04	0.09	0.08	0.07	0.02	0.08	0.02
13-Sep-2016	1.45	1.75	0.12	0.04	0.13	0.09	0.10	0.07	0.09	0.02	0.06	0.04	0.07	0.06	0.07	0.02	0.09	0.02
14-Sep-2016	1.23	1.97	0.16	0.03	0.12	0.07	0.11	0.08	0.12	0.08	0.08	0.05	0.09	0.06	0.12	0.03	0.08	<0.02
15-Sep-2016	1.18	1.46	0.14	0.06	0.16	0.11	0.20	0.16	0.13	0.07	0.11	0.06	0.07	<0.02	0.08	0.02	0.11	0.02
16-Sep-2016	1.27	1.98	0.18	0.08	0.12	0.09	0.14	0.10	0.15	0.06	0.10	0.07	0.07	0.06	0.08	0.03	0.10	<0.02
17-Sep-2016	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
18-Sep-2016	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
19-Sep-2016	1.10	1.77	0.18	0.08	OL	OL	0.17	0.12	0.16	0.05	0.14	0.08	0.12	0.07	0.12	0.05	0.08	0.02
20-Sep-2016	1.48	1.51	0.10	0.02	0.10	0.08	0.14	0.11	0.11	0.03	0.11	0.06	0.16	0.09	0.08	0.04	0.12	0.02
21-Sep-2016	1.18	NR	0.12	0.03	0.13	0.09	0.16	0.14	0.13	0.03	0.13	0.05	OL	OL	0.09	0.04	0.13	0.03
22-Sep-2016	1.07	NR	0.17	0.03	0.17	0.15	0.13	0.14	0.14	0.05	0.15	0.14	0.12	0.07	0.13	0.05	0.09	0.04
23-Sep-2016	1.01	1.25	0.10	0.02	0.11	0.08	0.11	0.03	0.11	0.04	0.14	0.11	0.10	0.03	0.07	0.03	0.13	0.04
24-Sep-2016	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
25-Sep-2016	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
26-Sep-2016	0.87	1.05	0.09	<0.02	0.09	0.08	0.10	0.02	0.13	0.03	0.09	0.10	0.09	0.02	0.12	0.11	0.07	0.04
27-Sep-2016	0.86	1.08	0.06	<0.02	0.06	0.07	0.08	<0.02	0.07	<0.02	0.06	0.09	0.11	0.03	0.07	0.03	0.08	0.03
28-Sep-2016	0.79	1.01	0.10	<0.02	0.11	0.08	0.07	<0.02	0.07	0.02	0.09	0.09	0.08	<0.02	0.07	0.03	OL	OL
29-Sep-2016	0.72	0.83	0.09	<0.02	0.10	0.07	0.10	<0.02	0.10	0.02	0.08	0.09	0.10	0.02	OL	OL	0.07	0.03
30-Sep-2016	0.77	1.09	0.08	<0.02	0.08	0.07	0.10	<0.02	OL	OL	0.19	0.08	0.10	0.03	0.07	0.03	0.14	0.04
Total number of measurements taken, A:			21		20		21		20		21		20		20		20	
Turbidity Standard for Monitoring Location (NTU):			0.30		0.30		0.30		0.30		0.30		0.30		0.30		0.30	
Number of measurements meeting standard, B:			21		20		21		20		21		20		20		20	
Compliance with Turbidity Standard, C= B/A X 100%:			100%		100%		100%		100%		100%		100%		100%		100%	

NS: No Sample NA: Not Analyzed OL: Off-Line

Comments:

Analyser reading was unstable at time of sample collection for the raw water on September 8 and 9.
There was no result for the raw water analyser on September 21 and 22 due to maintenance.

Report Compiled By: _____ H.Demchenko _____

Approved in LIMS By: _____ C.Diduck _____



WATER TREATMENT PLANT FREE CHLORINE ON-LINE MONITORING REPORT
Deacon Booster Pumping Station

Water System Code: **252.00**

Licence Number: **PWS-09-412-01**

Report Created: 01 October 2016

Report Period: September 2016

Date	BRANCH 1 [mg/L]		BRANCH 2 [mg/L]	
	Average	Minimum	Average	Minimum
1/09/2016	0.97	0.87	0.99	0.93
2/09/2016	1.07	0.97	1.10	1.00
3/09/2016	1.07	1.00	1.14	1.08
4/09/2016	1.17	1.04	1.22	1.10
5/09/2016	1.01	0.91	1.03	0.94
6/09/2016	1.17	0.97	1.16	1.01
7/09/2016	1.39	1.29	1.30	1.23
8/09/2016	1.38	1.26	1.28	1.14
9/09/2016	1.35	1.24	1.23	1.14
10/09/2016	1.33	1.22	1.21	1.17
11/09/2016	1.25	0.81	1.17	0.81
12/09/2016	1.29	1.18	1.22	1.16
13/09/2016	1.37	1.27	1.28	1.14
14/09/2016	1.41	1.31	1.34	1.23
15/09/2016	1.44	1.21	1.42	1.35
16/09/2016	1.23	1.10	1.39	1.28
17/09/2016	1.38	1.32	1.35	1.29
18/09/2016	1.36	1.25	1.33	1.26
19/09/2016	1.41	1.24	1.30	1.23
20/09/2016	1.37	1.30	1.33	1.25
21/09/2016	1.35	1.25	1.32	1.25
22/09/2016	1.35	1.24	1.28	1.21
23/09/2016	1.35	1.26	1.26	1.16
24/09/2016	1.32	1.25	1.21	1.13
25/09/2016	1.24	1.17	1.20	1.13
26/09/2016	1.24	1.13	1.23	1.11
27/09/2016	1.37	1.23	1.32	1.26
28/09/2016	1.37	1.31	1.24	1.19
29/09/2016	1.37	1.29	1.24	1.17
30/09/2016	1.42	1.33	1.33	1.25

Total Number of Measurements, A: 20879 20879

Minimum Free Chlorine Standard: 0.5 0.5

Number of Measurements Meeting Standard, B: 20879 20879

COMPLIANCE, C = B/A X 100%: 100 100

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Chlorine\2016\09-September

Submitted By (Print): D. Merredew

Signature: Original signed by D. Merredew



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENVIRONMENTAL STANDARDS DIVISION

WATER TREATMENT PLANT CHLORINE GRAB MONITORING REPORT

Water System Code: 252.00	Deacon Booster Pumping Station Branch 1			Deacon Booster Pumping Station Branch 2		
Licence No. PWS-09-412-01						
Date	Free Chlorine (mg/L)		Total Chlorine (mg/L)	Free Chlorine (mg/L)		Total Chlorine (mg/L)
	Analyser	Grab	Grab	Analyser	Grab	Grab
01-Sep-2016	0.92	1.02	1.15	0.94	1.01	1.16
02-Sep-2016	1.12	1.14	1.30	1.12	1.12	1.31
03-Sep-2016	NS	NS	NS	NS	NS	NS
04-Sep-2016	NS	NS	NS	NS	NS	NS
05-Sep-2016	NS	NS	NS	NS	NS	NS
06-Sep-2016	1.07	1.10	1.25	1.01	1.08	1.22
07-Sep-2016	1.40	1.46	1.65	1.32	1.35	1.48
08-Sep-2016	1.42	1.43	1.66	1.33	1.29	1.53
09-Sep-2016	1.35	1.35	1.54	1.24	1.24	1.37
10-Sep-2016	NS	NS	NS	NS	NS	NS
11-Sep-2016	NS	NS	NS	NS	NS	NS
12-Sep-2016	1.36	1.34	1.49	1.30	1.30	1.47
13-Sep-2016	1.41	1.39	1.58	1.29	1.24	1.43
14-Sep-2016	1.36	1.40	1.59	1.28	1.30	1.53
15-Sep-2016	1.50	1.48	1.64	1.42	1.39	1.54
16-Sep-2016	1.15	1.21	1.40	1.43	1.40	1.57
17-Sep-2016	NS	NS	NS	NS	NS	NS
18-Sep-2016	NS	NS	NS	NS	NS	NS
19-Sep-2016	1.27	1.38	1.62	1.25	1.34	1.52
20-Sep-2016	1.41	1.46	1.66	1.36	1.40	1.57
21-Sep-2016	1.35	1.47	1.63	1.31	1.36	1.60
22-Sep-2016	1.32	1.39	1.62	1.25	1.27	1.49
23-Sep-2016	1.38	1.42	1.56	1.35	1.30	1.46
24-Sep-2016	NS	NS	NS	NS	NS	NS
25-Sep-2016	NS	NS	NS	NS	NS	NS
26-Sep-2016	1.16	1.31	1.48	1.13	1.18	1.36
27-Sep-2016	1.42	1.45	1.63	1.32	1.34	1.53
28-Sep-2016	1.38	1.35	1.53	1.22	1.28	1.46
29-Sep-2016	1.42	1.44	1.57	1.29	1.32	1.45
30-Sep-2016	1.41	1.52	1.76	1.33	1.42	1.63
Total number of measurements taken, A:		21			21	
Chlorine Standard for Monitoring Location (mg/L):		0.50			0.50	
Number of measurements meeting standard, B:		21			21	
Compliance with Chlorine Standard, C= B/A X 100%:		100%			100%	

NS: No Sample NA: Not Analyzed OL: Off-Line

Comments:

Report Compiled By: _____ H.Demchenko

Approved in LIMS By: _____ C.Diduck



Water and Waste Department • Service des eaux et des déchets

Wednesday, October 5, 2016

Our Incident/Report No: 03-2016

LIMS Reference No: 47529

Incident Date: **September 28, 2016**

Ms. Melanie Betsill
Drinking Water Officer
Manitoba Sustainable Development, Office of Drinking Water
1007 Century Street
Winnipeg MB R3H 0W4

RE: CORRECTIVE ACTION REPORT

WATER SYSTEM, CODE	Winnipeg Public Water System, 252.00
LOCATION OF NON-COMPLIANT INCIDENT	Winnipeg 3-Dist NE05
INCIDENT REPORTED BY	Courtney Diduck, Analytical Services Branch Head
TYPE OF NON-COMPLIANT INCIDENT	Low positive Total Coliform (<10 per100mL), 3 MR 41/2007
DESCRIPTION OF CORRECTIVE ACTIONS	<u>Environmental Standards:</u> AS SOON AS POSSIBLE: Re-sampled original location until two consecutive negative results were reported. Also tested for turbidity, free/total chlorine, temperature and contacted the ODW.
TEST RESULTS	See Attached

NOTES/COMMENTS:

1. UP/DOWN STREAM testing performed when EC is >0 /100mL, TC is >10 /100mL or when resample/consecutive sample is positive for EC or TC or as directed by the Manager of Environmental Standards Division and/or the Office of Drinking Water

EMERGENCY REPORTING IS REQUIRED WHERE A POTENTIAL HEALTH RISK IS INVOLVED. FOLLOW THE INSTRUCTIONS OF YOUR DRINKING WATER OFFICER ON SITUATIONS REQUIRING IMMEDIATE REPORTING

N:\Environmental Standards\Analytical Services\Government Agencies\Office of Drinking Water\Corrective Action Reports



Water and Waste Department • Service des eaux et des déchets

Sample Name	Sample Number	Date Sampled	bacColiEsch-QT (MPNU/100mL)	bacColiTotal-QT (MPNU/100mL)	bacHPC (cfu/mL)	Chlorine, Free (mg/L)	Chlorine, Total (mg/L)	Temperature (°C)	Turbidity-field (ntu)	Time Sampled (hrs)
NE05	486482	28-Sep-16	<1	1	<1	0.71	0.95	17.2	0.29	10:10
NE05_Resample 1	487232	29-Sep-16	<1	<1	<1	0.76	1.05	17.0	0.44	15:03
NE05_Resample 1 Duplicate	487233	29-Sep-16	<1	<1	<1	NA	NA	NA	NA	NA
NE05_Resample 2	487236	30-Sep-16	<1	<1	<1	0.83	1.05	17.3	0.26	15:15
NE05_Resample 2 Duplicate	487237	30-Sep-16	<1	<1	<1	NA	NA	NA	NA	NA

NOTES/COMMENTS:

1. All microbiological tests performed by contract laboratory.
2. N/R-No Result due to laboratory/analyst error.
3. N/A-Not Analyzed.