



Water and Waste Department • Service des eaux et des déchets

Environmental Standards Division • Division des Normes Environnementales

January 5, 2018

Derek Clarke
Office of Drinking Water
Manitoba Sustainable Development
Box 6000
Gimli, Manitoba R0C 1B0

Our File: 040-18-18-55-00

Dear Mr. Clarke:

**RE: DECEMBER 2017 WATER QUALITY COMPLIANCE
SUBMISSION FOR THE CITY OF WINNIPEG WATER SUPPLY SYSTEM**

Please find attached on-line and grab turbidity summary reports, on-line and grab chlorine summary reports and the UV summary report for the Water Treatment Plant for December 2017. We have included one corrective action report for a low positive total coliform in the distribution system.

The December on-line and grab sampling turbidity reports include results obtained for the Water Treatment Plant raw water and the eight filters. Please note that on December 13, the turbidity for Filter 5 was greater than 0.3 NTU at start-up after backwashing, and a brief shut-down of DAF train 1 on December 20 caused the turbidities for Filters 1, 3, and 4 to be greater than 0.3 NTU at start-up. The elevated turbidities occurred for short periods of time which did not exceed 12 consecutive hours. The turbidity results for the effluent from the filters met the licence requirements.

The December on-line and grab sampling chlorine reports include results obtained for the Deacon Booster Pumping Station at the Water Treatment Plant. The free chlorine results at the Water Treatment Plant met the licence requirements.

On December 5, a positive total coliform result was reported for a routine sample at the SW04 location. The location was resampled on December 6 and 7 and results were reported negative. Our resampling also indicated that the chlorine levels at the location were normal and provided adequate disinfection. Please see the attached corrective action report for additional details.

The December UV summary report includes results obtained for the six UV reactors at the Water Treatment Plant. The UV disinfection results met the licence requirements.

Please let me know of any concerns or questions respecting this submission. I may be reached by telephone at 204-986-8359 or by e-mail at rgrosselle@winnipeg.ca.

Yours sincerely,

Original signed by:

R. Grosselle
Manager of Environmental Standards

Enclosures

cc: Dr. L. Richards, Winnipeg Regional Health Authority (email)
Dr. H. Chang, Winnipeg Regional Health Authority (email)
Dr. S. Roberecki, Manitoba Health, Seniors and Active Living (email)
M. L. Geer, CPA, CA (email)
G. Patton, P.Eng. (email)
T. Shanks, P.Eng. (email)
M. Szmon, P.Eng. (email)
C. Diduck (email)



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
WATER SERVICES

Water System Code: 252.00
Licence Number: PWS-09-412-01

WATER TREATMENT PLANT TURBIDITY ON-LINE MONITORING REPORT

December 2017 Turbidity (NTU)

Date	Raw		Filter #1		Filter #2		Filter #3		Filter #4		Filter #5		Filter #6		Filter #7		Filter #8	
	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max
1/12/2017	1.15	0.02	0.04	0.10	0.16	0.03	0.13	0.04	0.10	0.04	0.08	0.07	0.09	0.04	0.09	OL	OL	
2/12/2017	1.16	0.03	0.05	0.09	0.16	0.03	0.10	0.04	0.07	0.05	0.09	0.07	0.14	0.04	0.08	OL	OL	
3/12/2017	1.15	0.03	0.08	0.08	0.17	0.03	0.05	0.06	0.11	0.05	0.07	0.07	0.15	0.04	0.10	OL	OL	
4/12/2017	1.13	0.02	0.07	0.09	0.11	0.03	0.08	0.04	0.11	0.04	0.10	0.05	0.14	0.04	0.06	0.01	0.07	
5/12/2017	1.12	0.03	0.05	0.10	0.16	0.03	0.10	0.04	0.07	0.04	0.10	0.08	0.11	0.04	0.09	0.00	0.05	
6/12/2017	1.12	0.03	0.08	0.08	0.17	0.02	0.04	0.06	0.13	0.06	0.08	0.06	0.16	0.04	0.11	0.01	0.01	
7/12/2017	1.13	0.02	0.08	0.10	0.13	0.04	0.11	0.04	0.13	0.04	0.11	0.05	0.08	0.05	0.07	0.01	0.06	
8/12/2017	1.13	0.04	0.09	0.10	0.20	0.03	0.18	0.05	0.10	0.03	0.08	0.07	0.16	0.03	0.10	0.00	0.04	
9/12/2017	1.03	0.02	0.07	0.07	0.16	0.02	0.04	0.06	0.13	0.06	0.08	0.05	0.13	0.03	0.08	0.01	0.01	
10/12/2017	0.96	0.03	0.10	0.10	0.13	0.05	0.10	0.05	0.14	0.04	0.11	0.05	0.09	0.05	0.07	0.01	0.04	
11/12/2017	0.97	0.03	0.05	0.10	0.19	0.03	0.10	0.05	0.08	0.04	0.11	0.08	0.17	0.04	0.08	0.00	0.05	
12/12/2017	1.00	0.04	0.09	0.09	0.20	0.03	0.06	0.09	0.14	0.07	0.11	0.07	0.18	0.04	0.13	0.01	0.01	
13/12/2017	1.05	0.01	0.05	0.07	0.13	0.03	0.13	0.02	0.09	0.02	0.38	0.04	0.09	0.03	0.07	0.00	0.07	
14/12/2017	0.93	0.02	0.07	0.07	0.17	0.02	0.08	0.06	0.10	0.06	0.08	0.05	0.16	0.04	0.11	0.00	0.01	
15/12/2017	0.92	0.01	0.04	0.07	0.10	0.02	0.05	0.03	0.10	0.04	0.10	0.04	0.13	0.04	0.06	0.01	0.04	
16/12/2017	0.91	0.02	0.03	0.09	0.15	0.02	0.08	0.03	0.05	0.04	0.07	0.07	0.09	0.03	0.09	0.00	0.04	
17/12/2017	0.89	0.02	0.06	0.07	0.16	0.02	0.03	0.04	0.10	0.07	0.10	0.05	0.13	0.03	0.10	0.01	0.01	
18/12/2017	0.88	0.02	0.06	0.09	0.12	0.03	0.10	0.03	0.11	0.04	0.10	0.04	0.07	0.05	0.08	0.00	0.05	
19/12/2017	0.87	0.08	0.11	0.10	0.17	0.03	0.11	0.05	0.09	0.05	0.14	0.10	0.14	0.05	0.13	0.01	0.09	
20/12/2017	0.87	0.11	0.42	0.09	0.21	0.05	0.31	0.09	0.38	0.11	0.15	0.08	0.23	0.08	0.17	0.02	0.05	
21/12/2017	0.88	0.09	0.16	0.10	0.14	0.04	0.09	0.06	0.18	0.08	0.15	0.08	0.22	0.08	0.09	0.02	0.10	
22/12/2017	0.86	0.11	0.13	0.09	0.16	0.03	0.11	0.06	0.08	0.07	0.10	0.11	0.15	0.07	0.15	0.01	0.11	
23/12/2017	0.85	0.08	0.17	0.07	0.11	0.03	0.05	0.05	0.16	0.10	0.14	0.06	0.21	0.07	0.08	0.02	0.04	
24/12/2017	0.83	0.10	0.12	0.11	0.19	0.03	0.11	0.05	0.08	0.06	0.16	0.11	0.14	0.07	0.16	0.02	0.11	
25/12/2017	0.81	0.08	0.17	0.07	0.19	0.02	0.04	0.08	0.16	0.11	0.13	0.08	0.22	0.05	0.17	0.02	0.04	
26/12/2017	0.80	0.06	0.12	0.10	0.16	0.03	0.12	0.04	0.16	0.06	0.16	0.09	0.21	0.10	0.14	0.02	0.12	
27/12/2017	0.80	0.02	0.07	0.08	0.19	0.01	0.09	0.06	0.07	0.06	0.09	0.10	0.14	0.07	0.17	0.01	0.11	
28/12/2017	0.79	0.02	0.06	0.07	0.18	0.01	0.03	0.05	0.15	0.08	0.14	0.07	0.20	0.06	0.10	0.03	0.06	
29/12/2017	0.78	0.02	0.03	0.12	0.14	0.02	0.10	0.04	0.15	0.06	0.14	0.06	0.10	0.09	0.16	0.02	0.11	
30/12/2017	0.81	0.02	0.07	0.08	0.19	0.01	0.08	0.06	0.08	0.07	0.10	0.10	0.20	0.06	0.16	0.01	0.11	
31/12/2017	0.81	0.02	0.08	0.07	0.19	0.02	0.02	0.05	0.15	0.08	0.14	0.07	0.20	0.07	0.12	0.03	0.12	

Total Number of Measurements Taken, A: 14160 10805 14508 11360 14985 13591 13373 13342
Turbidity Standard for Monitoring Location (NTU): 0.3 0.3 0.3 0.3 0.3 0.3 0.3 0.3
Number of Measurements Meeting Standard, B: 14128 10805 14502 11334 14984 13591 13373 13342
Compliance with Turbidity Standard, C = B/A X 100%: 99.774% 100.000% 99.959% 99.771% 99.993% 100.000% 100.000% 100.000%
Note: OL - Offline

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Turbidity\2017\12-December

Submitted By (Print): D.Merredew

Signature: Original signed by D.Merredew



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENVIRONMENTAL STANDARDS DIVISION

WATER TREATMENT PLANT TURBIDITY GRAB MONITORING REPORT

Water System Code: 252.00	Turbidity (NTU)																	
	Raw Water		Filter 1		Filter 2		Filter 3		Filter 4		Filter 5		Filter 6		Filter 7		Filter 8	
Date	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser
01-Dec-2017	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	OL	OL
02-Dec-2017	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	OL	OL
03-Dec-2017	0.84	1.11	0.11	0.03	0.08	0.11	0.10	0.04	0.09	0.06	0.09	0.05	OL	OL	0.08	0.04	OL	OL
04-Dec-2017	0.73	1.11	OL	OL	0.08	0.11	0.10	0.04	OL	OL	0.09	0.07	0.07	0.07	0.08	0.04	0.08	<0.02
05-Dec-2017	0.73	1.09	0.09	0.02	0.10	0.13	OL	OL	0.10	0.06	0.08	0.05	0.10	0.09	0.12	0.06	OL	OL
06-Dec-2017	0.92	1.11	0.10	0.04	OL	OL	0.08	0.02	0.09	0.06	0.08	0.05	OL	OL	0.08	0.04	0.08	<0.02
07-Dec-2017	0.82	1.10	0.08	0.02	0.10	0.12	0.10	0.04	OL	OL	OL	OL	0.09	0.08	0.08	0.04	0.09	0.02
08-Dec-2017	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
09-Dec-2017	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
10-Dec-2017	0.74	0.94	0.09	0.02	0.09	0.13	0.11	0.05	OL	OL	OL	OL	0.10	0.08	0.10	0.05	0.13	0.03
11-Dec-2017	0.79	0.94	0.08	0.02	0.09	0.12	OL	OL	0.08	0.07	0.07	0.04	0.09	0.08	0.10	0.05	OL	OL
12-Dec-2017	0.73	0.94	0.12	0.04	OL	OL	0.11	0.05	0.11	0.10	0.09	0.06	0.13	0.12	OL	OL	0.09	0.02
13-Dec-2017	OL	OL	OL	OL	OL	OL	OL	OL	OL	OL	OL	OL	OL	OL	OL	OL	OL	OL
14-Dec-2017	0.73	0.91	0.08	<0.02	0.10	0.13	OL	OL	0.08	0.05	0.06	0.05	0.09	0.08	OL	OL	0.07	<0.02
15-Dec-2017	0.76	0.88	OL	OL	0.07	0.10	0.08	0.02	0.12	0.08	0.08	0.06	OL	OL	0.08	0.04	0.09	<0.02
16-Dec-2017	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
17-Dec-2017	0.74	0.89	0.09	0.02	OL	OL	0.07	<0.02	0.09	0.06	0.07	0.06	0.13	0.11	0.09	0.04	0.07	<0.02
18-Dec-2017	0.76	0.84	OL	OL	0.09	0.10	0.11	0.03	OL	OL	0.14	0.08	0.10	0.07	0.12	0.04	0.11	<0.02
19-Dec-2017	0.65	0.85	0.10	0.10	0.11	0.12	0.19	0.10	0.11	0.07	0.10	0.08	0.12	0.11	0.13	0.08	OL	OL
20-Dec-2017	0.79	0.86	0.50	0.41	OL	OL	0.46	0.31	0.52	0.39	0.16	0.13	0.19	0.16	OL	OL	0.11	0.04
21-Dec-2017	0.65	0.87	OL	OL	0.10	0.10	0.12	0.03	0.16	0.11	0.11	0.10	0.11	0.10	0.11	0.06	0.11	0.04
22-Dec-2017	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
23-Dec-2017	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
24-Dec-2017	0.74	0.81	0.11	0.10	0.12	0.13	OL	OL	0.10	0.07	0.09	0.08	0.12	0.12	0.15	0.10	OL	OL
25-Dec-2017	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
26-Dec-2017	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
27-Dec-2017	0.61	0.76	0.10	0.02	0.12	0.14	OL	OL	0.10	0.06	0.10	0.07	0.13	0.10	OL	OL	0.11	0.04
28-Dec-2017	0.62	0.77	OL	OL	0.08	0.11	0.09	<0.02	0.13	0.09	0.13	0.09	OL	OL	0.13	0.08	0.14	0.05
29-Dec-2017	0.63	0.76	0.10	<0.02	0.10	0.13	0.13	0.03	0.12	0.07	OL	OL	0.13	0.09	0.13	0.09	0.14	0.06
30-Dec-2017	NA	NA	NA	NA	NA	NA	0.09	<0.02	NA									
31-Dec-2017	0.62	0.80	OL	OL	0.10	0.12	0.11	0.02	0.16	0.11	0.13	0.10	OL	OL	0.13	0.08	0.13	0.05
Total number of measurements taken, A:	14		16		16		16		17		15		16		15		15	
Turbidity Standard for Monitoring Location (NTU):	0.30		0.30		0.30		0.30		0.30		0.30		0.30		0.30		0.30	
Number of measurements meeting standard, B:	13		16		15		15		17		15		16		15		15	
Compliance with Turbidity Standard, C= B/A X 100%:	93%		100%		94%		94%		100%		100%		100%		100%		100%	

NS: No Sample NA: Not Analyzed OL: Off-Line

Comments:
The raw water and filter effluent analyzers were offline on December 13, 2017 due to a scheduled WTP shutdown.

Report Compiled By: _____ H.Demchenko

Approved in LIMS By: _____ C.Diduck



City Of Winnipeg

Water and Waste Department

Water Services

WATER TREATMENT PLANT FREE CHLORINE ON-LINE MONITORING REPORT

Deacon Booster Pumping Station

Water System Code: **252.00**Licence Number: **PWS-09-412-01**

Report Created: 01 January 2018

Report Period: December 2017

Date	BRANCH 1 [mg/L]		BRANCH 2 [mg/L]	
	Average	Minimum	Average	Minimum
01/12/2017	1.11	0.94	1.00	0.91
02/12/2017	1.00	0.93	1.06	0.99
03/12/2017	1.01	0.97	1.09	1.01
04/12/2017	0.96	0.88	1.05	0.98
05/12/2017	0.90	0.84	0.99	0.94
06/12/2017	0.88	0.81	0.94	0.74
07/12/2017	0.90	0.82	0.98	0.86
08/12/2017	0.92	0.84	1.01	0.93
09/12/2017	0.96	0.87	1.05	0.90
10/12/2017	0.90	0.78	0.97	0.85
11/12/2017	0.96	0.87	1.02	0.94
12/12/2017	0.89	0.82	0.92	0.85
13/12/2017	0.84	0.67	0.88	0.66
14/12/2017	1.03	0.88	1.13	1.02
15/12/2017	1.05	0.92	1.11	0.97
16/12/2017	0.96	0.88	1.07	0.99
17/12/2017	0.92	0.84	1.05	0.97
18/12/2017	0.94	0.82	1.09	1.02
19/12/2017	0.94	0.86	1.10	0.98
20/12/2017	1.08	1.00	1.09	1.00
21/12/2017	1.19	1.10	1.08	1.04
22/12/2017	1.17	1.06	1.08	1.01
23/12/2017	1.06	0.95	1.03	0.96
24/12/2017	1.02	0.93	1.04	0.95
25/12/2017	1.05	0.96	1.00	0.85
26/12/2017	1.08	0.99	1.05	0.99
27/12/2017	1.06	0.94	1.06	0.95
28/12/2017	1.03	0.93	1.17	1.09
29/12/2017	1.08	1.00	1.19	1.13
30/12/2017	1.04	0.95	1.13	1.07
31/12/2017	1.01	0.95	1.10	1.07

Total Number of Measurements, A: 21601 21601

Minimum Free Chlorine Standard: 0.5 0.5

Number of Measurements Meeting Standard, B: 21601 21601

COMPLIANCE, C = B/A X 100%: 100.00 100.00

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Chlorine\2017\12-December

Submitted By (Print): D.MerredewSignature: Original signed by D.Merredew



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENVIRONMENTAL STANDARDS DIVISION

WATER TREATMENT PLANT CHLORINE GRAB MONITORING REPORT

Water System Code: 252.00 Licence No. PWS-09-412-01		Deacon Booster Pumping Station Branch 1			Deacon Booster Pumping Station Branch 2		
Date	Free Chlorine (mg/L)		Total Chlorine (mg/L)	Free Chlorine (mg/L)		Total Chlorine (mg/L)	
	Analyser	Grab	Grab	Analyser	Grab	Grab	
01-Dec-2017	NA	NA	NA	NA	NA	NA	NA
02-Dec-2017	NA	NA	NA	NA	NA	NA	NA
03-Dec-2017	1.01	1.03	1.17	1.10	1.09	1.27	
04-Dec-2017	0.95	1.01	1.18	1.05	1.07	1.28	
05-Dec-2017	0.91	0.96	1.11	0.95	1.02	1.25	
06-Dec-2017	0.89	0.94	1.05	0.95	0.96	1.14	
07-Dec-2017	0.90	0.92	1.07	0.96	0.99	1.16	
08-Dec-2017	NA	NA	NA	NA	NA	NA	
09-Dec-2017	NA	NA	NA	NA	NA	NA	
10-Dec-2017	0.90	0.93	1.12	0.97	0.99	1.18	
11-Dec-2017	0.98	0.97	1.23	1.03	1.12	1.28	
12-Dec-2017	0.89	0.95	1.13	0.93	0.98	1.20	
13-Dec-2017	OL	OL	OL	OL	OL	OL	
14-Dec-2017	1.03	1.07	1.29	1.09	1.15	1.31	
15-Dec-2017	1.16	1.16	1.38	1.21	1.19	1.40	
16-Dec-2017	NA	NA	NA	NA	NA	NA	
17-Dec-2017	0.91	0.95	1.08	1.04	1.06	1.20	
18-Dec-2017	0.94	1.05	1.18	1.11	1.11	1.22	
19-Dec-2017	0.91	1.00	1.21	1.08	1.14	1.31	
20-Dec-2017	1.10	1.04	1.23	1.03	1.07	1.26	
21-Dec-2017	1.20	1.18	1.43	1.09	1.15	1.32	
22-Dec-2017	NA	NA	NA	NA	NA	NA	
23-Dec-2017	NA	NA	NA	NA	NA	NA	
24-Dec-2017	1.00	1.09	1.27	0.95	1.01	1.24	
25-Dec-2017	NA	NA	NA	NA	NA	NA	
26-Dec-2017	NA	NA	NA	NA	NA	NA	
27-Dec-2017	1.08	1.14	1.32	1.03	1.06	1.27	
28-Dec-2017	1.07	1.17	1.34	1.20	1.19	1.43	
29-Dec-2017	1.11	1.12	1.30	1.17	1.21	1.45	
30-Dec-2017	NA	NA	NA	NA	NA	NA	
31-Dec-2017	0.97	1.11	1.28	1.10	1.15	1.39	
Total number of measurements taken, A:		20			20		
Chlorine Standard for Monitoring Location (mg/L):		0.50			0.50		
Number of measurements meeting standard, B:		20			20		
Compliance with Chlorine Standard, C= B/A X 100%:		100%			100%		

NS: No Sample NA: Not Analyzed OL: Off-Line

Comments:

Branch I and II were offline on December 13, 2017, due to a scheduled WTP shutdown. Branch I was offline on December 20, 2017 for maintenance.

Report Compiled By: _____ H.Demchenko

Approved in LIMS By: _____ C.Diduck



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
WATER SERVICES

Water System Code: 252.00
Licence Number: PWS-09-412-01

WATER TREATMENT PLANT UV REPORT

Report Period: December 2017

Report Created: Monday, January 01, 2018

Date	Transmittance %	UVR-D100A				UVR-D200A				UVR-D300A				UVR-D400A				UVR-D500A				UVR-D600A				Total Water Volume [ML]				% Volume Treated To Dose			
		Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]							
		Untreated	Below	To	Total	Untreated	Below	To	Total																								
01/12/2017	93.93	0.00	0.00	0.00	0.00	0.00	0.00	76.32	76.32	0.00	0.00	0.00	0.00	0.00	0.00	45.76	45.76	0.00	0.00	0.00	0.00	0.00	0.00	69.93	69.93	0.00	0.00	192.01	192.01	100.00			
02/12/2017	93.85	0.00	0.00	0.00	0.00	0.00	0.00	76.36	76.36	0.00	0.00	0.00	0.00	0.00	0.00	45.68	45.68	0.00	0.00	0.00	0.00	0.00	0.00	69.94	69.94	0.00	0.00	191.99	191.99	100.00			
03/12/2017	93.69	0.00	0.00	0.00	0.00	0.00	0.00	76.43	76.43	0.00	0.00	0.00	0.00	0.00	0.00	45.72	45.72	0.00	0.00	0.00	0.00	0.00	0.00	69.93	69.93	0.00	0.00	192.08	192.08	100.00			
04/12/2017	93.98	0.00	0.00	0.00	0.00	0.00	0.00	75.85	75.85	0.00	0.00	0.00	0.00	0.00	0.00	45.99	45.99	0.00	0.00	0.00	0.00	0.00	0.00	70.17	70.17	0.00	0.00	192.01	192.01	100.00			
05/12/2017	93.92	0.00	0.00	0.00	0.00	0.00	0.00	75.78	75.78	0.00	0.00	0.00	0.00	0.00	0.00	46.11	46.11	0.00	0.00	0.00	0.00	0.00	0.00	70.15	70.15	0.00	0.00	192.05	192.05	100.00			
06/12/2017	93.96	0.00	0.00	0.00	0.00	0.00	0.00	74.44	74.44	0.00	0.00	0.00	0.00	0.00	0.00	47.07	47.07	0.00	0.00	0.00	0.00	0.00	0.00	63.41	63.41	0.00	0.00	184.92	184.92	100.00			
07/12/2017	94.04	0.00	0.00	0.00	0.00	0.00	0.00	68.06	68.06	0.00	0.00	0.00	0.00	0.00	0.00	56.75	56.75	0.00	0.00	0.00	0.00	0.00	0.00	57.07	57.07	0.00	0.00	181.88	181.88	100.00			
08/12/2017	94.22	0.00	0.00	0.00	0.00	0.00	0.00	75.00	75.00	0.00	0.00	0.00	0.00	0.00	0.00	50.83	50.83	0.00	0.00	0.00	0.00	0.00	0.00	56.19	56.23	0.00	0.04	182.01	182.05	99.98			
09/12/2017	94.50	0.00	0.00	0.00	0.00	0.00	0.00	74.87	74.87	0.00	0.00	0.00	0.00	0.00	0.00	50.73	50.73	0.00	0.00	0.00	0.00	0.00	0.00	56.40	56.40	0.00	0.00	182.00	182.00	100.00			
10/12/2017	94.10	0.00	0.00	0.00	0.00	0.00	0.00	74.79	74.79	0.00	0.00	0.00	0.00	0.00	0.00	50.65	50.65	0.00	0.00	0.00	0.00	0.00	0.00	56.57	56.57	0.00	0.00	182.02	182.02	100.00			
11/12/2017	94.39	0.00	0.00	0.00	0.00	0.00	0.00	74.90	74.90	0.00	0.00	0.00	0.00	0.00	0.00	50.73	50.73	0.00	0.00	0.00	0.00	0.00	0.00	56.38	56.38	0.00	0.00	182.01	182.01	100.00			
12/12/2017	94.07	0.00	0.00	0.00	0.00	0.00	0.00	74.83	74.83	0.00	0.00	0.00	0.00	0.00	0.00	50.64	50.64	0.00	0.00	0.00	0.00	0.00	0.00	56.51	56.51	0.00	0.00	181.98	181.98	100.00			
13/12/2017	93.60	0.00	0.00	0.00	0.00	0.00	0.00	45.34	45.34	0.00	0.00	0.00	0.00	0.00	0.00	38.87	38.87	0.00	0.00	0.00	0.00	0.00	0.00	32.40	32.40	0.00	0.00	116.62	116.62	100.00			
14/12/2017	94.34	0.00	0.00	0.00	0.00	0.00	0.00	75.10	75.10	0.00	0.00	0.00	0.00	0.00	0.00	50.76	50.76	0.00	0.00	0.00	0.00	0.00	0.00	57.13	57.13	0.00	0.00	182.99	182.99	100.00			
15/12/2017	94.75	0.00	0.00	0.00	0.00	0.00	0.00	74.97	74.97	0.00	0.00	0.00	0.00	0.00	0.00	50.75	50.75	0.00	0.00	0.00	0.00	0.00	0.00	57.21	57.21	0.00	0.00	182.92	182.92	100.00			
16/12/2017	94.69	0.00	0.00	32.39	32.39	0.00	0.00	65.37	65.37	0.00	0.53	0.00	0.53	0.00	0.00	65.18	65.18	0.11	0.29	0.38	0.78	0.03	0.03	17.64	17.71	0.14	0.86	180.96	181.96	99.45			
17/12/2017	94.64	0.00	0.00	48.05	48.05	0.00	0.00	60.68	60.68	0.00	0.00	0.00	0.00	0.00	0.00	72.26	72.26	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	100.00			
18/12/2017	95.32	0.00	0.00	49.16	49.16	0.00	0.00	62.68	62.68	0.00	0.00	0.12	0.12	0.00	0.00	73.34	73.34	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	100.00			
19/12/2017	95.40	0.00	0.00	29.81	29.81	0.00	0.00	38.96	38.96	0.00	0.00	17.98	17.98	0.00	0.00	65.67	65.67	0.00	0.04	0.08	0.12	0.00	0.00	31.90	31.90	0.00	0.04	184.39	184.43	99.98			
20/12/2017	94.65	0.00	0.00	32.37	32.37	0.00	0.00	0.73	0.73	0.00	0.00	43.25	43.25	0.00	0.00	59.69	59.69	0.00	0.00	0.00	0.00	0.00	0.00	46.57	46.57	0.00	0.00	182.60	182.60	100.00			
21/12/2017	94.97	0.00	0.00	74.41	74.41	0.00	0.00	0.00	0.00	0.00	0.00	43.81	43.81	0.00	0.00	66.80	66.80	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	100.00			
22/12/2017	95.05	0.00	0.00	72.77	72.77	0.00	0.00	0.00	0.00	0.00	0.00	42.72	42.72	0.00	0.00	65.20	65.20	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	100.00			
23/12/2017	95.05	0.05	0.00	68.62	68.67	0.00	0.00	0.00	0.00	0.11	39.87	39.98	0.00	0.00	61.16	61.16	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.16	169.65	169.81	99.91				
24/12/2017	95.01	0.00	0.00	66.57	66.57	0.00	0.00	0.00	0.00	0.00	39.54	39.54	0.00	0.03	39.43	39.45	0.00	0.04	21.10	21.15	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.07	166.65	166.72	99.96	
25/12/2017	94.91	0.00	0.00	67.95	67.95	0.00	0.00	0.00	0.00	0.00	38.05	38.05	0.00	0.00	56.91	56.91	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	100.00			
26/12/2017	94.89	0.00	0.00	71.81	71.81	0.00	0.00	0.00	0.00	0.00	41.16	41.16	0.00	0.00	58.52	58.52	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	100.00			
27/12/2017	95.09	0.00	0.00	70.88	70.88	0.00	0.00	0.00	0.00	0.00	44.69	44.69	0.00	0.00	37.66	37.66	0.00	0.00	21.74	21.74	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	174.97	174.97	100.00
28/12/2017	95.17	0.00	0.00	60.89	60.89	0.00	0.00	23.00	23.00	0.00	0.00	57.17	57.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	100.00			
29/12/2017	95.03	0.00	0.00	49.87	49.87	0.00	0.00	62.22	62.22	0.00	0.00	70.73	70.73	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	100.00			
30/12/2017	95.06	0.00	0.00	50.15	50.15	0.00	0.00	62.70	62.70	0.00	0.00	71.18	71.18	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	100.00			
31/12/2017	94.94	0.00	0.00	50.10	50.10	0.00	0.00	62.75	62.75	0.00	0.00	71.17	71.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	100.00			

Water Volume [%]:

Untreated: 0.00 %

Below Dose: 0.02 %

To Dose: 99.98 %

Submitted By (Print): D.Merredew



Water and Waste Department • Service des eaux et des déchets

Monday, December 18, 2017

Our Incident/Report No: 05-2017

LIMS Reference No: 51471

Incident Date: **December 5, 2017**

Mr. Derek Clarke
Drinking Water Officer
Manitoba Sustainable Development, Office of Drinking Water
Box 6000
Gimli, MB R0C 1B0

RE: CORRECTIVE ACTION REPORT

WATER SYSTEM, CODE	Winnipeg Public Water System, 252.00
LOCATION OF NON-COMPLIANT INCIDENT	Winnipeg 3-Dist SW04
INCIDENT REPORTED BY	Courtney Diduck, Analytical Services Branch Head
TYPE OF NON-COMPLIANT INCIDENT	Low positive Total Coliform (<10 per100mL), 3 MR 41/2007
DESCRIPTION OF CORRECTIVE ACTIONS	<u>Environmental Standards:</u> AS SOON AS POSSIBLE: Re-sampled original location until two consecutive negative results were reported. Also tested for turbidity, free/total chlorine, temperature and contacted the ODW.
TEST RESULTS	See Attached

NOTES/COMMENTS:

1. UP/DOWN STREAM testing performed when EC is >0 /100mL, TC is >10 /100mL or when resample/consecutive sample is positive for EC or TC or as directed by the Manager of Environmental Standards Division and/or the Office of Drinking Water

EMERGENCY REPORTING IS REQUIRED WHERE A POTENTIAL HEALTH RISK IS INVOLVED. FOLLOW THE INSTRUCTIONS OF YOUR DRINKING WATER OFFICER ON SITUATIONS REQUIRING IMMEDIATE REPORTING

N:\Environmental Standards\Analytical Services\Government Agencies\Office of Drinking Water\Corrective Action Reports



Water and Waste Department • Service des eaux et des déchets

Sample Name	Sample Number	Date Sampled	bacColiEsch-QT (MPNU/100mL)	bacColiTotal-QT (MPNU/100mL)	bacHPC (cfu/mL)	Chlorine, Free (mg/L)	Chlorine, Total (mg/L)	Temperature (°C)	Turbidity-field (ntu)	Time Sampled (hrs)
SW04	532472	05-Dec-17	<1	1	<1	1.06	1.25	10.8	0.15	10:35
SW04_Resample	533080	06-Dec-17	<1	<1	<1	1.07	1.32	6.7	0.24	15:04
SW04_Resample 2	533082	07-Dec-17	<1	<1	<1	1.02	1.26	6.3	0.13	15:09
SW04_Resample 2 Duplicate	533104	07-Dec-17	<1	<1	<1	NA	NA	NA	NA	15:09

NOTES/COMMENTS:

1. All microbiological tests performed by contract laboratory.
2. N/R-No Result due to laboratory/analyst error.
3. N/A-Not Analyzed.