



**Water and Waste Department • Service des eaux et des déchets**  
*Environmental Standards Division • Division des Normes Environnementales*

---

March 6, 2017

Marc Balcaen  
Office of Drinking Water  
Manitoba Sustainable Development  
1007 Century Street  
Winnipeg, Manitoba R3H 0W4

Our File: 040-18-18-55-00

Dear Mr. Balcaen:

**RE: FEBRUARY 2017 WATER QUALITY COMPLIANCE  
SUBMISSION FOR THE CITY OF WINNIPEG WATER SUPPLY SYSTEM**

Please find attached on-line and grab turbidity summary reports, on-line and grab chlorine summary reports and the UV summary report for the Water Treatment Plant for February 2017. There are no corrective action reports to be submitted for February 2017.

The February on-line and grab sampling turbidity reports include results obtained for the Water Treatment Plant raw water and the eight filters. The turbidity results for the effluent from the filters met the licence requirements.

The February on-line and grab sampling chlorine reports include results obtained for the Deacon Booster Pumping Station at the Water Treatment Plant. The free chlorine results at the Water Treatment Plant met the licence requirements.

The February UV summary report includes results obtained for the six UV reactors at the Water Treatment Plant. The UV disinfection results met the licence requirements.

Please let me know of any concerns or questions respecting this submission. I may be reached by telephone at 204-986-8359 or by e-mail at [rgrosselle@winnipeg.ca](mailto:rgrosselle@winnipeg.ca).

Yours sincerely,

*Original signed by:*

R. Grosselle  
Manager of Environmental Standards

Enclosures

cc: Dr. L. Richards, Winnipeg Regional Health Authority (email)  
Dr. H. Chang, Winnipeg Regional Health Authority (email)  
Dr. S. Roberecki, Manitoba Health, Seniors and Active Living (email)  
M. L. Geer, CPA, CA (email)  
G. Patton, P.Eng. (email)  
T. Shanks, P.Eng. (email)  
M. Szmon, P.Eng. (email)  
C. Diduck (email)







CITY OF WINNIPEG  
WATER AND WASTE DEPARTMENT  
ENVIRONMENTAL STANDARDS DIVISION

**WATER TREATMENT PLANT TURBIDITY GRAB MONITORING REPORT**

Water System Code: 252.00	Turbidity (NTU)																	
	Raw Water		Filter 1		Filter 2		Filter 3		Filter 4		Filter 5		Filter 6		Filter 7		Filter 8	
Date	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser
01-Feb-2017	0.49	0.55	OL	OL	0.08	0.04	0.11	<0.02	0.07	<0.02	0.10	<0.02	0.08	<0.02	0.07	<0.02	0.07	<0.02
02-Feb-2017	0.51	0.52	0.06	<0.02	OL	OL	0.07	<0.02	0.08	<0.02	0.06	<0.02	0.08	<0.02	0.06	<0.02	0.06	<0.02
03-Feb-2017	0.53	0.52	0.06	<0.02	0.07	0.02	0.06	<0.02	0.06	<0.02	0.06	<0.02	0.06	<0.02	OL	OL	OL	OL
04-Feb-2017	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
05-Feb-2017	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
06-Feb-2017	0.50	0.50	0.07	0.02	0.08	0.02	0.07	<0.02	OL	OL	0.07	<0.02	0.07	<0.02	0.07	<0.02	OL	OL
07-Feb-2017	0.47	0.50	OL	OL	0.06	0.03	0.07	<0.02	OL	OL	0.08	<0.02	0.07	<0.02	0.06	<0.02	0.08	<0.02
08-Feb-2017	0.50	0.49	0.06	<0.02	OL	OL	0.06	<0.02	0.09	0.02	0.06	<0.02	0.08	<0.02	0.06	<0.02	0.06	<0.02
09-Feb-2017	0.50	0.50	0.06	<0.02	0.05	0.02	0.06	<0.02	0.05	<0.02	0.06	<0.02	0.06	<0.02	0.07	<0.02	OL	OL
10-Feb-2017	0.49	0.51	0.05	<0.02	0.06	0.02	0.06	<0.02	0.07	<0.02	0.07	<0.02	0.06	<0.02	0.06	<0.02	<0.05	<0.02
11-Feb-2017	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
12-Feb-2017	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
13-Feb-2017	0.48	0.52	0.08	<0.02	0.08	0.03	0.10	<0.02	0.09	<0.02	OL	OL	0.11	<0.02	0.09	<0.02	0.08	<0.02
14-Feb-2017	0.47	0.51	0.09	0.02	OL	OL	0.09	<0.02	0.08	<0.02	0.08	<0.02	0.11	0.03	0.10	<0.02	0.12	0.02
15-Feb-2017	0.48	0.50	0.09	0.03	0.08	0.03	0.10	<0.02	0.12	<0.02	0.11	0.02	0.09	<0.02	0.07	<0.02	0.07	<0.02
16-Feb-2017	0.56	0.52	0.12	0.03	0.18	0.08	0.14	<0.02	OL	OL	0.12	<0.02	0.06	<0.02	0.11	<0.02	0.10	<0.02
17-Feb-2017	0.48	0.50	0.09	0.03	0.08	0.02	0.09	<0.02	OL	OL	0.10	<0.02	0.09	<0.02	0.16	<0.02	0.15	0.04
18-Feb-2017	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
19-Feb-2017	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
20-Feb-2017	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
21-Feb-2017	0.50	0.56	0.11	0.03	0.09	0.03	0.08	0.03	0.10	<0.02	0.09	<0.02	0.07	<0.02	OL	OL	0.06	<0.02
22-Feb-2017	0.54	0.55	0.09	0.03	0.12	0.06	0.10	<0.02	OL	OL	0.09	<0.02	0.11	0.02	0.09	<0.02	0.08	<0.02
23-Feb-2017	0.48	0.56	0.06	<0.02	0.06	<0.02	0.06	<0.02	0.06	<0.02	0.06	<0.02	0.06	<0.02	OL	OL	0.07	<0.02
24-Feb-2017	0.50	0.53	0.12	0.02	0.08	<0.02	0.09	<0.02	0.09	<0.02	0.11	0.04	0.08	<0.02	0.07	<0.02	0.07	<0.02
25-Feb-2017	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
26-Feb-2017	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
27-Feb-2017	0.52	0.55	0.12	0.02	0.10	<0.02	0.10	0.02	0.10	<0.02	0.10	0.04	0.11	<0.02	OL	OL	0.08	<0.02
28-Feb-2017	0.50	0.56	0.08	<0.02	0.11	<0.02	0.16	0.10	OL	OL	0.09	0.02	0.09	0.02	0.09	<0.02	0.08	<0.02
<b>Total number of measurements taken, A:</b>			17		16		19		13		18		18		16		15	
<b>Turbidity Standard for Monitoring Location (NTU):</b>			0.30		0.30		0.30		0.30		0.30		0.30		0.30		0.30	
<b>Number of measurements meeting standard, B:</b>			17		16		19		13		18		18		16		15	
<b>Compliance with Turbidity Standard, C= B/A X 100%:</b>			100%		100%		100%		100%		100%		100%		100%		100%	

NS: No Sample NA: Not Analyzed OL: Off-Line

Comments:

Report Compiled By: \_\_\_\_\_ H.Demchenko \_\_\_\_\_

Approved in LIMS By: \_\_\_\_\_ C.Diduck \_\_\_\_\_



**WATER TREATMENT PLANT FREE CHLORINE ON-LINE MONITORING REPORT**  
**Deacon Booster Pumping Station**

Water System Code: **252.00**

Licence Number: **PWS-09-412-01**

Report Created: 01 March 2017

Report Period: February 2017

Date	BRANCH 1 [mg/L]		BRANCH 2 [mg/L]	
	Average	Minimum	Average	Minimum
01/02/2017	1.17	1.08	1.25	1.07
02/02/2017	1.17	1.08	1.24	1.10
03/02/2017	1.20	1.15	1.26	1.12
04/02/2017	1.21	1.12	1.26	1.11
05/02/2017	1.22	1.14	1.26	1.12
06/02/2017	1.25	1.17	1.34	1.20
07/02/2017	1.23	1.11	1.28	1.10
08/02/2017	1.26	1.15	1.23	1.13
09/02/2017	1.28	1.19	1.25	1.13
10/02/2017	1.20	1.11	1.19	1.04
11/02/2017	1.19	1.13	1.16	1.04
12/02/2017	1.14	1.09	1.15	1.05
13/02/2017	1.07	0.99	1.11	0.94
14/02/2017	1.13	0.95	1.18	0.99
15/02/2017	1.22	1.17	1.18	1.00
16/02/2017	1.22	1.22	1.17	1.12
17/02/2017	1.27	1.22	1.14	1.04
18/02/2017	1.35	1.24	1.20	1.09
19/02/2017	1.25	1.15	1.18	1.12
20/02/2017	1.14	1.10	1.10	1.05
21/02/2017	1.15	1.07	1.11	1.06
22/02/2017	1.19	1.08	1.15	1.10
23/02/2017	1.21	1.15	1.13	1.05
24/02/2017	1.14	1.10	1.04	1.00
25/02/2017	1.21	1.12	1.09	1.04
26/02/2017	1.23	1.13	1.11	1.04
27/02/2017	1.18	1.09	1.12	1.02
28/02/2017	1.19	1.16	1.18	1.13

Total Number of Measurements, A: 19443 19441

Minimum Free Chlorine Standard: 0.5 0.5

Number of Measurements Meeting Standard, B: 19443 19441

COMPLIANCE, C = B/A X 100%: 100.00 100.00

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Chlorine\2017\02-February

Submitted By (Print): D. Merredew

Signature: Original signed by D. Merredew



CITY OF WINNIPEG  
WATER AND WASTE DEPARTMENT  
ENVIRONMENTAL STANDARDS DIVISION

**WATER TREATMENT PLANT CHLORINE GRAB MONITORING REPORT**

Water System Code: 252.00	Deacon Booster Pumping Station Branch 1			Deacon Booster Pumping Station Branch 2		
Date	Free Chlorine (mg/L)		Total Chlorine (mg/L)	Free Chlorine (mg/L)		Total Chlorine (mg/L)
	Analyser	Grab	Grab	Analyser	Grab	Grab
01-Feb-2017	1.15	1.18	1.42	1.24	1.29	1.54
02-Feb-2017	1.16	1.27	1.41	1.23	1.28	1.53
03-Feb-2017	1.19	1.31	1.46	1.27	1.33	1.56
04-Feb-2017	NS	NS	NS	NS	NS	NS
05-Feb-2017	NS	NS	NS	NS	NS	NS
06-Feb-2017	1.28	1.33	1.54	1.41	1.42	1.65
07-Feb-2017	1.25	1.17	1.40	1.23	1.21	1.43
08-Feb-2017	1.23	1.32	1.43	1.21	1.24	1.43
09-Feb-2017	1.33	1.32	1.48	1.28	1.30	1.48
10-Feb-2017	1.22	1.26	1.50	1.22	1.27	1.49
11-Feb-2017	NS	NS	NS	NS	NS	NS
12-Feb-2017	NS	NS	NS	NS	NS	NS
13-Feb-2017	1.06	1.12	1.36	1.09	1.16	1.37
14-Feb-2017	1.20	1.17	1.32	1.20	1.21	1.38
15-Feb-2017	1.23	1.31	1.47	1.07	1.15	1.31
16-Feb-2017	OL	OL	OL	1.24	1.34	1.50
17-Feb-2017	1.27	1.33	1.51	1.11	1.19	1.47
18-Feb-2017	NS	NS	NS	NS	NS	NS
19-Feb-2017	NS	NS	NS	NS	NS	NS
20-Feb-2017	NS	NS	NS	NS	NS	NS
21-Feb-2017	1.15	1.30	1.50	1.09	1.23	1.41
22-Feb-2017	1.20	1.35	1.50	1.12	1.24	1.43
23-Feb-2017	1.21	1.37	1.50	1.12	1.26	1.44
24-Feb-2017	1.14	1.27	1.43	1.04	1.11	1.32
25-Feb-2017	NS	NS	NS	NS	NS	NS
26-Feb-2017	NS	NS	NS	NS	NS	NS
27-Feb-2017	1.17	1.33	1.49	1.10	1.24	1.43
28-Feb-2017	1.20	1.37	1.51	1.18	1.25	1.44
<b>Total number of measurements taken, A:</b>		18				19
<b>Chlorine Standard for Monitoring Location (mg/L):</b>		0.50				0.50
<b>Number of measurements meeting standard, B:</b>		18				19
<b>Compliance with Chlorine Standard, C= B/A X 100%:</b>		100%				100%

NS: No Sample    NA: Not Analyzed    OL: Off-Line

**Comments:**

On February 16th, DBPS 1 was offline at the time of sampling.

Report Compiled By: H.Demchenko

Approved in LIMS By: C.Diduck

