



Water and Waste Department • Service des eaux et des déchets
Environmental Standards Division • Division des Normes Environnementales

April 7, 2017

Marc Balcaen
Office of Drinking Water
Manitoba Sustainable Development
1007 Century Street
Winnipeg, Manitoba R3H 0W4

Our File: 040-18-18-55-00

Dear Mr. Balcaen:

**RE: MARCH 2017 WATER QUALITY COMPLIANCE
SUBMISSION FOR THE CITY OF WINNIPEG WATER SUPPLY SYSTEM**

Please find attached on-line and grab turbidity summary reports, on-line and grab chlorine summary reports and the UV summary report for the Water Treatment Plant for March 2017. There are no corrective action reports to be submitted for March 2017.

The March on-line and grab sampling turbidity reports include results obtained for the Water Treatment Plant raw water and the eight filters. The turbidity results for the effluent from the filters met the licence requirements.

The March on-line and grab sampling chlorine reports include results obtained for the Deacon Booster Pumping Station at the Water Treatment Plant. The free chlorine results at the Water Treatment Plant met the licence requirements.

The March UV summary report includes results obtained for the six UV reactors at the Water Treatment Plant. The UV disinfection results met the licence requirements.

Please let me know of any concerns or questions respecting this submission. I may be reached by telephone at 204-986-8359 or by e-mail at rgrosselle@winnipeg.ca.

Yours sincerely,

Original signed by:

R. Grosselle
Manager of Environmental Standards

Enclosures

cc: Dr. L. Richards, Winnipeg Regional Health Authority (email)
Dr. H. Chang, Winnipeg Regional Health Authority (email)
Dr. S. Roberecki, Manitoba Health, Seniors and Active Living (email)
M. L. Geer, CPA, CA (email)
G. Patton, P.Eng. (email)
T. Shanks, P.Eng. (email)
M. Szmon, P.Eng. (email)
C. Diduck (email)





CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
WATER SERVICES

Water System Code: 252.00
Licence Number: PWS-09-412-01

WATER TREATMENT PLANT TURBIDITY ON-LINE MONITORING REPORT

March 2017 Turbidity (NTU)

Date	Raw		Filter #1		Filter #2		Filter #3		Filter #4		Filter #5		Filter #6		Filter #7		Filter #8	
	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max
1/03/2017	0.60	0.01	0.05		0.00	0.05	0.01	0.08	0.02	0.02	0.03	0.07	0.02	0.11	0.03	0.10	0.00	0.04
2/03/2017	0.60	0.01	0.04		0.00	0.01	0.01	0.10	0.01	0.04	0.02	0.07	0.02	0.04	0.02	0.10	0.01	0.01
3/03/2017	0.60	0.01	0.02		0.00	0.08	0.01	0.10	0.01	0.04	0.02	0.04	0.02	0.11	0.04	0.08	0.01	0.02
4/03/2017	0.61	0.01	0.05		0.00	0.00	0.02	0.04	0.02	0.02	0.03	0.06	0.02	0.11	0.03	0.10	0.01	0.25
5/03/2017	0.62	0.01	0.05		0.00	0.04	0.02	0.11	0.01	0.05	0.02	0.06	0.03	0.06	0.02	0.04	0.01	0.01
6/03/2017	0.63	0.01	0.04		0.00	0.03	0.02	0.06	0.01	0.02	0.02	0.04	0.02	0.12	0.03	0.11	0.00	0.03
7/03/2017	0.66	0.01	0.04		0.00	0.00	0.02	0.04	0.01	0.04	0.02	0.07	0.01	0.03	0.02	0.09	0.00	0.02
8/03/2017	0.67	0.01	0.01		0.00	0.03	0.02	0.08	0.01	0.04	0.01	0.06	0.02	0.11	0.03	0.04	0.01	0.01
9/03/2017	0.68	0.01	0.04		0.00	0.03	0.01	0.02	0.01	0.02	0.02	0.05	0.02	0.10	0.03	0.09	0.00	0.01
10/03/2017	0.68	0.01	0.03		0.00	0.01	0.02	0.07	0.01	0.04	0.02	0.06	0.01	0.04	0.02	0.10	0.00	0.01
11/03/2017	0.69	0.01	0.02		0.00	0.04	0.01	0.09	0.01	0.04	0.01	0.03	0.02	0.10	0.03	0.05	0.01	0.01
12/03/2017	0.70	O/L	O/L		0.01	0.09	0.02	0.04	0.02	0.02	0.04	0.07	0.04	0.19	0.05	0.10	0.01	0.05
13/03/2017	0.72	O/L	O/L		0.00	0.01	0.02	0.11	0.01	0.02	0.02	0.06	0.01	0.09	0.03	0.09	0.01	0.01
14/03/2017	0.73	O/L	O/L		0.00	0.06	0.04	0.09	0.01	0.05	0.02	0.08	0.02	0.06	0.02	0.10	0.01	0.01
15/03/2017	0.74	O/L	O/L		0.01	0.07	0.04	0.15	0.02	0.08	0.02	0.04	0.03	0.09	0.03	0.06	0.01	0.01
16/03/2017	0.75	O/L	O/L		0.00	0.07	0.04	0.06	0.02	0.02	0.03	0.07	0.02	0.06	0.03	0.11	0.01	0.01
17/03/2017	0.77	O/L	O/L		0.00	0.04	0.05	0.24	0.02	0.09	0.03	0.07	0.02	0.03	0.03	0.11	0.01	0.01
18/03/2017	0.75	0.01	0.05		0.01	0.07	0.03	0.11	0.01	0.09	0.02	0.04	0.03	0.11	0.03	0.04	0.01	0.01
19/03/2017	0.75	0.01	0.04		0.00	0.00	0.04	0.06	0.02	0.02	0.03	0.08	0.02	0.10	0.03	0.10	0.00	0.02
20/03/2017	0.73	0.01	0.01		0.01	0.06	0.05	0.12	0.01	0.09	0.02	0.08	0.03	0.04	0.02	0.10	0.00	0.01
21/03/2017	0.74	0.02	0.08		0.02	0.10	0.04	0.15	0.01	0.02	0.04	0.06	0.04	0.13	0.05	0.07	0.01	0.03
22/03/2017	0.75	0.01	0.09		0.02	0.04	0.08	0.10	0.03	0.12	0.04	0.12	0.03	0.05	0.04	0.14	0.01	0.06
23/03/2017	0.74	0.01	0.05		0.01	0.10	0.05	0.16	0.01	0.11	0.02	0.22	0.04	0.15	0.02	0.05	0.01	0.01
24/03/2017	0.76	0.00	0.01		0.00	0.00	0.01	0.06	0.01	0.02	0.01	0.06	0.02	0.07	0.02	0.11	0.00	0.03
25/03/2017	0.75	0.00	0.00		0.00	0.00	0.00	0.00	0.00	0.00	0.02	0.09	0.03	0.05	0.02	0.11	0.00	0.03
26/03/2017	0.75	0.00	0.00		0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.02	0.02	0.09	0.02	0.04	0.01	0.01
27/03/2017	0.75	0.00	0.00		0.00	0.00	0.00	0.02	0.00	0.00	0.01	0.05	0.01	0.08	0.02	0.07	0.00	0.01
28/03/2017	0.76	0.00	0.00		0.00	0.00	0.00	0.04	0.00	0.00	0.01	0.05	0.01	0.03	0.01	0.07	0.00	0.01
29/03/2017	0.75	0.00	0.00		0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.02	0.01	0.07	0.01	0.03	0.01	0.01
30/03/2017	0.75	0.00	0.00		0.00	0.00	0.00	0.03	0.00	0.00	0.01	0.05	0.01	0.08	0.02	0.07	0.00	0.01
31/03/2017	0.77	0.00	0.00		0.00	0.00	0.00	0.04	0.00	0.00	0.01	0.06	0.02	0.04	0.02	0.08	0.00	0.01

Total Number of Measurements Taken, A: 7779 2719 11184 7569 15053 14958 13374 14542
Turbidity Standard for Monitoring Location (NTU): 0.3 0.3 0.3 0.3 0.3 0.3 0.3 0.3
Number of Measurements Meeting Standard, B: 7779 2719 11184 7569 15053 14958 13374 14542
Compliance with Turbidity Standard, C = B/A X 100%: 100.000% 100.000% 100.000% 100.000% 100.000% 100.000% 100.000% 100.000%

Note: OL - Offline

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Turbidity\2017\03-March

Submitted By (Print): D.Merredew

Signature: Original Signed by D.Merredew



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENVIRONMENTAL STANDARDS DIVISION

WATER TREATMENT PLANT TURBIDITY GRAB MONITORING REPORT

Water System Code: 252.00	Turbidity (NTU)																	
	Raw Water		Filter 1		Filter 2		Filter 3		Filter 4		Filter 5		Filter 6		Filter 7		Filter 8	
Date	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser
01-Mar-2017	0.53	0.57	0.11	<0.02	0.08	<0.02	0.10	0.02	0.10	<0.02	0.11	0.03	OL	OL	0.14	0.04	0.17	0.04
02-Mar-2017	0.55	0.56	OL	OL	0.10	<0.02	0.10	0.02	0.11	<0.02	0.12	0.04	0.10	<0.02	0.09	0.02	0.09	<0.02
03-Mar-2017	0.52	0.55	0.09	<0.02	OL	OL	OL	OL	0.08	<0.02	0.07	<0.02	0.12	0.03	0.10	0.02	0.10	<0.02
04-Mar-2017	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
05-Mar-2017	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
06-Mar-2017	0.57	0.60	0.09	<0.02	OL	OL	OL	OL	0.08	<0.02	0.08	<0.02	0.17	0.06	0.12	0.02	0.12	<0.02
07-Mar-2017	0.59	0.64	0.11	<0.02	0.07	<0.02	0.08	0.02	0.08	<0.02	0.10	0.03	0.10	<0.02	OL	OL	OL	OL
08-Mar-2017	0.62	0.66	0.07	<0.02	0.08	<0.02	0.10	0.03	OL	OL	OL	0.11	<0.02	0.09	0.02	0.09	<0.02	
09-Mar-2017	0.65	0.66	0.12	<0.02	OL	OL	0.10	<0.02	0.09	<0.02	0.10	0.02	OL	OL	0.16	0.03	0.16	<0.02
10-Mar-2017	0.55	0.67	OL	OL	0.09	<0.02	0.10	<0.02	0.12	<0.02	0.12	0.03	0.11	<0.02	OL	OL	0.12	<0.02
11-Mar-2017	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
12-Mar-2017	NS	NS	OL	OL	NS													
13-Mar-2017	0.61	0.70	OL	OL	0.13	<0.02	0.14	<0.02	0.19	<0.02	0.19	0.03	0.18	<0.02	OL	OL	0.17	<0.02
14-Mar-2017	0.62	0.71	OL	OL	0.18	<0.02	0.14	0.02	0.17	0.04	0.09	<0.02	0.13	<0.02	0.13	0.02	0.11	<0.02
15-Mar-2017	0.60	0.69	OL	OL	OL	OL	0.11	0.03	0.10	<0.02	0.11	0.02	0.15	0.04	0.11	0.02	0.12	<0.02
16-Mar-2017	0.62	0.72	OL	OL	0.13	<0.02	0.12	0.05	0.11	<0.02	0.11	0.03	0.10	0.02	0.14	0.04	OL	OL
17-Mar-2017	0.65	0.79	OL	OL	0.10	<0.02	0.11	0.05	0.12	<0.02	0.14	0.06	0.09	<0.02	0.09	<0.02	0.07	<0.02
18-Mar-2017	NS	NS	0.09	<0.02	NS													
19-Mar-2017	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
20-Mar-2017	0.62	0.74	0.10	<0.02	0.11	<0.02	0.13	0.06	0.13	<0.02	OL	OL	0.11	0.02	OL	OL	0.08	<0.02
21-Mar-2017	0.64	0.71	0.21	<0.02	OL	OL	0.14	0.05	0.13	<0.02	0.11	0.03	0.22	0.11	0.13	0.04	0.13	<0.02
22-Mar-2017	0.65	0.73	0.14	<0.02	0.13	0.02	0.15	0.08	0.14	<0.02	0.14	0.06	0.13	0.04	OL	OL	OL	OL
23-Mar-2017	0.60	0.73	0.11	<0.02	0.14	0.02	OL	OL	OL	OL	0.11	0.03	0.12	<0.02	0.14	0.02	0.11	<0.02
24-Mar-2017	0.66	0.69	OL	OL	0.07	<0.02	0.07	0.02	0.07	<0.02	0.07	<0.02	OL	OL	0.08	<0.02	0.06	<0.02
25-Mar-2017	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
26-Mar-2017	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
27-Mar-2017	0.61	0.74	OL	OL	0.07	<0.02	0.08	0.02	0.08	<0.02	0.09	<0.02	0.08	<0.02	0.10	0.02	OL	OL
28-Mar-2017	0.59	0.72	0.08	<0.02	0.08	<0.02	0.11	0.04	OL	OL	OL	OL	0.09	<0.02	0.08	<0.02	0.07	<0.02
29-Mar-2017	0.61	0.73	0.09	<0.02	OL	OL	OL	OL	0.07	<0.02	0.07	<0.02	0.10	0.02	0.08	<0.02	0.07	<0.02
30-Mar-2017	0.59	0.73	OL	OL	0.07	<0.02	0.08	0.03	0.09	<0.02	0.08	<0.02	0.07	<0.02	0.09	0.02	0.12	<0.02
31-Mar-2017	0.60	0.79	0.08	<0.02	0.08	<0.02	0.10	0.04	0.10	<0.02	OL	OL	0.09	<0.02	OL	OL	0.07	<0.02
Total number of measurements taken, A:			14		17		19		20		19		20		17		19	
Turbidity Standard for Monitoring Location (NTU):			0.30		0.30		0.30		0.30		0.30		0.30		0.30		0.30	
Number of measurements meeting standard, B:			14		17		19		20		19		20		17		19	
Compliance with Turbidity Standard, C= B/A X 100%:			100%		100%		100%		100%		100%		100%		100%		100%	

NS: No Sample NA: Not Analyzed OL: Off-Line

Comments:
Filter 1 was offline for maintenance March 12-17, 2017.

Report Compiled By: _____ H.Demchenko

Approved in LIMS By: _____ C.Diduck



City of Winnipeg

Water and Waste Department

Water Services

WATER TREATMENT PLANT FREE CHLORINE ON-LINE MONITORING REPORT
Deacon Booster Pumping Station

Water System Code: **252.00**
Licence Number: **PWS-09-412-01**
Report Created: **01 April 2017**

Report Period: March 2017

Date	BRANCH 1 [mg/L]		BRANCH 2 [mg/L]	
	Average	Minimum	Average	Minimum
1/03/2017	1.23	1.17	1.21	1.16
2/03/2017	1.12	1.02	1.13	1.03
3/03/2017	0.99	0.96	1.03	1.01
4/03/2017	1.05	0.96	1.11	1.01
5/03/2017	1.13	1.08	1.19	1.15
6/03/2017	1.22	1.16	1.29	1.26
7/03/2017	1.26	1.18	1.34	1.27
8/03/2017	1.31	1.26	1.39	1.36
9/03/2017	1.19	0.99	1.24	1.05
10/03/2017	1.02	0.97	1.09	1.01
11/03/2017	1.01	0.98	1.07	1.04
12/03/2017	1.04	0.94	1.07	0.98
13/03/2017	1.13	1.08	1.15	1.10
14/03/2017	1.07	0.99	1.09	0.87
15/03/2017	1.03	0.81	1.12	1.02
16/03/2017	1.00	0.94	1.07	1.02
17/03/2017	1.04	0.92	1.03	0.81
18/03/2017	1.00	0.91	1.00	0.89
19/03/2017	0.98	0.90	0.99	0.96
20/03/2017	0.95	0.84	0.99	0.94
21/03/2017	0.97	0.87	1.00	0.95
22/03/2017	0.97	0.90	0.98	0.92
23/03/2017	1.07	0.95	1.09	1.03
24/03/2017	1.02	0.70	1.01	0.71
25/03/2017	1.04	0.91	0.98	0.94
26/03/2017	0.98	0.84	0.97	0.91
27/03/2017	0.95	0.86	0.98	0.92
28/03/2017	0.96	0.88	0.99	0.96
29/03/2017	1.00	0.91	1.01	0.92
30/03/2017	1.02	0.91	1.04	0.99
31/03/2017	1.06	1.01	1.12	1.08

Total Number of Measurements, A: **21566** 21568
Minimum Free Chlorine Standard: **0.5** 0.5
Number of Measurements Meeting Standard, B: **21566** 21568
COMPLIANCE, C = B/A X 100%: **100.00** 100.00

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Chlorine\2017\03-March

Submitted By (Print): D. MerredewSignature: Original Signed by D.Merredew



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENVIRONMENTAL STANDARDS DIVISION

WATER TREATMENT PLANT CHLORINE GRAB MONITORING REPORT

Water System Code: 252.00 Licence No. PWS-09-412-01	Deacon Booster Pumping Station Branch 1			Deacon Booster Pumping Station Branch 2		
	Date	Free Chlorine (mg/L)		Total Chlorine (mg/L)	Free Chlorine (mg/L)	
	Analyser	Grab	Grab	Analyser	Grab	Grab
01-Mar-2017	1.25	1.46	1.61	1.22	1.33	1.50
02-Mar-2017	1.11	1.21	1.48	1.22	1.28	1.52
03-Mar-2017	1.00	1.10	1.25	1.05	1.07	1.29
04-Mar-2017	NS	NS	NS	NS	NS	NS
05-Mar-2017	NS	NS	NS	NS	NS	NS
06-Mar-2017	1.21	1.25	1.46	1.29	1.32	1.61
07-Mar-2017	1.22	1.29	1.46	1.29	1.31	1.53
08-Mar-2017	1.33	1.41	1.60	1.39	1.33	1.66
09-Mar-2017	1.26	1.25	1.43	1.32	1.32	1.51
10-Mar-2017	1.03	1.05	1.22	1.10	0.98	1.27
11-Mar-2017	NS	NS	NS	NS	NS	NS
12-Mar-2017	NS	NS	NS	NS	NS	NS
13-Mar-2017	1.19	1.29	1.43	1.24	1.12	1.46
14-Mar-2017	1.08	1.11	1.25	1.10	1.16	1.31
15-Mar-2017	1.21	1.06	1.25	1.14	1.14	1.30
16-Mar-2017	0.99	1.10	1.28	1.06	1.16	1.30
17-Mar-2017	1.10	1.13	1.28	1.11	1.15	1.33
18-Mar-2017	NS	NS	NS	NS	NS	NS
19-Mar-2017	NS	NS	NS	NS	NS	NS
20-Mar-2017	0.99	1.11	1.31	1.03	1.08	1.26
21-Mar-2017	1.02	1.06	1.25	1.03	1.03	1.27
22-Mar-2017	0.98	1.01	1.23	0.98	1.05	1.22
23-Mar-2017	1.10	1.15	1.30	1.11	1.18	1.34
24-Mar-2017	0.72	0.82	0.97	0.81	0.95	1.14
25-Mar-2017	NS	NS	NS	NS	NS	NS
26-Mar-2017	NS	NS	NS	NS	NS	NS
27-Mar-2017	0.96	1.05	1.24	0.98	0.97	1.25
28-Mar-2017	0.97	1.08	1.22	0.99	1.12	1.27
29-Mar-2017	1.02	1.11	1.31	1.03	1.16	1.31
30-Mar-2017	1.01	1.12	1.27	1.03	1.10	1.29
31-Mar-2017	1.07	1.17	1.37	1.11	1.20	1.35

Total number of measurements taken, A:

Chlorine Standard for Monitoring Location (mg/L):

Number of measurements meeting standard, B:

Compliance with Chlorine Standard, C= B/A X 100%:

NS: No Sample NA: Not Analyzed OL: Off-Line

Comments:

Report Compiled By: _____ H.Demchenko

Approved in LIMS By: _____ C.Diduck



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
WATER SERVICES

Water System Code: 252.00
Licence Number: PWS-09-412-01

Report Period: March 2017

Report Created: Saturday, April 01, 2017

WATER TREATMENT PLANT UV REPORT

Date	Transmittance %	UVR-D100A				UVR-D200A				UVR-D300A				UVR-D400A				UVR-D500A				UVR-D600A				Total				% Volume Treated To Dose	
		Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]					
		Untreated	Below	To	Total	Untreated	Below	To	Total																						
01/03/2017	93.40	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	77.62	77.62	0.00	0.00	0.00	0.00	33.36	33.36	0.00	0.00	61.04	61.04	0.00	0.00	172.02	172.02	100.00	
02/03/2017	93.63	0.00	0.00	0.00	0.00	0.00	0.00	0.00	39.09	39.09	0.01	0.21	33.92	34.14	0.00	0.04	29.00	29.04	0.00	0.00	11.14	11.14	0.00	0.00	58.62	58.62	0.01	0.24	171.76	172.02	99.85
03/03/2017	93.71	0.00	0.00	0.00	0.00	0.00	0.00	0.00	59.74	59.74	0.00	0.00	0.00	0.00	0.00	0.00	55.25	55.25	0.00	0.00	0.00	0.00	0.00	0.00	57.02	57.02	0.00	0.00	172.01	172.01	100.00
04/03/2017	93.57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	56.41	56.41	0.00	0.00	40.02	40.02	0.00	0.00	17.87	17.87	0.00	0.00	0.00	0.00	0.00	0.00	57.72	57.72	0.00	0.00	172.02	172.02	100.00
05/03/2017	93.52	0.00	0.00	0.00	0.00	0.00	0.00	0.00	54.99	54.99	0.00	0.00	58.80	58.80	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	58.20	58.20	0.00	0.00	171.99	171.99	100.00
06/03/2017	93.57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	56.43	56.43	0.00	0.00	59.90	59.90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	59.27	59.27	0.00	0.00	175.60	175.60	100.00
07/03/2017	93.65	0.00	0.00	0.00	0.00	0.00	0.00	0.00	56.98	56.98	0.00	0.00	60.35	60.35	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	59.68	59.68	0.00	0.00	177.02	177.02	100.00
08/03/2017	93.69	0.00	0.00	0.00	0.00	0.00	0.00	0.00	57.00	57.00	0.00	0.00	60.30	60.30	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	59.69	59.69	0.00	0.00	176.99	176.99	100.00
09/03/2017	93.69	0.00	0.00	0.00	0.00	0.00	0.00	0.00	51.10	51.10	0.00	0.00	63.69	63.69	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	62.21	62.21	0.00	0.00	177.00	177.00	100.00
10/03/2017	93.69	0.00	0.00	0.00	0.00	0.00	0.04	0.04	50.09	50.13	0.00	0.00	64.12	64.12	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	62.68	62.68	0.00	0.04	176.89	176.93	99.98
11/03/2017	93.71	0.00	0.00	0.00	0.00	0.00	0.00	0.00	56.70	56.70	0.00	0.00	60.54	60.54	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	59.78	59.78	0.00	0.00	177.02	177.02	100.00
12/03/2017	92.11	0.00	0.00	0.00	0.00	0.00	0.00	0.00	56.78	56.78	0.00	0.00	60.48	60.48	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	59.74	59.74	0.00	0.00	177.01	177.01	100.00
13/03/2017	92.85	0.00	0.00	0.00	0.00	0.00	0.00	0.00	57.06	57.06	0.00	0.00	60.30	60.30	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	59.62	59.62	0.00	0.00	176.98	176.98	100.00
14/03/2017	93.46	0.00	0.00	0.00	0.00	0.00	0.00	0.00	58.01	58.01	0.00	0.00	59.40	59.40	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	58.48	58.48	0.00	0.00	175.89	175.89	100.00
15/03/2017	93.76	0.00	0.00	0.17	0.17	0.00	0.00	0.00	59.04	59.04	0.00	0.00	59.80	59.80	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	59.01	59.01	0.00	0.00	178.02	178.02	100.00
16/03/2017	93.26	0.00	0.00	0.00	0.00	0.00	0.00	0.00	59.69	59.69	0.00	0.00	61.19	61.19	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	60.66	60.66	0.00	0.00	181.54	181.54	100.00
17/03/2017	93.85	0.06	0.06	2.41	2.53	0.01	0.01	66.28	66.31	0.01	0.01	28.48	28.49	0.08	0.08	26.00	26.15	0.00	0.00	0.00	0.00	0.00	0.03	58.97	59.01	0.16	0.19	182.14	182.49	99.81	
18/03/2017	87.91	0.00	0.00	0.00	0.00	0.00	31.59	31.59	0.00	0.00	27.91	27.91	0.00	0.00	51.23	51.23	0.00	0.00	0.00	0.00	0.00	0.00	72.23	72.23	0.00	0.00	182.96	182.96	100.00		
19/03/2017	95.72	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	47.35	47.35	0.00	0.00	52.92	52.92	0.00	0.00	0.00	0.00	0.00	0.00	82.70	82.70	0.00	0.00	182.97	182.97	100.00	
20/03/2017	94.62	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	44.64	44.64	0.00	0.00	49.54	49.54	0.00	0.00	0.00	0.00	0.00	0.00	77.90	77.90	0.00	0.00	172.07	172.07	100.00	
21/03/2017	93.67	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	42.04	42.04	0.00	0.00	46.30	46.30	0.00	0.00	0.00	0.00	0.00	0.00	73.43	73.43	0.00	0.00	161.77	161.77	100.00	
22/03/2017	93.48	0.00	0.00	12.48	12.48	0.00	0.00	0.00	0.00	0.00	0.00	43.06	43.06	0.00	0.00	38.79	38.79	0.00	0.00	0.00	0.00	0.00	0.00	70.59	70.59	0.00	0.00	164.92	164.92	100.00	
23/03/2017	94.01	0.00	0.00	71.95	71.95	0.00	0.00	0.00	0.00	0.00	0.00	47.30	47.30	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	59.98	59.98	0.00	0.00	179.24	179.24	100.00	
24/03/2017	93.50	0.00	0.00	64.31	64.31	0.00	0.00	0.00	0.00	0.00	0.00	40.07	40.07	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	54.94	54.94	0.00	0.00	159.32	159.32	100.00	
25/03/2017	94.10	0.00	0.00	71.33	71.33	0.00	0.00	0.00	0.00	0.00	0.00	48.32	48.32	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	60.36	60.36	0.00	0.00	180.01	180.01	100.00	
26/03/2017	94.71	0.00	0.00	71.61	71.61	0.00	0.00	0.00	0.00	0.00	0.00	48.45	48.45	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	59.92	59.92	0.00	0.00	179.98	179.98	100.00	
27/03/2017	94.78	0.00	0.00	71.59	71.59	0.00	0.00	0.00	0.00	0.00	0.00	48.39	48.39	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	60.01	60.01	0.00	0.00	180.00	180.00	100.00	
28/03/2017	94.82	0.00	0.00	71.59	71.59	0.00	0.00	0.00	0.00	0.00	0.00	48.35	48.35	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	60.07	60.07	0.00	0.00	180.01	180.01	100.00	
29/03/2017	94.94	0.00	0.00	71.54	71.54	0.00	0.00	0.00	0.00	0.00	0.00	48.44	48.44	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	59.15	59.15	0.00	0.00	179.13	179.13	100.00	
30/03/2017	94.97	0.00	0.00	71.82	71.82	0.00	0.00	0.00	0.00	0.00	0.00	48.59	48.59	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	59.62	59.62	0.00	0.00	180.02	180.02	100.00	
31/03/2017	95.11	0.00	0.00	71.82	71.82	0.00	0.00	0.00	0.00	0.00	0.00	48.30	48.30	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	59.87	59.87	0.00	0.00	179.99	179.99	100.00	

Water Volume [%]:

Untreated: 0.0