



Water and Waste Department • Service des eaux et des déchets

Environmental Standards Division • Division des Normes Environnementales

October 6, 2017

Derek Clarke
Office of Drinking Water
Manitoba Sustainable Development
Box 6000
Gimli, Manitoba R0C 1B0

Our File: 040-18-18-55-00

Dear Mr. Clarke:

**RE: SEPTEMBER 2017 WATER QUALITY COMPLIANCE
SUBMISSION FOR THE CITY OF WINNIPEG WATER SUPPLY SYSTEM**

Please find attached on-line and grab turbidity summary reports, on-line and grab chlorine summary reports and the UV summary report for the Water Treatment Plant for September 2017. There are no corrective action reports to be submitted for September 2017.

The September on-line and grab sampling turbidity reports include results obtained for the Water Treatment Plant raw water and the eight filters. Please note that a brief plant shut-down on September 6 caused the maximum turbidities for Filters 2 and 7 to be greater than 0.3 NTU; the elevated turbidities occurred for a short period of time which did not exceed 12 consecutive hours. The turbidity results for the effluent from the filters met the licence requirements.

The September on-line and grab sampling chlorine reports include results obtained for the Deacon Booster Pumping Station at the Water Treatment Plant. The free chlorine results at the Water Treatment Plant met the licence requirements.

The September UV summary report includes results obtained for the six UV reactors at the Water Treatment Plant. The UV disinfection results met the licence requirements.

Please let me know of any concerns or questions respecting this submission. I may be reached by telephone at 204-986-8359 or by e-mail at rgrosselle@winnipeg.ca.

Yours sincerely,

Original signed by:

R. Grosselle
Manager of Environmental Standards

Enclosures

cc: Dr. L. Richards, Winnipeg Regional Health Authority (email)
Dr. H. Chang, Winnipeg Regional Health Authority (email)
Dr. S. Roberecki, Manitoba Health, Seniors and Active Living (email)
M. L. Geer, CPA, CA (email)
G. Patton, P.Eng. (email)
T. Shanks, P.Eng. (email)
M. Szmon, P.Eng. (email)
C. Diduck (email)



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
WATER SERVICES

Water System Code: 252.00
Licence Number: PWS-09-412-01

WATER TREATMENT PLANT TURBIDITY ON-LINE MONITORING REPORT

September 2017 Turbidity (NTU)

Date	Raw		Filter #1		Filter #2		Filter #3		Filter #4		Filter #5		Filter #6		Filter #7		Filter #8	
	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max
1/09/2017	3.79	0.08	0.16	0.06	0.15	0.04	0.06	0.05	0.13	0.04	0.07	0.06	0.13	0.03	0.11	0.01	0.04	
2/09/2017	2.99	0.07	0.15	0.08	0.14	0.04	0.15	0.05	0.13	0.04	0.09	0.05	0.13	0.03	0.04	0.01	0.01	
3/09/2017	2.94	0.06	0.14	0.07	0.15	0.04	0.14	0.05	0.07	0.04	0.10	0.06	0.08	0.04	0.12	0.01	0.05	
4/09/2017	4.24	0.08	0.10	0.07	0.14	0.04	0.05	0.05	0.14	0.05	0.06	0.06	0.14	0.03	0.12	0.01	0.05	
5/09/2017	3.33	0.07	0.16	0.08	0.11	0.04	0.12	0.05	0.14	0.05	0.10	0.06	0.15	0.03	0.05	0.01	0.01	
6/09/2017	2.33	0.06	0.26	0.06	0.32	0.03	0.18	0.05	0.23	0.03	0.13	0.05	0.23	0.03	0.31	0.00	0.15	
7/09/2017	2.73	0.07	0.17	0.09	0.13	0.04	0.10	0.05	0.13	0.05	0.09	0.06	0.14	0.03	0.07	0.01	0.03	
8/09/2017	2.70	0.06	0.13	0.08	0.16	0.04	0.15	0.05	0.09	0.04	0.08	0.05	0.12	0.03	0.04	0.01	0.01	
9/09/2017	3.94	0.04	0.06	0.08	0.14	0.04	0.14	0.06	0.15	0.04	0.08	0.06	0.07	0.03	0.10	0.01	0.02	
10/09/2017	2.33	0.05	0.14	0.07	0.15	0.03	0.06	0.06	0.11	0.04	0.07	0.05	0.12	0.03	0.08	0.01	0.02	
11/09/2017	2.33	0.05	0.12	0.09	0.13	0.05	0.13	0.05	0.12	0.04	0.08	0.01	0.06	0.03	0.10	0.01	0.01	
12/09/2017	2.80	0.04	0.11	0.08	0.17	0.04	0.15	0.06	0.12	0.04	0.09	O/L	O/L	0.03	0.07	0.01	0.04	
13/09/2017	2.34	0.04	0.14	0.08	0.16	0.04	0.14	0.06	0.08	0.03	0.09	O/L	O/L	0.04	0.10	0.01	0.04	
14/09/2017	2.33	0.05	0.07	0.08	0.16	0.04	0.15	0.06	0.13	0.04	0.08	O/L	O/L	0.04	0.11	0.01	0.04	
15/09/2017	2.32	0.06	0.14	0.09	0.17	0.04	0.12	0.06	0.12	0.04	0.06	O/L	O/L	0.03	0.09	0.01	0.02	
16/09/2017	2.31	0.04	0.13	0.08	0.16	0.02	0.06	0.04	0.11	0.04	0.07	O/L	O/L	0.03	0.09	0.01	0.03	
17/09/2017	2.23	0.03	0.10	0.08	0.11	0.02	0.08	0.04	0.09	0.04	0.07	O/L	O/L	0.04	0.10	0.01	0.01	
18/09/2017	2.18	0.03	0.08	0.07	0.13	0.01	0.09	0.04	0.10	0.04	0.06	O/L	O/L	0.04	0.06	0.01	0.01	
19/09/2017	2.20	0.02	0.09	0.07	0.12	0.01	0.03	0.04	0.06	0.04	0.07	O/L	O/L	0.05	0.08	0.01	0.01	
20/09/2017	2.23	0.03	0.05	0.05	0.16	0.00	0.14	0.04	0.09	0.04	0.06	0.05	0.18	0.03	0.13	0.00	0.04	
21/09/2017	2.09	0.02	0.14	0.07	0.10	0.01	0.04	0.02	0.12	0.04	0.08	0.05	0.12	0.03	0.12	0.00	0.02	
22/09/2017	2.20	0.02	0.13	0.09	0.20	0.01	0.13	0.02	0.12	0.03	0.08	0.06	0.10	0.04	0.06	0.01	0.01	
23/09/2017	2.47	0.04	0.07	0.09	0.21	0.03	0.17	0.05	0.09	0.03	0.14	0.10	0.12	0.05	0.15	0.00	0.06	
24/09/2017	2.18	0.09	0.16	0.11	0.18	0.06	0.09	0.06	0.20	0.06	0.13	0.07	0.17	0.04	0.16	0.00	0.06	
25/09/2017	3.06	0.06	0.22	0.12	0.28	0.07	0.21	0.05	0.20	0.05	0.15	0.07	0.11	0.05	0.07	0.01	0.01	
26/09/2017	2.43	0.07	0.10	0.06	0.18	0.05	0.19	0.08	0.11	0.04	0.10	0.10	0.18	0.05	0.10	0.00	0.04	
27/09/2017	2.07	0.05	0.20	0.06	0.10	0.06	0.10	0.06	0.19	0.06	0.14	0.06	0.16	0.03	0.14	0.00	0.01	
28/09/2017	1.93	0.04	0.14	0.05	0.14	0.03	0.14	0.04	0.13	0.03	0.09	0.08	0.11	0.04	0.06	0.01	0.02	
29/09/2017	2.82	0.07	0.09	0.05	0.17	0.03	0.16	0.05	0.09	0.03	0.09	0.10	0.14	0.04	0.10	0.00	0.02	
30/09/2017	1.71	0.07	0.21	0.06	0.10	0.06	0.10	0.07	0.17	0.06	0.14	0.08	0.19	0.04	0.17	0.00	0.05	

Total Number of Measurements Taken, A:

14898

13321

14831

13967

15631

9877

14139

14779

Turbidity Standard for Monitoring Location (NTU):

0.3

0.3

0.3

0.3

0.3

0.3

0.3

0.3

Number of Measurements Meeting Standard, B:

14898

13320

14831

13967

15631

9877

14138

14779

Compliance with Turbidity Standard, C = B/A X 100%:

100.000%

99.992%

100.000%

100.000%

100.000%

100.000%

99.999%

100.000%

O/L = Off Line

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Turbidity\2017\09-September

Submitted By (Print): D.Merredew

Signature: Original signed by D.Merredew



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENVIRONMENTAL STANDARDS DIVISION

WATER TREATMENT PLANT TURBIDITY GRAB MONITORING REPORT

Water System Code: 252.00	Turbidity (NTU)																	
	Raw Water		Filter 1		Filter 2		Filter 3		Filter 4		Filter 5		Filter 6		Filter 7		Filter 8	
Date	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser
01-Sep-2017	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
02-Sep-2017	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
03-Sep-2017	1.85	2.35	0.08	0.05	0.10	0.08	OL	OL	0.09	0.06	0.07	0.04	0.08	0.07	0.09	0.03	0.08	<0.02
04-Sep-2017	1.92	2.40	0.08	0.06	0.08	0.07	0.08	0.03	0.10	0.06	0.09	0.04	0.09	0.08	OL	OL	0.07	<0.02
05-Sep-2017	1.83	2.60	0.13	0.08	0.10	0.08	0.11	0.04	0.10	0.05	0.09	0.04	OL	OL	0.09	0.03	0.09	<0.02
06-Sep-2017	1.62	2.65	0.10	0.08	OL	OL	0.11	0.05	0.12	0.09	0.09	0.06	0.08	0.08	0.08	0.04	0.09	0.02
07-Sep-2017	1.96	2.48	0.12	0.08	0.11	0.09	0.12	0.04	OL	OL	0.09	0.04	0.10	0.08	0.08	0.02	0.08	<0.02
08-Sep-2017	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
09-Sep-2017	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
10-Sep-2017	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
11-Sep-2017	1.52	3.04	OL	OL	0.14	0.09	0.12	0.04	0.09	0.06	0.09	0.03	OL	OL	0.11	0.03	0.09	<0.02
12-Sep-2017	1.63	2.20	OL	OL	0.12	0.10	0.14	0.06	0.11	0.08	0.08	0.04	OL	OL	0.08	0.03	0.09	<0.02
13-Sep-2017	1.39	2.40	0.09	0.03	0.11	0.09	0.13	0.05	0.08	0.05	OL	OL	OL	OL	0.08	0.03	0.08	<0.02
14-Sep-2017	1.58	2.34	0.19	0.04	0.13	0.08	0.12	0.03	0.10	0.06	0.07	0.04	OL	OL	0.08	0.03	OL	OL
15-Sep-2017	1.44	2.26	0.16	0.07	OL	OL	0.14	0.06	0.14	0.10	0.10	0.04	OL	OL	0.11	0.03	0.09	<0.02
16-Sep-2017	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	OL	OL	NS	NS	NS	NS	NS
17-Sep-2017	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	OL	OL	NS	NS	NS	NS	NS
18-Sep-2017	1.33	2.13	0.09	<0.02	0.09	0.08	0.11	<0.02	0.07	0.08	0.08	0.05	OL	OL	0.07	0.04	0.08	<0.02
19-Sep-2017	1.37	1.96	0.09	0.02	0.12	0.08	0.13	0.02	0.07	0.04	OL	OL	OL	OL	0.07	0.04	0.09	<0.02
20-Sep-2017	1.46	2.15	0.10	0.02	OL	OL	0.08	<0.02	0.09	0.06	0.07	0.04	0.08	0.06	0.07	0.04	OL	OL
21-Sep-2017	1.25	1.98	0.08	0.02	0.07	0.09	0.08	<0.02	OL	OL	0.07	0.03	0.11	0.11	0.07	0.04	0.07	<0.02
22-Sep-2017	1.49	1.99	OL	OL	0.10	0.10	0.10	<0.02	OL	OL	0.12	0.06	0.12	0.09	0.09	0.04	0.09	<0.02
23-Sep-2017	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
24-Sep-2017	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
25-Sep-2017	1.45	2.29	OL	OL	0.20	0.09	0.21	0.09	OL	OL	0.17	0.11	0.09	0.11	0.08	0.05	0.09	<0.02
26-Sep-2017	1.15	NR	0.19	0.07	OL	OL	OL	OL	0.21	0.09	0.10	0.06	0.09	0.11	0.15	0.06	0.09	0.12
27-Sep-2017	1.18	2.12	0.18	0.09	0.14	0.07	0.17	0.06	0.11	0.05	0.09	0.03	OL	OL	0.07	0.10	0.10	0.10
28-Sep-2017	1.19	1.72	0.12	0.03	0.13	0.06	0.16	0.05	OL	OL	OL	OL	0.08	0.10	0.07	0.03	0.07	0.10
29-Sep-2017	1.06	NR	0.16	<0.02	OL	OL	OL	OL	0.17	0.07	0.12	0.04	0.09	0.11	0.11	0.04	0.10	0.11
30-Sep-2017	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
Total number of measurements taken, A:			16		15		17		15		17		11		18		18	
Turbidity Standard for Monitoring Location (NTU):			0.30		0.30		0.30		0.30		0.30		0.30		0.30		0.30	
Number of measurements meeting standard, B:			16		15		17		15		17		11		18		18	
Compliance with Turbidity Standard, C= B/A X 100%:			100%		100%		100%		100%		100%		100%		100%		100%	

NS: No Sample NA: Not Analyzed OL: Off-Line

Comments:

There was no result for the raw online analyzer on September 26 and 29 due to maintenance requirements. Filter 6 was offline for maintenance from September 11th to 20th.

Report Compiled By: _____ H.Demchenko _____

Approved in LIMS By: _____ C.Diduck _____



City of Winnipeg

Water and Waste Department

Water Services

WATER TREATMENT PLANT FREE CHLORINE ON-LINE MONITORING REPORT
Deacon Booster Pumping StationWater System Code: **252.00**Licence Number: **PWS-09-412-01**

Report Created: 01 October 2017

Report Period: September 2017

Date	BRANCH 1 [mg/L]		BRANCH 2 [mg/L]	
	Average	Minimum	Average	Minimum
01/09/2017	1.19	1.04	1.31	1.20
02/09/2017	1.23	1.11	1.28	1.16
03/09/2017	1.14	0.88	1.18	1.12
04/09/2017	1.26	1.13	1.19	1.12
05/09/2017	1.21	1.08	1.13	1.03
06/09/2017	0.97	0.85	0.89	0.64
07/09/2017	1.07	0.93	1.09	0.96
08/09/2017	1.24	1.13	1.19	1.09
09/09/2017	1.19	1.07	1.16	1.07
10/09/2017	1.16	1.08	1.13	1.05
11/09/2017	1.12	1.01	1.10	1.05
12/09/2017	1.07	1.01	1.06	0.96
13/09/2017	1.09	0.97	1.06	0.97
14/09/2017	1.07	0.97	1.07	0.97
15/09/2017	1.10	0.92	1.19	1.00
16/09/2017	1.10	0.99	1.19	1.09
17/09/2017	1.14	1.02	1.22	1.10
18/09/2017	1.10	0.92	1.14	1.00
19/09/2017	1.18	1.03	1.18	1.07
20/09/2017	1.21	1.11	1.22	1.15
21/09/2017	1.21	1.05	1.15	1.05
22/09/2017	1.23	1.17	1.16	1.11
23/09/2017	1.14	1.07	1.11	1.04
24/09/2017	1.12	1.04	1.10	1.03
25/09/2017	1.06	0.85	1.10	1.03
26/09/2017	1.07	1.00	1.13	1.07
27/09/2017	1.57	0.94	1.65	1.06
28/09/2017	1.13	0.95	1.19	1.08
29/09/2017	1.10	0.90	1.13	0.98
30/09/2017	1.31	1.16	1.20	1.12

Total Number of Measurements, A: 20849 20846

Minimum Free Chlorine Standard: 0.5 0.5

Number of Measurements Meeting Standard, B: 20849 20846

COMPLIANCE, C = B/A X 100%: 100.00 100.00

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Chlorine\2017\09-September

Submitted By (Print): D.MerredewSignature: Original signed by D.Merredew



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENVIRONMENTAL STANDARDS DIVISION

WATER TREATMENT PLANT CHLORINE GRAB MONITORING REPORT

Water System Code: 252.00	Deacon Booster Pumping Station Branch 1			Deacon Booster Pumping Station Branch 2		
Licence No. PWS-09-412-01						
Date	Free Chlorine (mg/L)		Total Chlorine (mg/L)	Free Chlorine (mg/L)		Total Chlorine (mg/L)
	Analyser	Grab	Grab	Analyser	Grab	Grab
01-Sep-2017	NS	NS	NS	NS	NS	NS
02-Sep-2017	NS	NS	NS	NS	NS	NS
03-Sep-2017	0.97	1.19	1.41	1.20	1.27	1.41
04-Sep-2017	1.25	1.25	1.48	1.20	1.34	1.44
05-Sep-2017	1.23	1.26	1.57	1.11	1.21	1.37
06-Sep-2017	1.12	1.16	1.36	1.05	1.19	1.33
07-Sep-2017	1.02	1.08	1.27	0.99	1.12	1.29
08-Sep-2017	NS	NS	NS	NS	NS	NS
09-Sep-2017	NS	NS	NS	NS	NS	NS
10-Sep-2017	NS	NS	NS	NS	NS	NS
11-Sep-2017	1.16	1.20	1.33	1.12	1.13	1.27
12-Sep-2017	1.10	1.09	1.31	1.04	1.11	1.21
13-Sep-2017	OL	1.18	1.32	1.08	1.11	1.30
14-Sep-2017	1.05	1.12	1.29	1.07	1.12	1.30
15-Sep-2017	1.14	1.19	1.37	1.20	1.25	1.39
16-Sep-2017	NS	NS	NS	NS	NS	NS
17-Sep-2017	NS	NS	NS	NS	NS	NS
18-Sep-2017	1.08	1.18	1.35	1.15	1.16	1.36
19-Sep-2017	1.27	1.31	1.51	1.24	1.25	1.45
20-Sep-2017	1.13	1.27	1.43	1.21	1.27	1.46
21-Sep-2017	1.29	1.21	1.52	1.17	1.16	1.43
22-Sep-2017	1.22	1.30	1.49	1.15	1.21	1.44
23-Sep-2017	NS	NS	NS	NS	NS	NS
24-Sep-2017	NS	NS	NS	NS	NS	NS
25-Sep-2017	1.05	1.15	1.27	1.25	1.23	1.34
26-Sep-2017	1.05	1.17	1.30	1.15	1.24	1.40
27-Sep-2017	0.99	1.10	1.27	1.12	1.18	1.37
28-Sep-2017	1.09	1.14	1.40	1.19	1.22	1.43
29-Sep-2017	1.01	1.09	1.22	1.07	1.20	1.35
30-Sep-2017	NS	NS	NS	NS	NS	NS
Total number of measurements taken, A:		20			20	
Chlorine Standard for Monitoring Location (mg/L):		0.50			0.50	
Number of measurements meeting standard, B:		20			20	
Compliance with Chlorine Standard, C= B/A X 100%:		100%			100%	

NS: No Sample NA: Not Analyzed NR: No Result OL: Off-Line

Comments:

DBPS Branch I analyzer was offline on September 13 due to maintenance requirements.

Report Compiled By: _____ H.Demchenko

Approved in LIMS By: _____ C.Diduck



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
WATER SERVICES

Water System Code: 252.00
Licence Number: PWS-09-412-01

WATER TREATMENT PLANT UV REPORT

Report Period: September 2017

Report Created: Wednesday, October 04, 2017

Date	Transmittance %	UVR-D100A				UVR-D200A				UVR-D300A				UVR-D400A				UVR-D500A				UVR-D600A				Total Water Volume [ML]				% Volume Treated To Dose	
		Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]					
		Untreated	Below	To	Total	Untreated	Below	To	Total																						
01/09/2017	95.17	0.00	0.00	85.05	85.05	0.00	0.00	0.00	0.00	0.00	0.00	57.15	57.15	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	82.89	82.89	0.00	0.00	225.08	225.08	100.00
02/09/2017	95.25	0.00	0.00	84.99	84.99	0.00	0.00	0.00	0.00	0.00	0.00	53.96	53.96	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	80.00	80.00	0.00	0.00	218.96	218.96	100.00
03/09/2017	95.32	0.00	0.00	78.86	78.86	0.00	0.00	0.00	0.00	0.00	0.00	50.34	50.34	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	79.04	79.04	0.00	0.00	208.23	208.23	100.00
04/09/2017	95.27	0.00	0.00	73.42	73.42	0.00	0.00	0.00	0.00	0.00	0.00	47.05	47.05	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	76.07	76.07	0.00	0.00	196.54	196.54	100.00
05/09/2017	95.40	0.00	0.00	72.00	72.00	0.00	0.00	0.00	0.00	0.00	0.00	46.14	46.14	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	74.61	74.61	0.00	0.00	192.76	192.76	100.00
06/09/2017	94.40	0.00	0.00	47.34	47.34	0.00	0.00	0.00	0.00	0.00	0.00	0.80	15.31	16.11	0.01	0.01	14.24	14.26	0.00	0.00	0.00	0.00	0.02	0.02	43.67	43.70	0.02	0.82	120.56	121.41	99.30
07/09/2017	94.97	0.00	0.00	81.10	81.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	54.45	54.45	0.00	0.00	0.00	0.00	0.00	0.00	73.07	73.07	0.00	0.00	208.62	208.62	100.00
08/09/2017	95.38	0.00	0.00	83.19	83.19	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	54.94	54.94	0.00	0.00	0.00	0.00	0.00	0.00	76.23	76.23	0.00	0.00	214.37	214.37	100.00
09/09/2017	95.43	0.00	0.00	82.08	82.08	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	52.92	52.92	0.00	0.00	0.00	0.00	0.00	0.00	79.97	79.97	0.00	0.00	214.97	214.97	100.00
10/09/2017	95.32	0.00	0.00	81.99	81.99	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	52.98	52.98	0.00	0.00	0.00	0.00	0.00	0.00	79.99	79.99	0.00	0.00	214.96	214.96	100.00
11/09/2017	95.11	0.00	0.00	82.11	82.11	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	52.89	52.89	0.00	0.00	0.00	0.00	0.00	0.00	79.97	79.97	0.00	0.00	214.97	214.97	100.00
12/09/2017	95.27	0.00	0.00	77.38	77.38	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	61.77	61.77	0.00	0.00	0.00	0.00	0.00	0.00	77.66	77.66	0.00	0.00	216.81	216.81	100.00
13/09/2017	94.75	0.00	0.34	43.93	44.28	0.00	0.00	4.83	4.83	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.23	72.81	73.04	0.00	0.00	16.93	0.00	0.00	77.44	77.44	0.00	0.57	215.94	216.51	99.74
14/09/2017	94.66	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	82.40	82.40	0.00	0.00	53.43	0.00	0.00	80.89	80.89	0.00	0.00	216.71	216.71	100.00	
15/09/2017	94.03	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	81.03	81.03	0.00	0.00	53.82	0.00	0.00	81.55	81.55	0.00	0.00	216.41	216.41	100.00		
16/09/2017	94.52	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	77.40	77.40	0.00	0.00	50.55	0.00	0.00	78.85	78.85	0.00	0.00	206.80	206.80	100.00		
17/09/2017	94.80	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	68.36	68.36	0.00	0.11	41.81	0.00	0.00	77.16	77.16	0.00	0.11	187.33	187.44	99.94		
18/09/2017	95.02	0.00	0.00	30.06	30.06	0.00	0.00	10.53	10.53	0.00	0.00	0.57	0.00	0.00	0.00	52.99	52.99	0.25	0.25	22.65	0.00	0.00	71.27	71.27	0.25	0.82	187.50	188.58	99.43		
19/09/2017	95.35	0.00	0.00	72.77	72.77	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	45.50	45.50	0.00	0.00	0.00	0.00	0.00	0.00	71.71	71.71	0.00	0.00	189.98	189.98	100.00	
20/09/2017	95.33	0.00	0.00	72.73	72.73	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	45.50	45.50	0.00	0.00	0.00	0.00	0.00	0.00	71.75	71.75	0.00	0.00	189.99	189.99	100.00	
21/09/2017	95.36	0.00	0.00	72.77	72.77	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	45.64	45.64	0.00	0.00	0.00	0.00	0.00	0.00	71.61	71.61	0.00	0.00	190.03	190.03	100.00	
22/09/2017	95.16	0.00	0.00	72.78	72.78	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	45.65	45.65	0.00	0.00	0.00	0.00	0.00	0.00	71.56	71.56	0.00	0.00	189.99	189.99	100.00	
23/09/2017	94.74	0.00	0.00	71.66	71.66	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	44.97	44.97	0.00	0.00	0.00	0.00	0.00	0.00	69.75	69.75	0.00	0.00	186.38	186.38	100.00	
24/09/2017	94.13	0.00	0.00	70.92	70.92	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	44.54	44.54	0.00	0.00	0.00	0.00	0.00	0.00	69.52	69.52	0.00	0.00	184.98	184.98	100.00	
25/09/2017	94.21	0.00	0.64	23.66	24.29	0.00	0.00	47.01	47.01	0.00	0.00	0.00	0.00	0.00	0.00	44.03	44.03	0.00	0.00	1.26	0.00	0.00	68.39	68.39	0.00	0.64	184.35	184.99	99.65		
26/09/2017	94.29	0.00	0.00	0.00	0.00	0.00	0.00	75.17	75.17	0.00	0.00	0.00	0.00	0.00	0.00	42.64	42.64	0.00	0.00	0.00	0.00	0.00	0.00	67.22	67.22	0.00	0.00	185.03	185.03	100.00	
27/09/2017	94.17	0.00	0.00	23.82	23.82	0.00	0.00	50.12	50.12	0.00	0.00	0.00	0.00	0.00	0.00	43.47	43.47	0.00	0.00	45.11	0.00	0.00	23.25	0.00	0.00	185.76	185.77	100.00			
28/09/2017	94.66	0.00	0.00	59.23	59.23	0.00	0.00	39.72	39.72	0.00	0.00	0.00	0.00	0.00	0.00	62.97	62.97	0.00	0.00	27.62	0.00	0.00	0.00	0.00	0.00	0.00	189.54	189.54	100.00		
29/09/2017	94.40	0.00	0.00	57.69	57.69	0.00	0.00	45.49	45.49	0.00	0.00	0.00	0.00	0.00	0.00	65.96	65.96	0.00	0.00	21.81	0.00	0.00	0.00	0.00	0.00	0.00	190.95	190.95	100.00		
30/09/2017	93.66	0.00	0.00	73.33	73.33	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	45.77	45.77	0.00	0.00	71.89	0.00	0.00	0.00	0.00	0.00	0.00	190.98	190.98	100.00		

Water Volume [%]:

Untreated: 0.00 %

Below Dose: 0.05 %

To Dose: 99.95 %

Submitted By (Print): D. Minor

Signature: Original signed by D. Minor