



**Water and Waste Department • Service des eaux et des déchets**

*Environmental Standards Division • Division des Normes Environnementales*

---

April 6, 2018

Derek Clarke  
Office of Drinking Water  
Manitoba Sustainable Development  
Box 6000  
Gimli, Manitoba R0C 1B0

Our File: 040-18-18-55-00

Dear Mr. Clarke:

**RE: MARCH 2018 WATER QUALITY COMPLIANCE  
SUBMISSION FOR THE CITY OF WINNIPEG WATER SUPPLY SYSTEM**

Please find attached on-line and grab turbidity summary reports, on-line and grab chlorine summary reports and the UV summary report for the Water Treatment Plant for March 2018. We have also included one corrective action report for a positive total coliform in the distribution system.

The March on-line and grab sampling turbidity reports include results obtained for the Water Treatment Plant raw water and the eight filters. Please note that the maximum turbidity for Filter 3 was greater than 0.3 NTU on March 8; the elevated turbidity occurred for a short period of time which did not exceed 12 consecutive hours. The turbidity results for the effluent from the filters met the licence requirements.

The March on-line and grab sampling chlorine reports include results obtained for the Deacon Booster Pumping Station at the Water Treatment Plant. The free chlorine results at the Water Treatment Plant met the licence requirements.

On March 13, a positive total coliform result was reported for a routine sample at the WC04 location. On March 14 and 16, the location was resampled and results were reported negative. Our resampling also indicated that the chlorine levels at the location were normal and provided adequate disinfection. Please see the attached corrective action report for additional details.

The March UV summary report includes results obtained for the six UV reactors at the Water Treatment Plant. The UV disinfection results met the licence requirements.

Please let me know of any concerns or questions respecting this submission. I may be reached by telephone at 204-986-8359 or by e-mail at [rgrosselle@winnipeg.ca](mailto:rgrosselle@winnipeg.ca).

Yours sincerely,

*Original signed by M. Marsland for:*

R. Grosselle  
Manager of Environmental Standards

Enclosures

cc: Dr. L. Richards, Winnipeg Regional Health Authority (email)  
Dr. H. Chang, Winnipeg Regional Health Authority (email)  
Dr. S. Roberecki, Manitoba Health, Seniors and Active Living (email)  
M. L. Geer, CPA, CA (email)  
G. Patton, P.Eng. (email)  
T. Shanks, P.Eng. (email)  
M. Szmon, P.Eng. (email)  
C. Diduck (email)



**CITY OF WINNIPEG**  
WATER AND WASTE DEPARTMENT  
WATER SERVICES

Water System Code: 252.00  
Licence Number: PWS-09-412-01

**WATER TREATMENT PLANT TURBIDITY ON-LINE MONITORING REPORT**

March 2018 Turbidity (NTU)

	Raw	Filter #1		Filter #2		Filter #3		Filter #4		Filter #5		Filter #6		Filter #7		Filter #8	
Date	Avg	Avg	Max														
1/03/2018	0.63	0.03	0.08	0.05	0.08	0.03	0.12	0.03	0.11	0.03	0.05	0.04	0.10	0.05	0.09	0.01	0.01
2/03/2018	0.63	0.02	0.07	0.07	0.14	0.04	0.06	0.02	0.05	0.02	0.07	0.04	0.12	0.04	0.10	0.01	0.06
3/03/2018	0.62	0.03	0.05	0.05	0.12	0.03	0.10	0.03	0.11	0.02	0.07	0.03	0.05	0.03	0.10	0.01	0.06
4/03/2018	0.63	0.03	0.06	0.05	0.13	0.04	0.15	0.03	0.10	0.01	0.03	0.04	0.13	0.04	0.07	0.01	0.06
5/03/2018	0.61	0.03	0.13	0.05	0.08	0.05	0.23	0.03	0.10	0.02	0.05	0.03	0.10	0.03	0.08	0.01	0.03
6/03/2018	0.60	0.02	0.06	0.05	0.11	0.04	0.20	0.03	0.05	0.01	0.06	0.02	0.10	0.02	0.07	0.01	0.05
7/03/2018	0.58	0.03	0.07	0.05	0.12	0.04	0.18	0.03	0.09	0.02	0.07	0.05	0.08	0.03	0.06	0.01	0.07
8/03/2018	0.56	0.03	0.16	0.05	0.14	0.06	0.32	0.03	0.11	0.03	0.06	0.05	0.13	0.05	0.09	0.01	0.03
9/03/2018	0.55	0.02	0.06	0.05	0.09	0.03	0.09	0.02	0.08	0.02	0.05	0.03	0.10	0.03	0.09	0.01	0.08
10/03/2018	0.53	0.04	0.11	0.08	0.14	0.08	0.11	0.04	0.07	0.03	0.10	0.05	0.15	0.05	0.13	0.03	0.10
11/03/2018	0.52	0.04	0.07	0.05	0.14	0.05	0.13	0.04	0.12	0.02	0.07	0.05	0.07	0.03	0.05	0.02	0.09
12/03/2018	0.50	0.03	0.08	0.05	0.08	0.04	0.12	0.03	0.10	0.03	0.05	0.04	0.13	0.05	0.10	0.02	0.03
13/03/2018	0.49	0.02	0.04	0.06	0.14	0.05	0.07	0.03	0.05	0.02	0.07	0.03	0.12	0.03	0.10	0.03	0.09
14/03/2018	0.46	0.04	0.07	0.05	0.14	0.05	0.12	0.03	0.11	0.01	0.04	0.05	0.07	0.03	0.05	0.02	0.10
15/03/2018	0.46	0.03	0.09	0.05	0.08	0.04	0.13	0.03	0.11	0.03	0.06	0.04	0.10	0.04	0.09	0.03	0.05
16/03/2018	0.46	0.03	0.05	0.07	0.14	0.07	0.10	0.03	0.06	0.02	0.06	0.03	0.11	0.03	0.09	0.03	0.09
17/03/2018	0.46	0.05	0.09	0.05	0.14	0.05	0.13	0.04	0.11	0.02	0.07	0.05	0.11	0.03	0.05	0.03	0.10
18/03/2018	0.46	0.04	0.10	0.05	0.08	0.05	0.14	0.03	0.13	0.03	0.06	0.04	0.11	0.04	0.10	0.04	0.06
19/03/2018	0.47	0.03	0.06	0.08	0.15	0.06	0.10	0.03	0.06	0.02	0.07	0.03	0.11	0.03	0.10	0.05	0.11
20/03/2018	0.46	0.06	0.10	0.05	0.14	0.05	0.13	0.04	0.11	0.02	0.07	0.05	0.07	0.03	0.05	0.04	0.11
21/03/2018	0.47	0.04	0.10	0.06	0.08	0.04	0.14	0.03	0.12	0.03	0.06	0.04	0.12	0.04	0.10	0.05	0.07
22/03/2018	0.47	0.04	0.06	0.07	0.14	0.07	0.10	0.04	0.07	0.02	0.07	0.03	0.11	0.03	0.09	0.05	0.11
23/03/2018	0.52	0.05	0.11	0.05	0.14	0.04	0.14	0.03	0.11	0.02	0.07	0.06	0.08	0.03	0.05	0.05	0.12
24/03/2018	0.53	0.04	0.09	0.05	0.13	0.04	0.12	0.03	0.08	0.03	0.06	0.05	0.13	0.05	0.10	0.06	0.09
25/03/2018	0.53	0.04	0.10	0.07	0.10	0.05	0.07	0.03	0.10	0.02	0.08	0.05	0.14	0.04	0.11	0.07	0.13
26/03/2018	0.53	0.05	0.07	0.05	0.13	0.06	0.14	0.04	0.09	0.02	0.07	0.05	0.13	0.04	0.11	0.06	0.14
27/03/2018	0.55	0.05	0.10	0.05	0.11	0.05	0.12	0.03	0.09	0.01	0.03	0.07	0.13	0.05	0.07	0.05	0.13
28/03/2018	0.57	0.05	0.11	0.07	0.09	0.05	0.08	0.03	0.12	0.03	0.08	0.06	0.15	0.05	0.12	0.10	0.13
29/03/2018	0.60	0.06	0.08	0.06	0.15	0.07	0.15	0.05	0.07	0.03	0.11	0.05	0.16	0.04	0.12	0.07	0.16
30/03/2018	0.61	0.07	0.13	0.05	0.15	0.05	0.15	0.04	0.11	0.03	0.04	0.09	0.14	0.06	0.08	0.06	0.16
31/03/2018	0.62	0.04	0.13	0.07	0.08	0.05	0.07	0.02	0.11	0.03	0.09	0.05	0.16	0.04	0.11	0.10	0.16

Total Number of Measurements Taken, A: 14036      11213      14305      11545      14771      13168      13120      14556  
Turbidity Standard for Monitoring Location (NTU): 0.3      0.3      0.3      0.3      0.3      0.3      0.3      0.3  
Number of Measurements Meeting Standard, B: 14036      11213      14302      11545      14771      13168      13120      14556  
Compliance with Turbidity Standard, C = B/A X 100%: 100.000%      100.000%      99.979%      100.000%      100.000%      100.000%      100.000%      100.000%

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Turbidity\2018\03-March

Submitted By (Print): D.Merredew

Signature: Original signed by D.Merredew



CITY OF WINNIPEG  
WATER AND WASTE DEPARTMENT  
ENVIRONMENTAL STANDARDS DIVISION

**WATER TREATMENT PLANT TURBIDITY GRAB MONITORING REPORT**

Water System Code: 252.00	Turbidity (NTU)																	
	Raw Water		Filter 1		Filter 2		Filter 3		Filter 4		Filter 5		Filter 6		Filter 7		Filter 8	
Date	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser
01-Mar-2018	0.43	0.62	0.12	0.05	0.08	0.07	OL	OL	OL	OL	0.09	0.02	0.12	0.08	0.12	0.05	0.10	<0.02
02-Mar-2018	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
03-Mar-2018	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
04-Mar-2018	0.48	0.61	0.12	0.03	OL	OL	OL	OL	0.14	0.05	0.10	<0.02	0.11	0.05	0.10	0.03	0.09	<0.02
05-Mar-2018	0.53	0.61	OL	OL	0.09	0.06	0.16	0.10	OL	OL	0.12	0.02	0.13	0.07	0.10	0.03	0.10	<0.02
06-Mar-2018	0.47	0.59	0.07	0.02	0.09	0.07	0.09	0.04	0.08	0.03	OL	OL	0.08	0.05	OL	OL	0.09	0.03
07-Mar-2018	0.47	0.55	0.08	<0.02	0.13	0.11	0.10	0.05	0.10	0.04	0.08	<0.02	0.09	0.06	0.08	0.03	OL	OL
08-Mar-2018	0.45	0.53	0.10	0.04	OL	OL	OL	OL	0.15	0.09	0.09	0.02	0.12	0.07	0.11	0.04	0.09	0.03
09-Mar-2018	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
10-Mar-2018	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
11-Mar-2018	0.45	0.50	0.08	0.02	0.13	0.11	0.13	0.07	0.11	0.05	OL	OL	0.10	0.06	0.10	0.03	OL	OL
12-Mar-2018	0.40	0.50	0.10	0.05	0.07	0.07	OL	OL	OL	OL	0.08	0.02	0.10	0.06	0.09	0.04	0.08	0.04
13-Mar-2018	0.41	0.48	0.07	0.02	0.08	0.07	0.08	0.05	0.08	0.03	0.11	0.04	OL	OL	OL	OL	0.10	0.06
14-Mar-2018	0.42	0.45	0.09	0.03	OL	OL	0.12	0.08	0.12	0.06	0.07	<0.02	0.09	0.05	0.08	0.03	OL	OL
15-Mar-2018	0.38	0.44	OL	OL	0.08	0.07	0.08	0.05	OL	OL	0.09	0.03	0.12	0.07	0.10	0.04	0.09	0.05
16-Mar-2018	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
17-Mar-2018	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
18-Mar-2018	0.44	0.47	0.13	0.07	0.11	0.08	OL	OL	OL	OL	0.11	0.03	0.11	0.07	0.09	0.04	0.08	0.07
19-Mar-2018	0.45	0.46	0.10	0.03	0.13	0.08	0.09	0.06	0.08	0.04	0.10	0.02	OL	OL	OL	OL	0.09	0.07
20-Mar-2018	0.39	0.44	0.10	0.04	0.17	0.13	0.12	0.07	0.11	0.06	0.08	<0.02	0.10	0.05	0.09	0.03	OL	OL
21-Mar-2018	0.40	0.49	0.14	0.08	0.09	0.07	OL	OL	OL	OL	0.10	0.02	0.11	0.07	0.10	0.04	0.10	0.08
22-Mar-2018	0.43	0.45	0.08	0.04	0.09	0.08	0.10	0.06	0.09	0.04	0.12	0.03	OL	OL	OL	OL	0.11	0.09
23-Mar-2018	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
24-Mar-2018	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
25-Mar-2018	0.47	0.50	OL	OL	0.09	0.07	0.09	0.06	0.09	0.04	0.10	0.03	OL	OL	0.13	0.07	0.11	0.11
26-Mar-2018	0.44	0.54	0.09	0.04	0.09	0.08	0.10	0.06	0.10	0.04	OL	OL	0.10	0.06	OL	OL	0.11	0.13
27-Mar-2018	0.44	0.51	0.08	0.04	OL	OL	0.12	0.09	0.10	0.05	0.09	<0.02	0.10	0.07	0.09	0.03	OL	OL
28-Mar-2018	0.45	0.55	OL	OL	0.08	0.08	0.09	0.07	OL	OL	0.10	0.03	0.15	0.12	0.11	0.06	0.09	0.11
29-Mar-2018	0.45	0.57	0.10	0.05	0.10	0.09	0.11	0.07	0.10	0.05	OL	OL	0.10	0.08	OL	OL	0.12	0.13
30-Mar-2018	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
31-Mar-2018	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
<b>Total number of measurements taken, A:</b>			17		17		15		14		17		17		15		16	
<b>Turbidity Standard for Monitoring Location (NTU):</b>			0.30		0.30		0.30		0.30		0.30		0.30		0.30		0.30	
<b>Number of measurements meeting standard, B:</b>			17		17		15		14		17		17		15		16	
<b>Compliance with Turbidity Standard, C= B/A X 100%:</b>			100%		100%		100%		100%		100%		100%		100%		100%	

NS: No Sample NA: Not Analyzed OL: Off-Line

Comments:

Report Compiled By: \_\_\_\_\_ H.Demchenko \_\_\_\_\_

Approved in LIMS By: \_\_\_\_\_ C.Diduck \_\_\_\_\_



**WATER TREATMENT PLANT FREE CHLORINE ON-LINE MONITORING REPORT**  
Deacon Booster Pumping Station

Water System Code: **252.00**

Licence Number: **PWS-09-412-01**

Report Created: 01 April 2018

Report Period: March 2018

Date	BRANCH 1 [mg/L]		BRANCH 2 [mg/L]	
	Average	Minimum	Average	Minimum
01/03/2018	OL	OL	1.09	1.06
02/03/2018	OL	OL	1.09	1.06
03/03/2018	OL	OL	1.06	0.96
04/03/2018	OL	OL	1.07	1.05
05/03/2018	OL	OL	1.12	1.07
06/03/2018	OL	OL	1.08	0.85
07/03/2018	OL	OL	1.22	1.10
08/03/2018	OL	OL	1.15	1.09
09/03/2018	1.00	0.92	1.09	0.97
10/03/2018	1.02	0.95	0.97	0.94
11/03/2018	1.03	0.99	0.99	0.93
12/03/2018	1.04	0.99	1.08	1.06
13/03/2018	1.04	0.98	1.13	1.07
14/03/2018	1.02	0.98	1.13	1.11
15/03/2018	1.16	0.98	1.19	1.13
16/03/2018	1.24	1.18	1.22	1.17
17/03/2018	1.24	1.14	1.20	1.17
18/03/2018	1.16	1.11	1.14	1.10
19/03/2018	1.14	0.88	1.11	1.02
20/03/2018	0.99	0.81	1.08	1.03
21/03/2018	1.04	0.92	1.09	1.05
22/03/2018	1.02	0.91	1.10	1.06
23/03/2018	0.93	0.83	1.06	0.91
24/03/2018	0.89	0.81	0.99	0.89
25/03/2018	0.92	0.85	1.03	0.93
26/03/2018	1.02	0.89	1.15	1.01
27/03/2018	1.01	0.87	1.10	0.97
28/03/2018	1.01	0.92	0.99	0.93
29/03/2018	1.00	0.92	1.01	0.91
30/03/2018	0.93	0.84	1.02	0.92
31/03/2018	0.99	0.92	1.06	0.99

Total Number of Measurements, A: 15591 21565

Minimum Free Chlorine Standard: 0.5 0.5

Number of Measurements Meeting Standard, B: 15591 21565

COMPLIANCE, C = B/A X 100%: 100.00 100.00  
Off-line OL

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Chlorine\2018\03-March

Submitted By (Print): D. Merredew

Signature: Original signed by D.Merredew



CITY OF WINNIPEG  
WATER AND WASTE DEPARTMENT  
ENVIRONMENTAL STANDARDS DIVISION

**WATER TREATMENT PLANT CHLORINE GRAB MONITORING REPORT**

Water System Code: 252.00 Licence No. PWS-09-412-01	Deacon Booster Pumping Station Branch 1			Deacon Booster Pumping Station Branch 2		
	Date	Free Chlorine (mg/L)	Total Chlorine (mg/L)	Free Chlorine (mg/L)	Total Chlorine (mg/L)	
	Analyser	Grab	Grab	Analyser	Grab	Grab
01-Mar-2018	OL	OL	OL	1.11	1.17	1.32
02-Mar-2018	NA	NA	NA	NA	NA	NA
03-Mar-2018	NA	NA	NA	NA	NA	NA
04-Mar-2018	OL	OL	OL	1.07	1.09	1.27
05-Mar-2018	OL	OL	OL	1.13	1.15	1.33
06-Mar-2018	OL	OL	OL	1.05	1.17	1.30
07-Mar-2018	OL	OL	OL	1.29	1.15	1.35
08-Mar-2018	OL	OL	OL	1.21	1.23	1.42
09-Mar-2018	0.97	1.14	1.28	NA	NA	NA
10-Mar-2018	0.96	0.97	1.25	NA	NA	NA
11-Mar-2018	1.02	1.05	1.24	0.95	1.05	1.24
12-Mar-2018	1.04	1.10	1.27	1.08	1.10	1.30
13-Mar-2018	1.04	1.08	1.27	1.09	1.15	1.39
14-Mar-2018	1.03	1.07	1.23	1.14	1.17	1.31
15-Mar-2018	1.16	1.20	1.39	1.16	1.16	1.31
16-Mar-2018	NA	NA	NA	NA	NA	NA
17-Mar-2018	NA	NA	NA	NA	NA	NA
18-Mar-2018	1.15	1.18	1.40	1.12	1.16	1.32
19-Mar-2018	1.22	1.22	1.41	1.11	1.14	1.27
20-Mar-2018	1.05	1.01	1.21	1.13	1.05	1.23
21-Mar-2018	1.05	1.04	1.23	1.10	1.05	1.21
22-Mar-2018	1.04	1.06	1.18	1.09	1.14	1.29
23-Mar-2018	NA	NA	NA	NA	NA	NA
24-Mar-2018	NA	NA	NA	NA	NA	NA
25-Mar-2018	0.92	0.99	1.11	1.02	1.03	1.25
26-Mar-2018	1.04	1.10	1.27	1.18	1.17	1.34
27-Mar-2018	1.01	1.11	1.30	1.07	1.18	1.32
28-Mar-2018	1.06	1.03	1.22	0.99	1.11	1.28
29-Mar-2018	0.98	1.00	1.17	1.04	1.07	1.26
30-Mar-2018	NA	NA	NA	NA	NA	NA
31-Mar-2018	NA	NA	NA	NA	NA	NA
<b>Total number of measurements taken, A:</b>		17			21	
<b>Chlorine Standard for Monitoring Location (mg/L):</b>		0.50			0.50	
<b>Number of measurements meeting standard, B:</b>		17			21	
<b>Compliance with Chlorine Standard, C= B/A X 100%:</b>		100%			100%	

NS: No Sample    NA: Not Analyzed    OL: Off-Line

Comments:

Branch 1 offline March 1 to 9 to facilitate maintenance work.

Report Compiled By: H.Demchenko

Approved in LIMS By: C.Diduck



**CITY OF WINNIPEG**  
WATER AND WASTE DEPARTMENT  
WATER SERVICES

Water System Code: 252.00  
Licence Number: PWS-09-412-01

**WATER TREATMENT PLANT UV REPORT**

Report Period: March 2018

Report Created: Sunday, April 01, 2018

Date	Transmittance %	UVR-D100A				UVR-D200A				UVR-D300A				UVR-D400A				UVR-D500A				UVR-D600A				Total Water Volume [ML]				% Volume Treated To Dose	
		Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]					
		Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	To	Total																		
01/03/2018	95.16	0.00	0.00	0.00	0.00	0.00	0.00	70.50	70.50	0.00	0.00	0.00	0.00	0.00	0.00	52.83	52.83	0.00	0.00	0.00	0.00	0.00	0.00	76.68	76.68	0.00	0.00	200.01	200.01	100.00	
02/03/2018	95.23	0.00	0.00	0.00	0.00	0.00	0.00	70.61	70.61	0.00	0.00	0.00	0.00	0.00	0.00	52.58	52.58	0.00	0.00	0.00	0.00	0.00	0.00	76.80	76.80	0.00	0.00	199.99	199.99	100.00	
03/03/2018	95.28	0.00	0.00	0.00	0.00	0.00	0.00	70.67	70.67	0.00	0.00	0.00	0.00	0.00	0.00	52.55	52.55	0.00	0.00	0.00	0.00	0.00	0.00	76.77	76.77	0.00	0.00	199.99	199.99	100.00	
04/03/2018	95.11	0.00	0.00	0.00	0.00	0.00	0.00	70.66	70.66	0.00	0.00	0.00	0.00	0.00	0.00	52.57	52.57	0.00	0.00	0.00	0.00	0.00	0.00	76.78	76.78	0.00	0.00	200.01	200.01	100.00	
05/03/2018	95.25	0.00	0.00	0.00	0.00	0.00	0.00	70.65	70.65	0.00	0.00	0.00	0.00	0.00	0.00	52.56	52.56	0.00	0.00	0.00	0.00	0.00	0.00	76.79	76.79	0.00	0.00	200.00	200.00	100.00	
06/03/2018	95.34	0.00	0.00	0.00	0.00	0.00	0.00	64.34	64.34	0.00	0.00	0.00	0.00	0.00	0.00	51.67	51.67	0.00	0.00	0.00	0.00	0.00	0.00	68.26	68.26	0.00	0.00	184.28	184.28	100.00	
07/03/2018	95.01	0.00	0.00	0.00	0.00	0.00	0.00	70.66	70.66	0.00	0.00	0.00	0.00	0.00	0.00	52.42	52.42	0.00	0.00	0.00	0.00	0.00	0.00	76.89	76.89	0.00	0.00	199.96	199.96	100.00	
08/03/2018	94.76	0.00	0.00	0.00	0.00	0.00	0.00	72.01	72.01	0.00	0.00	0.00	0.00	0.00	0.00	52.87	52.87	0.00	0.00	0.00	0.00	0.00	0.00	74.86	74.86	0.00	0.00	199.73	199.73	100.00	
09/03/2018	94.78	0.00	0.00	0.00	0.00	0.00	0.00	73.89	73.89	0.00	0.00	0.00	0.00	0.12	0.12	28.40	28.64	0.00	0.00	20.16	20.16	0.00	0.00	75.67	75.67	0.12	0.12	198.11	198.35	99.88	
10/03/2018	93.93	0.00	0.00	0.00	0.00	0.00	0.00	75.01	75.01	0.00	0.00	0.00	0.00	0.00	0.00	39.00	39.99	0.00	0.00	72.38	72.38	0.00	0.00	187.38	187.38	100.00					
11/03/2018	94.52	0.00	0.00	0.00	0.00	0.00	0.00	72.89	72.89	0.00	0.00	0.00	0.00	0.00	0.00	35.67	35.67	0.00	0.00	64.42	64.42	0.00	0.00	172.98	172.98	100.00					
12/03/2018	94.57	0.00	0.00	0.00	0.00	0.00	0.00	65.01	65.01	0.00	0.00	0.00	0.00	0.00	0.00	0.75	37.74	38.49	0.00	0.00	69.53	69.53	0.00	0.00	172.28	173.03	99.56				
13/03/2018	94.63	0.00	0.00	0.00	0.00	0.00	0.00	56.15	56.15	0.00	0.00	0.00	0.00	0.00	0.00	35.25	35.25	0.00	3.61	11.41	15.02	0.00	0.00	66.53	66.53	0.00	3.61	169.34	172.95	97.91	
14/03/2018	94.46	0.00	0.00	0.00	0.00	0.00	0.00	53.70	53.70	0.00	0.00	0.00	0.00	0.00	0.00	56.25	56.25	0.00	0.00	0.00	0.00	0.00	0.00	63.03	63.03	0.00	0.00	172.98	172.98	100.00	
15/03/2018	94.19	0.00	0.00	0.00	0.00	0.00	0.00	16.60	16.60	0.00	0.00	30.10	30.10	0.00	0.00	52.58	52.58	0.00	0.00	0.00	0.00	0.00	0.00	73.68	73.68	0.00	0.00	172.97	172.97	100.00	
16/03/2018	93.96	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	45.23	45.23	0.00	0.00	50.10	50.10	0.00	0.00	0.00	0.00	0.00	0.00	78.63	78.63	0.00	0.00	173.96	173.96	100.00	
17/03/2018	93.79	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	46.81	46.81	0.00	0.00	51.11	51.11	0.00	0.00	0.00	0.00	0.00	0.00	80.09	80.09	0.00	0.00	178.01	178.01	100.00		
18/03/2018	93.74	0.00	0.00	0.00	0.00	0.00	0.00	0.00	47.10	47.10	0.00	0.00	51.00	51.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	79.92	79.92	0.00	0.00	178.02	178.02	100.00		
19/03/2018	93.66	0.00	0.19	3.50	3.69	0.00	0.04	15.06	15.10	0.36	0.36	55.47	56.18	0.00	0.00	17.16	17.16	0.00	0.46	14.04	14.50	0.00	0.00	71.28	71.28	0.36	1.05	176.51	177.91	99.21	
20/03/2018	93.57	0.04	0.04	22.62	22.69	0.00	0.00	56.54	56.54	0.00	0.00	21.88	21.88	0.00	0.00	0.00	0.00	0.00	0.00	20.62	20.62	0.00	0.00	59.37	59.37	0.04	0.04	181.03	181.10	99.96	
21/03/2018	93.98	0.00	0.00	23.20	23.20	0.00	0.00	76.58	76.58	0.00	0.00	0.00	0.00	0.24	0.24	0.00	0.48	0.00	0.00	20.63	20.63	0.00	0.00	69.27	69.27	0.24	0.24	189.68	190.16	99.75	
22/03/2018	94.92	0.00	0.00	52.07	52.07	0.00	0.00	65.98	65.98	0.00	0.00	0.00	0.00	0.03	0.24	0.59	0.85	0.00	0.00	0.00	0.00	0.00	0.00	71.12	71.12	0.03	0.24	189.76	190.02	99.86	
23/03/2018	95.04	0.00	0.00	19.37	19.37	0.00	0.00	74.92	74.92	0.00	0.00	0.00	0.00	0.00	0.09	33.21	33.30	0.00	0.00	0.00	0.00	0.00	0.00	62.45	62.45	0.00	0.09	189.95	190.03	99.95	
24/03/2018	95.10	0.00	0.00	0.07	0.07	0.00	0.00	80.57	80.57	0.00	0.00	0.00	0.00	0.00	0.00	51.19	51.19	0.00	0.00	0.00	0.00	0.00	0.00	58.17	58.17	0.00	0.00	190.00	190.00	100.00	
25/03/2018	95.00	0.00	0.00	0.00	0.00	0.00	0.00	80.57	80.57	0.00	0.00	0.00	0.00	0.00	0.00	51.17	51.17	0.00	0.00	0.00	0.00	0.00	0.00	58.28	58.28	0.00	0.00	190.02	190.02	100.00	
26/03/2018	95.02	0.00	0.00	0.00	0.00	0.00	0.00	80.28	80.28	0.00	0.00	0.00	0.00	0.00	0.00	50.84	50.84	0.00	0.00	0.00	0.00	0.00	0.00	58.00	58.00	0.00	0.00	189.12	189.12	100.00	
27/03/2018	95.12	0.00	0.00	0.00	0.00	0.00	0.00	80.16	80.16	0.00	0.00	0.00	0.00	0.00	0.00	50.68	50.68	0.00	0.00	0.00	0.00	0.00	0.00	57.66	57.66	0.00	0.00	188.50	188.50	100.00	
28/03/2018	94.75	0.00	0.00	0.00	0.00	0.00	0.00	79.96	79.96	0.00	0.00	0.00	0.00	0.00	0.00	50.58	50.58	0.00	0.00	0.00	0.00	0.00	0.00	57.44	57.44	0.00	0.00	187.98	187.98	100.00	
29/03/2018	94.77	0.00	0.00	0.00	0.00	0.00	0.00	80.07	80.07	0.00	0.00	0.00	0.00	0.00	0.00	50.55	50.55	0.00	0.00	0.00	0.00	0.00	0.00	57.35	57.35	0.00	0.00	187.96	187.96	100.00	
30/03/2018	94.79	0.00	0.00	0.00	0.00	0.00	0.00	75.18	75.18	0.00	0.00	0.00	0.00	0.00	0.00	48.15	48.15	0.00	0.00	0.00	0.00	0.00	0.00	53.05	53.05	0.00	0.00	176.39	176.39	100.00	
31/03/2018	95.05	0.00	0.00	0.00	0.00	0.00	0.00	73.39	73.39	0.00	0.00	0.00	0.00	0.00	0.00	47.37	47.37	0.00	0.00	0.00	0.00	0.00	0.00	51.92	51.92	0.00	0.00	172.68	172.68	100.00	

Water Volume [%]:

Untreated: 0.01 %

Below Dose: 0.11 %

To Dose: 99.88 %

Submitted By: D.Merredew

Signature: Original Signed by D.Merredew



Water and Waste Department • Service des eaux et des déchets

Wednesday, April 4, 2018

**Our Incident/Report No: 01-2018**

LIMS Reference No: 52231

Incident Date: **March 13, 2018**

Mr. Derek Clarke  
Drinking Water Officer  
Manitoba Sustainable Development, Office of Drinking Water  
Box 6000  
Gimli, MB R0C 1B0

**RE: CORRECTIVE ACTION REPORT**

---

<b>WATER SYSTEM, CODE</b>	Winnipeg Public Water System, 252.00
<b>LOCATION OF NON-COMPLIANT INCIDENT</b>	<b>Winnipeg 3-Dist WC04</b>
<b>INCIDENT REPORTED BY</b>	Courtney Diduck, Analytical Services Branch Head
<b>TYPE OF NON-COMPLIANT INCIDENT</b>	Low positive Total Coliform (<10 per100mL), 3 MR 41/2007
<b>DESCRIPTION OF CORRECTIVE ACTIONS</b>	<u>Environmental Standards:</u> AS SOON AS POSSIBLE: Re-sampled original location until two consecutive negative results were reported. Also tested for turbidity, free/total chlorine, temperature and contacted the ODW.
<b>TEST RESULTS</b>	See Attached

NOTES/COMMENTS:

1. UP/DOWN STREAM testing performed when EC is >0 /100mL, TC is >10 /100mL or when resample/consecutive sample is positive for EC or TC or as directed by the Manager of Environmental Standards Division and/or the Office of Drinking Water

**EMERGENCY REPORTING IS REQUIRED WHERE A POTENTIAL HEALTH RISK IS INVOLVED. FOLLOW THE INSTRUCTIONS OF YOUR DRINKING WATER OFFICER ON SITUATIONS REQUIRING IMMEDIATE REPORTING**

N:\Environmental Standards\Analytical Services\Government Agencies\Office of Drinking Water\Corrective Action Reports



Water and Waste Department • Service des eaux et des déchets

Sample Name	Sample Number	Date Sampled	bacColiEsch-QT (MPNU/100mL)	bacColiTotal-QT (MPNU/100mL)	bacHPC (cfu/mL)	Chlorine, Free (mg/L)	Chlorine, Total (mg/L)	Turbidity-field (ntu)	Temperature (°C)	Time Sampled (hrs)
WC04	542102	13-Mar-18	<1	1	<1	0.70	1.00	0.12	5.4	10:49
WC04_Resample	542718	14-Mar-18	<1	<1	<1	0.85	1.04	0.14	5.7	15:03
WC04_Resample Duplicate	542719	14-Mar-18	<1	<1	NA	NA	NA	NA	NA	NA
WC04_Resample 2	542900	16-Mar-18	<1	<1	1	0.81	0.96	0.12	5.7	10:36
WC04_Resample Duplicate 2	542901	16-Mar-18	<1	<1	<1	NA	NA	NA	NA	NA

NOTES/COMMENTS:

1. All microbiological tests performed by contract laboratory.
2. N/R-No Result due to laboratory/analyst error.
3. N/A-Not Analyzed.