



## Water and Waste Eaux et déchets

Derek Clarke, Drinking Water Officer  
Office of Drinking Water, Manitoba Sustainable Development  
Box 6000  
Gimli, MB R0C 1B0

**May 7, 2019**

### **RE: APRIL 2019 WATER QUALITY COMPLIANCE SUBMISSION FOR THE CITY OF WINNIPEG WATER SUPPLY SYSTEM**

Please find attached on-line and grab turbidity summary reports, on-line and grab chlorine summary reports and the UV summary report for the Water Treatment Plant for April 2019.

The April on-line and grab sampling turbidity reports include results obtained for the Water Treatment Plant raw water and the eight filters. Please note that the maximum turbidity for Filter 2 on April 4 was 5.00 ntu, this was a reading of the calibration cuvette, not the filter effluent; please see CAR\_01-2019, submitted on May 6, 2019, for additional details. The turbidity results for the effluent from the filters met the licence requirements.

The April on-line and grab sampling chlorine reports include results obtained for the Deacon Booster Pumping Station at the Water Treatment Plant. The free chlorine results at the Water Treatment Plant met the licence requirements.

The April UV summary report includes results obtained for the six UV reactors at the Water Treatment Plant. The UV disinfection results met the licence requirements.

Please let me know of any concerns or questions respecting this submission. I may be reached by telephone at 204-986-8359 or by e-mail at rgrosselle@winnipeg.ca.

Yours sincerely,

Original signed by:

R. Grosselle  
Manager of Environmental Standards

Enclosures

cc: Dr. L. Richards, Winnipeg Regional Health Authority (email)  
Dr. H. Chang, Winnipeg Regional Health Authority (email)  
Dr. S. Roberecki, Manitoba Health, Seniors and Active Living (email)  
M. L. Geer, CPA, CA (email)  
G. Patton, P.Eng. (email)  
T. Shanks, P.Eng. (email)  
M. Szmon, P.Eng. (email)  
C. Diduck (email)



**CITY OF WINNIPEG**  
WATER AND WASTE DEPARTMENT  
WATER SERVICES

Water System Code: 252.00  
Licence Number: PWS-09-412-01

**WATER TREATMENT PLANT TURBIDITY ON-LINE MONITORING REPORT**

April 2019 Turbidity (NTU)

	Raw	Filter #1		Filter #2		Filter #3		Filter #4		Filter #5		Filter #6		Filter #7		Filter #8	
Date	Avg	Avg	Max														
1/04/2019	0.28	0.03	0.09	0.05	0.11	0.05	0.14	0.05	0.13	0.05	0.09	0.03	0.10	0.02	0.03	0.01	0.01
2/04/2019	0.32	0.03	0.08	0.06	5.00	0.05	0.08	0.04	0.10	0.04	0.09	0.03	0.08	0.04	0.06	0.01	0.03
3/04/2019	0.37	0.03	0.09	0.06	0.10	0.05	0.13	0.02	0.11	0.04	0.10	0.05	0.12	0.03	0.08	0.00	0.01
4/04/2019	0.40	0.04	0.06	0.07	0.13	0.04	0.13	0.04	0.09	0.04	0.10	0.04	0.12	0.03	0.09	0.00	0.01
5/04/2019	0.42	0.04	0.10	0.06	0.14	0.04	0.14	0.03	0.11	0.06	0.09	0.04	0.12	0.03	0.06	0.01	0.01
6/04/2019	0.47	0.03	0.10	0.05	0.13	0.05	0.07	0.03	0.11	0.04	0.11	0.03	0.06	0.05	0.09	0.01	0.02
7/04/2019	0.50	0.02	0.09	0.09	0.10	0.05	0.13	0.13	0.06	0.04	0.11	0.06	0.13	0.04	0.10	0.00	0.02
8/04/2019	0.52	0.04	0.06	0.06	0.13	0.04	0.13	0.04	0.10	0.04	0.07	0.04	0.12	0.04	0.09	0.00	0.02
9/04/2019	0.54	0.03	0.09	0.05	0.13	0.04	0.07	0.03	0.09	0.05	0.11	0.04	0.12	0.04	0.07	0.01	0.01
10/04/2019	0.56	0.03	0.09	0.05	0.08	0.06	0.12	0.02	0.09	0.04	0.11	0.05	0.08	0.04	0.09	0.00	0.03
11/04/2019	0.57	0.03	0.05	0.07	0.13	0.04	0.13	0.04	0.07	0.03	0.10	0.04	0.11	0.04	0.09	0.00	0.01
12/04/2019	0.58	0.04	0.09	0.05	0.12	0.04	0.12	0.03	0.10	0.05	0.08	0.04	0.11	0.03	0.09	0.01	0.01
13/04/2019	0.60	0.03	0.08	0.05	0.12	0.04	0.06	0.02	0.08	0.04	0.10	0.03	0.11	0.05	0.07	0.01	0.02
14/04/2019	0.62	0.03	0.08	0.06	0.08	0.05	0.11	0.02	0.08	0.04	0.09	0.05	0.08	0.04	0.08	0.00	0.02
15/04/2019	0.62	0.03	0.05	0.07	0.11	0.04	0.11	0.04	0.07	0.03	0.10	0.04	0.10	0.04	0.09	0.00	0.03
16/04/2019	0.62	0.04	0.09	0.04	0.12	0.04	0.12	0.03	0.09	0.06	0.09	0.03	0.11	0.04	0.06	0.01	0.01
17/04/2019	0.85	0.02	0.11	0.03	0.23	0.05	0.28	0.02	0.23	0.01	0.05	0.03	0.07	0.04	0.09	0.02	0.10
18/04/2019	0.62	0.03	0.06	0.03	0.08	0.05	0.13	0.04	0.09	0.00	0.01	0.04	0.11	0.04	0.09	0.04	0.11
19/04/2019	0.62	0.04	0.10	0.03	0.09	0.05	0.13	0.03	0.10	0.01	0.01	0.03	0.10	0.04	0.23	0.04	0.07
20/04/2019	0.61	0.03	0.08	0.02	0.08	0.04	0.07	0.03	0.08	0.01	0.02	0.03	0.10	0.05	0.07	0.05	0.11
21/04/2019	0.59	0.03	0.09	0.02	0.05	0.06	0.14	0.02	0.08	0.00	0.02	0.04	0.06	0.04	0.09	0.04	0.10
22/04/2019	0.59	0.03	0.05	0.03	0.07	0.05	0.12	0.03	0.05	0.00	0.02	0.04	0.09	0.04	0.08	0.04	0.10
23/04/2019	0.59	0.04	0.09	0.02	0.07	0.04	0.13	0.03	0.08	0.01	0.01	0.03	0.10	0.03	0.09	0.04	0.06
24/04/2019	0.59	0.02	0.07	0.02	0.06	0.05	0.07	0.02	0.08	0.00	0.02	0.03	0.04	0.05	0.07	0.04	0.10
25/04/2019	0.60	0.02	0.04	0.02	0.05	0.05	0.12	0.02	0.05	0.00	0.03	0.04	0.09	0.03	0.11	0.03	0.11
26/04/2019	0.61	0.03	0.07	0.02	0.06	0.04	0.11	0.02	0.08	0.01	0.01	0.02	0.07	0.03	0.07	0.03	0.05
27/04/2019	0.59	0.02	0.07	0.02	0.06	0.05	0.07	0.02	0.08	0.00	0.02	0.02	0.04	0.05	0.06	0.04	0.08
28/04/2019	0.59	0.02	0.06	0.02	0.04	0.06	0.11	0.02	0.04	0.00	0.02	0.03	0.06	0.03	0.08	0.03	0.08
29/04/2019	0.61	0.03	0.05	0.02	0.06	0.05	0.11	0.03	0.07	0.00	0.01	0.02	0.07	0.03	0.08	0.03	0.08
30/04/2019	0.61	0.03	0.07	0.02	0.06	0.04	0.12	0.02	0.08	0.01	0.02	0.02	0.07	0.04	0.05	0.04	0.05

Total Number of Measurements Taken, A: 13510 10566 13505 11325 14148 12724 12646 14052  
Turbidity Standard for Monitoring Location (NTU): 0.3 0.3 0.3 0.3 0.3 0.3 0.3 0.3  
Number of Measurements Meeting Standard, B: 13510 10565 13505 11325 14148 12724 12646 14052  
Compliance with Turbidity Standard, C = B/A X 100%: 100.000% 99.991% 100.000% 100.000% 100.000% 100.000% 100.000% 100.000%

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Turbidity\2019\04-April

Submitted By (Print): D.Merredew

Signature: Original signed by D.Merredew



CITY OF WINNIPEG  
WATER AND WASTE DEPARTMENT  
ENVIRONMENTAL STANDARDS DIVISION

WATER TREATMENT PLANT TURBIDITY GRAB MONITORING REPORT																		
Water System Code: 252.00		Turbidity (NTU)																
Date	Raw Water		Filter 1		Filter 2		Filter 3		Filter 4		Filter 5		Filter 6		Filter 7		Filter 8	
	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser
01-Apr-2019	0.40	0.26	0.10	0.03	OL	OL	0.11	0.06	0.15	0.09	0.10	0.04	OL	OL	0.11	0.02	0.11	<0.02
02-Apr-2019	0.37	0.28	OL	OL	0.09	0.07	0.11	0.06	OL	OL	0.11	0.06	0.09	0.05	0.09	0.02	0.10	<0.02
03-Apr-2019	0.38	0.34	0.07	0.02	0.08	0.07	0.11	0.06	0.08	0.03	OL	OL	0.08	0.06	0.10	0.06	OL	OL
04-Apr-2019	0.40	0.36	0.09	0.03	0.10	0.09	OL	OL	0.11	0.05	0.08	0.04	0.13	0.09	OL	OL	0.08	<0.02
05-Apr-2019	NR	0.37	NR	0.04	OL	OL	NR	0.05	NR	0.08	NR	0.05	OL	OL	NR	0.04	NR	<0.02
06-Apr-2019	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
07-Apr-2019	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
08-Apr-2019	NR	0.50	NR	0.03	NR	0.09	NR	OL	NR	0.04	NR	0.04	NR	0.10	OL	OL	NR	<0.02
09-Apr-2019	0.42	0.50	0.11	0.05	OL	OL	0.10	0.05	OL	OL	0.10	0.06	0.09	0.05	0.09	0.04	0.10	<0.02
10-Apr-2019	0.48	0.54	OL	OL	0.08	0.08	0.10	0.06	0.08	0.03	OL	OL	0.10	0.06	0.10	0.06	0.13	0.03
11-Apr-2019	0.55	0.53	0.08	0.03	0.09	0.09	OL	OL	0.09	0.04	0.07	0.04	0.11	0.07	OL	OL	0.07	<0.02
12-Apr-2019	0.53	0.56	0.09	0.03	OL	OL	0.11	0.05	0.12	0.06	0.08	0.05	OL	OL	0.08	0.03	0.09	<0.02
13-Apr-2019	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
14-Apr-2019	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
15-Apr-2019	0.60	0.60	0.09	0.03	0.09	0.09	OL	OL	0.10	0.05	0.08	0.04	0.11	0.07	OL	OL	0.08	<0.02
16-Apr-2019	0.56	0.61	0.10	0.03	OL	OL	0.09	0.05	0.12	0.06	0.16	0.05	OL	OL	0.12	0.04	0.09	<0.02
17-Apr-2019	0.56	0.60	OL	OL	0.08	0.03	0.09	0.05	0.08	0.02	OL	OL	0.09	0.04	0.09	0.04	0.09	<0.02
18-Apr-2019	0.53	0.60	0.12	0.02	0.10	0.04	0.16	0.10	0.12	0.04	0.09	<0.02	0.12	0.07	0.13	0.07	0.13	0.04
19-Apr-2019	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
20-Apr-2019	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
21-Apr-2019	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
22-Apr-2019	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
23-Apr-2019	0.58	0.56	0.08	0.03	0.10	0.05	OL	OL	0.11	0.04	0.09	<0.02	0.16	0.07	0.07	0.03	0.08	0.04
24-Apr-2019	0.51	0.56	OL	OL	0.07	0.03	0.10	0.06	OL	OL	0.10	0.02	0.08	0.04	0.10	0.04	0.09	0.04
25-Apr-2019	0.56	0.56	0.10	<0.02	0.08	0.03	0.10	0.07	0.08	0.03	0.09	<0.02	0.11	0.06	OL	OL	OL	OL
26-Apr-2019	0.56	0.59	0.08	0.03	OL	OL	0.08	0.06	0.10	0.04	0.07	<0.02	OL	OL	0.06	0.03	0.07	0.03
27-Apr-2019	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
28-Apr-2019	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
29-Apr-2019	0.52	0.59	0.08	0.02	0.09	0.03	OL	OL	0.09	0.03	0.08	<0.02	0.09	0.05	OL	OL	0.08	0.03
30-Apr-2019	0.50	0.60	0.09	0.02	OL	OL	0.09	0.06	0.12	0.06	0.08	0.02	OL	OL	0.08	0.04	0.07	0.03
Total number of measurements taken, A:			14		12		13		15		15		13		13		16	
Turbidity Standard for Monitoring Location (NTU):			0.30		0.30		0.30		0.30		0.30		0.30		0.30		0.30	
Number of measurements meeting standard, B:			14		12		13		15		15		13		13		16	
Compliance with Turbidity Standard, C= B/A X 100%:			100%		100%		100%		100%		100%		100%		100%		100%	

NS: No Sample    NA: Not Analyzed    OL: Off-Line

**Comments:**

No result on April 5 and 8, 2019 due to sample bottle contamination.

Report Compiled By: H.Demchenko

Authorized By: C.Diduck

Date Compiled: 6-May-19



**City Of Winnipeg**

Water and Waste Department

Water Services

**WATER TREATMENT PLANT FREE CHLORINE ON-LINE MONITORING REPORT**  
Deacon Booster Pumping Station

Water System Code: **252.00**

Licence Number: **PWS-09-412-01**

Report Created: 01 May 2019

Report Period: April 2019

Date	BRANCH 1 [mg/L]		BRANCH 2 [mg/L]	
	Average	Minimum	Average	Minimum
01/04/2019	1.07	0.93	1.11	1.05
02/04/2019	1.15	0.91	1.17	1.05
03/04/2019	1.22	1.13	1.23	1.14
04/04/2019	1.19	1.08	1.16	1.08
05/04/2019	1.14	1.04	1.12	1.09
06/04/2019	1.11	1.03	1.09	1.04
07/04/2019	1.11	1.01	1.14	1.08
08/04/2019	1.12	1.00	1.15	1.08
09/04/2019	1.11	1.02	1.14	1.11
10/04/2019	1.08	0.99	1.10	1.03
11/04/2019	1.06	0.95	1.09	1.04
12/04/2019	1.02	0.93	1.08	1.05
13/04/2019	0.99	0.90	1.04	0.94
14/04/2019	0.93	0.79	0.94	0.85
15/04/2019	0.94	0.86	0.92	0.90
16/04/2019	0.99	0.82	1.06	0.91
17/04/2019	1.26	0.97	1.41	1.16
18/04/2019	1.11	0.89	1.27	0.99
19/04/2019	1.13	0.99	1.04	0.99
20/04/2019	1.18	1.07	1.11	1.02
21/04/2019	1.14	1.02	1.10	1.06
22/04/2019	1.09	0.99	1.04	0.95
23/04/2019	1.08	0.94	1.06	0.98
24/04/2019	1.13	0.90	1.11	1.03
25/04/2019	1.19	1.04	1.04	0.96
26/04/2019	1.34	0.95	1.60	0.74
27/04/2019	1.24	1.08	1.25	1.03
28/04/2019	1.12	0.98	1.02	0.86
29/04/2019	1.18	1.02	1.06	0.60
30/04/2019	1.21	1.07	1.17	1.02

Total Number of Measurements, A: 20838 20837

Minimum Free Chlorine Standard: 0.5 0.5

Number of Measurements Meeting Standard, B: 20838 20837

COMPLIANCE, C = B/A X 100%: 100.00 100.00

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Chlorine\2019\04-April

Submitted By (Print): D.Merredew

Signature: Original signed by D.Merredew



CITY OF WINNIPEG  
WATER AND WASTE DEPARTMENT  
ENVIRONMENTAL STANDARDS DIVISION

**WATER TREATMENT PLANT CHLORINE GRAB MONITORING REPORT**

Water System Code: 252.00	Deacon Booster Pumping Station Branch 1			Deacon Booster Pumping Station Branch 2		
Licence No. PWS-09-412-01	Date	Free Chlorine (mg/L)	Total Chlorine (mg/L)	Free Chlorine (mg/L)	Total Chlorine (mg/L)	
		Analyser	Grab	Analyser	Grab	
	01-Apr-2019	1.03	0.98	1.23	1.09	1.17
	02-Apr-2019	1.03	1.09	1.25	1.07	1.12
	03-Apr-2019	1.14	1.20	1.27	1.18	1.15
	04-Apr-2019	1.18	1.25	1.39	1.13	1.24
	05-Apr-2019	1.15	1.14	1.36	1.12	1.17
	06-Apr-2019	NA	NA	NA	NA	NA
	07-Apr-2019	NA	NA	NA	NA	NA
	08-Apr-2019	1.10	1.04	1.30	1.10	1.22
	09-Apr-2019	1.13	1.08	1.28	1.16	1.21
	10-Apr-2019	1.11	1.09	1.24	1.13	1.09
	11-Apr-2019	1.05	1.05	1.17	1.11	1.15
	12-Apr-2019	1.04	1.01	1.16	1.06	1.09
	13-Apr-2019	NA	NA	NA	NA	NA
	14-Apr-2019	NA	NA	NA	NA	NA
	15-Apr-2019	0.95	0.95	1.04	0.93	0.96
	16-Apr-2019	0.93	0.99	1.14	0.98	1.01
	17-Apr-2019	1.52	1.61	1.71	1.79	1.77
	18-Apr-2019	0.93	1.00	1.10	1.08	1.09
	19-Apr-2019	NA	NA	NA	NA	NA
	20-Apr-2019	NA	NA	NA	NA	NA
	21-Apr-2019	NA	NA	NA	NA	NA
	22-Apr-2019	NA	NA	NA	NA	NA
	23-Apr-2019	1.07	1.04	1.23	1.06	1.03
	24-Apr-2019	1.03	1.07	1.11	1.11	1.06
	25-Apr-2019	1.21	1.16	1.37	1.03	1.06
	26-Apr-2019	1.21	1.21	1.35	1.05	1.13
	27-Apr-2019	NA	NA	NA	NA	NA
	28-Apr-2019	NA	NA	NA	NA	NA
	29-Apr-2019	1.11	1.17	1.38	0.96	1.13
	30-Apr-2019	1.26	1.13	1.39	1.22	1.10
<b>Total number of measurements taken, A:</b>		20			20	
<b>Chlorine Standard for Monitoring Location (mg/L):</b>		0.50			0.50	
<b>Number of measurements meeting standard, B:</b>		20			20	
<b>Compliance with Chlorine Standard, C= B/A X 100%:</b>		100%			100%	

NS: No Sample    NA: Not Analyzed    OL: Off-Line

Comments:

Report Compiled By: \_\_\_\_\_ H.Demchenko

Authorized By: \_\_\_\_\_ C.Diduck

Date Compiled: \_\_\_\_\_ 2-May-19



**CITY OF WINNIPEG**  
WATER AND WASTE DEPARTMENT  
WATER SERVICES

Water System Code: 252.00  
Licence Number: PWS-09-412-01

WATER TREATMENT PLANT UV REPORT

Report Period: April 2019

Report Created: Wednesday, May 01, 2019

Date	Transmittance %	UVR-D100A				UVR-D200A				UVR-D300A				UVR-D400A				UVR-D500A				UVR-D600A				Total				% Volume Treated To Dose
		Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				
		Untreated	Below	To	Total	Untreated	Below	To	Total																					
01/04/2019	94.66	0.00	0.00	30.96	30.96	0.00	0.00	45.12	45.12	0.00	0.73	0.83	1.55	0.00	0.00	30.41	30.41	0.00	0.00	21.14	21.14	0.00	0.00	65.77	65.77	0.00	0.73	194.23	194.95	99.63
02/04/2019	94.59	0.00	0.00	68.71	68.71	0.00	0.00	0.00	0.00	0.01	0.28	31.54	31.83	0.00	0.05	5.67	5.72	0.00	0.00	54.54	54.54	0.00	0.00	40.48	40.48	0.01	0.33	200.94	201.28	99.83
03/04/2019	94.49	0.00	0.00	64.31	64.31	0.00	0.00	0.00	0.00	0.00	0.05	34.71	34.75	0.00	0.00	34.53	34.53	0.00	0.00	67.77	67.77	0.00	0.00	0.00	0.00	0.00	0.05	201.32	201.37	99.98
04/04/2019	94.39	0.00	0.00	63.99	63.99	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	66.26	66.26	0.00	0.00	64.49	64.49	0.00	0.00	0.00	0.00	0.00	0.00	194.74	194.74	100.00
05/04/2019	94.42	0.00	0.00	62.19	62.19	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	64.62	64.62	0.00	0.00	63.23	63.23	0.00	0.00	0.00	0.00	0.00	0.00	190.05	190.05	100.00
06/04/2019	94.39	0.00	0.00	61.03	61.03	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	64.31	64.31	0.00	0.00	60.44	60.44	0.00	0.00	0.00	0.00	0.00	0.00	185.78	185.78	100.00
07/04/2019	94.42	0.00	0.00	60.35	60.35	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	63.75	63.75	0.00	0.04	8.71	8.75	0.00	0.00	51.17	51.17	0.00	0.04	183.98	184.02	99.98
08/04/2019	94.43	0.00	0.00	59.25	59.25	0.00	0.00	0.00	0.00	0.00	0.00	18.88	18.88	0.04	0.04	44.79	44.88	0.00	0.00	0.00	0.00	1.34	1.34	58.79	61.47	1.38	1.38	181.71	184.48	98.50
09/04/2019	94.50	0.00	0.00	60.36	60.36	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	64.00	64.00	0.00	0.00	0.00	0.00	0.00	0.00	59.63	59.63	0.00	0.00	183.99	183.99	100.00
10/04/2019	94.65	0.00	0.00	60.49	60.49	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	63.88	63.88	0.00	0.00	0.00	0.00	0.00	0.00	59.95	59.95	0.00	0.00	184.31	184.31	100.00
11/04/2019	94.85	0.00	0.00	60.93	60.93	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	64.05	64.05	0.00	0.00	0.04	0.04	0.00	0.00	60.23	60.23	0.00	0.00	185.24	185.24	100.00
12/04/2019	94.75	0.00	0.00	61.22	61.22	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	64.23	64.23	0.00	0.00	0.00	0.00	0.00	0.00	60.54	60.54	0.00	0.00	185.99	185.99	100.00
13/04/2019	94.62	0.00	0.00	59.98	59.98	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	63.54	63.54	0.00	0.00	0.00	0.00	0.00	0.00	59.66	59.66	0.00	0.00	183.17	183.17	100.00
14/04/2019	94.40	0.00	0.00	59.73	59.73	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	63.41	63.41	0.00	0.00	0.00	0.00	0.00	0.00	59.87	59.87	0.00	0.00	183.01	183.01	100.00
15/04/2019	93.91	0.00	0.00	61.77	61.77	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	65.29	65.29	0.00	0.00	0.00	0.00	0.00	0.00	61.37	61.37	0.00	0.00	188.42	188.42	100.00
16/04/2019	93.32	0.00	0.00	61.65	61.65	0.00	0.00	0.00	0.00	0.00	0.00	28.75	28.75	0.00	0.00	38.00	38.00	0.01	0.01	27.87	27.89	0.00	0.00	36.72	36.72	0.01	0.01	193.00	193.02	99.99
17/04/2019	92.14	0.01	0.01	43.98	44.00	0.00	0.00	0.00	0.00	0.01	0.01	47.12	47.14	0.02	0.02	0.30	0.33	0.19	0.19	51.61	52.00	0.09	0.09	0.11	0.30	0.33	0.33	143.11	143.77	99.54
18/04/2019	92.32	0.00	0.00	61.11	61.11	0.00	0.00	0.00	0.00	0.00	0.00	40.07	40.07	0.09	0.12	32.91	33.11	0.00	0.00	50.69	50.69	0.00	0.04	30.92	30.96	0.09	0.15	215.70	215.93	99.89
19/04/2019	91.59	0.00	0.00	78.32	78.32	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	53.61	53.61	0.00	0.00	0.00	0.00	0.00	0.00	76.30	76.30	0.00	0.00	208.23	208.23	100.00
20/04/2019	90.94	0.00	0.00	69.16	69.16	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	55.71	55.71	0.00	0.00	0.00	0.00	0.00	0.00	68.91	68.91	0.00	0.00	193.77	193.77	100.00
21/04/2019	90.72	0.00	0.00	62.00	62.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	65.21	65.21	0.00	0.00	0.00	0.00	0.00	0.00	61.21	61.21	0.00	0.00	188.42	188.42	100.00
22/04/2019	99.94	0.00	0.00	65.81	65.81	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.06	53.65	53.71	0.00	0.00	0.00	0.00	0.00	0.00	67.93	67.93	0.00	0.06	187.38	187.44	99.97
23/04/2019	97.59	0.00	0.05	64.61	64.66	0.00	0.00	0.00	0.00	0.00	0.00	22.15	22.15	0.00	0.00	33.03	33.03	0.00	0.00	0.00	0.00	0.00	0.00	68.16	68.16	0.00	0.05	187.95	187.99	99.98
24/04/2019	95.72	0.00	0.00	35.44	35.44	0.00	0.00	30.04	30.04	0.00	0.00	0.00	0.00	0.00	0.00	60.85	60.85	0.00	0.00	34.05	34.05	0.00	0.00	27.63	27.63	0.00	0.00	188.02	188.02	100.00
25/04/2019	95.68	0.00	0.00	0.00	0.00	0.00	0.00	75.08	75.08	0.00	0.00	0.00	0.00	0.00	0.00	57.21	57.21	0.00	0.00	60.30	60.30	0.00	0.00	0.00	0.00	0.00	0.00	192.60	192.60	100.00
26/04/2019	96.09	0.00	0.00	0.00	0.00	0.00	0.00	79.44	79.44	0.00	0.00	0.00	0.00	0.00	0.00	53.11	53.11	0.00	0.00	60.37	60.37	0.00	0.00	0.00	0.00	0.00	0.00	192.92	192.92	100.00
27/04/2019	96.17	0.00	0.00	0.00	0.00	0.00	0.00	78.78	78.78	0.00	0.00	0.00	0.00	0.00	0.00	52.69	52.69	0.00	0.00	60.07	60.07	0.00	0.00	0.00	0.00	0.00	0.00	191.54	191.54	100.00
28/04/2019	96.18	0.00	0.00	0.00	0.00	0.00	0.00	80.70	80.70	0.00	0.00	0.00	0.00	0.00	0.00	53.85	53.85	0.00	0.00	61.45	61.45	0.00	0.00	0.00	0.00	0.00	0.00	196.01	196.01	100.00
29/04/2019	96.11	0.00	0.00	0.00	0.00	0.00	0.00	80.72	80.72	0.00	0.00	0.00	0.00	0.00	0.00	53.83	53.83	0.00	0.00	61.46	61.46	0.00	0.00	0.00	0.00	0.00	0.00	196.01	196.01	100.00
30/04/2019	96.11	0.00	0.00	0.00	0.00	0.00	0.00	81.14	81.14	0.00	0.00	0.00	0.00	0.00	0.00	54.09	54.09	0.00	0.00	61.83	61.83	0.00	0.00	0.00	0.00	0.00	0.00	197.05	197.05	100.00

Water Volume [%]:

Untreated: 0.03 %

Below Dose: 0.05 %

To Dose: 99.91 %

Submitted By (Print): D.Merredew

Signature: Original signed by D.Merredew