



Derek Clarke, Drinking Water Officer
Office of Drinking Water, Manitoba Sustainable Development
Box 6000
Gimli, MB R0C 1B0

July 5, 2019

RE: JUNE 2019 WATER QUALITY COMPLIANCE SUBMISSION FOR THE CITY OF WINNIPEG WATER SUPPLY SYSTEM

Please find attached on-line and grab turbidity summary reports, on-line and grab chlorine summary reports and the UV summary report for the Water Treatment Plant for June 2019.

The June on-line and grab sampling turbidity reports include results obtained for the Water Treatment Plant raw water and the eight filters. The turbidity results for the filter effluent met the licence requirements.

The June on-line and grab sampling chlorine reports include results obtained for the Deacon Booster Pumping Station at the Water Treatment Plant. The free chlorine results at the Water Treatment Plant met the licence requirements.

The June UV summary report includes results obtained for the six UV reactors at the Water Treatment Plant. The UV disinfection results met the licence requirements.

Please let me know of any concerns or questions respecting this submission. I can be reached by telephone at 204-986-8359 or by e-mail at rgrosselle@winnipeg.ca.

Yours sincerely,

Original signed by:

R. Grosselle
Manager of Environmental Standards

Enclosures

cc: Dr. L. Richards, Winnipeg Regional Health Authority (email)
Dr. H. Chang, Winnipeg Regional Health Authority (email)
Dr. S. Roberecki, Manitoba Health, Seniors and Active Living (email)
M. L. Geer, CPA, CA (email)
G. Patton, P.Eng. (email)
T. Shanks, P.Eng. (email)
M. Szmon, P.Eng. (email)
C. Diduck (email)



CITY OF WINNIPEG
 WATER AND WASTE DEPARTMENT
 WATER SERVICES

Water System Code: 252.00
 Licence Number: PWS-09-412-01

WATER TREATMENT PLANT TURBIDITY ON-LINE MONITORING REPORT

June 2019 Turbidity (NTU)

Date	Raw	Filter #1		Filter #2		Filter #3		Filter #4		Filter #5		Filter #6		Filter #7		Filter #8	
	Avg	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max
1/06/2019	1.00	0.07	0.14	0.05	0.11	0.09	0.23	0.05	0.16	0.01	0.06	0.01	0.08	0.02	0.10	0.04	0.13
2/06/2019	0.98	0.08	0.14	0.04	0.11	0.12	0.23	OL	OL	0.01	0.05	0.01	0.07	0.02	0.07	0.05	0.10
3/06/2019	0.95	0.08	0.13	0.04	0.10	0.13	0.24	0.01	0.12	0.01	0.05	0.01	0.07	0.02	0.08	0.05	0.11
4/06/2019	1.04	0.07	0.13	0.04	0.09	0.13	0.20	0.05	0.09	0.02	0.04	0.01	0.06	0.02	0.07	0.04	0.11
5/06/2019	1.13	0.07	0.13	0.04	0.10	0.10	0.13	0.06	0.11	0.02	0.05	0.01	0.05	0.01	0.07	0.04	0.06
6/06/2019	1.25	0.07	0.12	0.04	0.09	0.10	0.17	0.05	0.11	0.02	0.05	0.00	0.05	0.02	0.04	0.05	0.10
7/06/2019	1.37	0.07	0.12	0.04	0.06	0.10	0.18	0.06	0.12	0.02	0.06	0.01	0.04	0.02	0.08	0.05	0.11
8/06/2019	1.61	0.08	0.10	0.05	0.10	0.11	0.19	0.06	0.13	0.02	0.04	0.01	0.06	0.03	0.08	0.05	0.12
9/06/2019	1.80	0.07	0.13	0.05	0.10	0.10	0.13	0.08	0.09	0.03	0.06	0.01	0.07	0.02	0.08	0.05	0.13
10/06/2019	2.07	0.07	0.14	0.04	0.20	0.13	0.18	0.08	0.15	0.03	0.07	0.01	0.08	0.03	0.05	0.06	0.09
11/06/2019	2.41	0.07	0.09	0.04	0.19	0.09	0.23	0.07	0.19	0.03	0.09	0.02	0.04	0.04	0.10	0.06	0.14
12/06/2019	2.67	0.07	0.15	0.04	0.17	0.06	0.20	0.06	0.24	0.03	0.23	0.01	0.09	0.04	0.17	0.04	0.27
13/06/2019	2.66	0.06	0.15	0.04	0.15	0.11	0.15	0.11	0.20	0.03	0.09	0.01	0.11	0.03	0.13	0.05	0.08
14/06/2019	1.91	0.07	0.16	0.04	0.12	0.09	0.21	0.06	0.17	0.03	0.11	0.01	0.08	0.03	0.07	0.06	0.17
15/06/2019	0.99	0.08	0.11	0.04	0.20	0.10	0.20	0.06	0.16	0.03	0.28	0.02	0.09	0.04	0.13	0.05	0.15
16/06/2019	1.10	0.08	0.15	0.04	0.07	0.10	0.21	0.05	0.17	0.04	0.11	0.02	0.11	0.04	0.14	0.05	0.17
17/06/2019	1.18	0.03	0.15	0.03	0.12	0.07	0.20	0.04	0.20	0.02	0.16	0.01	0.16	0.01	0.14	0.03	0.16
18/06/2019	1.08	0.06	0.14	0.04	0.11	0.09	0.21	0.05	0.16	0.04	0.13	0.01	0.03	0.04	0.10	0.05	0.14
19/06/2019	1.07	0.07	0.10	0.03	0.06	0.09	0.20	0.05	0.15	0.03	0.10	0.01	0.09	0.03	0.12	0.04	0.13
20/06/2019	1.16	0.06	0.14	0.05	0.10	0.09	0.18	0.06	0.09	0.03	0.10	0.01	0.08	0.03	0.12	0.04	0.13
21/06/2019	1.35	0.05	0.14	0.04	0.10	0.12	0.20	0.06	0.15	0.03	0.10	0.01	0.09	0.03	0.12	0.04	0.07
22/06/2019	1.85	0.05	0.14	0.03	0.13	0.11	0.21	0.06	0.17	0.04	0.07	0.02	0.11	0.03	0.06	0.06	0.16
23/06/2019	1.81	0.07	0.12	0.04	0.09	0.10	0.18	0.02	0.07	0.04	0.11	0.02	0.11	0.05	0.13	0.05	0.16
24/06/2019	2.98	0.06	0.09	0.04	0.10	0.10	0.21	OL	OL	0.04	0.10	0.03	0.06	0.05	0.11	0.06	0.13
25/06/2019	3.18	0.07	0.24	0.05	0.09	0.10	0.22	0.03	0.15	0.04	0.10	0.03	0.06	0.06	0.09	0.05	0.16
26/06/2019	2.27	0.07	0.13	0.04	0.12	0.13	0.17	0.06	0.17	0.04	0.11	0.04	0.18	0.04	0.17	0.05	0.09
27/06/2019	1.43	0.05	0.14	0.04	0.12	0.07	0.23	0.06	0.11	0.03	0.10	0.04	0.14	0.04	0.13	0.08	0.18
28/06/2019	0.78	0.05	0.13	0.04	0.11	0.02	0.11	0.05	0.14	0.03	0.07	0.05	0.14	0.05	0.08	0.06	0.16
29/06/2019	0.94	0.05	0.13	0.04	0.12	0.02	0.10	0.04	0.12	0.03	0.10	0.05	0.08	0.06	0.14	0.06	0.16
30/06/2019	0.90	0.04	0.11	0.05	0.07	0.02	0.10	0.05	0.14	0.03	0.12	0.06	0.14	0.06	0.15	0.05	0.15

Total Number of Measurements Taken, A:	10857	12361	13874	11127	13072	12547	13651	14601
Turbidity Standard for Monitoring Location (NTU):	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3
Number of Measurements Meeting Standard, B:	10857	12361	13874	11127	13072	12547	13651	14601
Compliance with Turbidity Standard, C = B/A X 100%:	100.000%	100.000%	100.000%	100.000%	100.000%	100.000%	100.000%	100.000%

OL - Off Line

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Turbidity\2019\06-June

Submitted By (Print): D.Merredew

Signature: Original signed by D.Merredew

WATER TREATMENT PLANT TURBIDITY GRAB MONITORING REPORT

Water System Code: 252.00		Turbidity (NTU)																	
Licence No. PWS-09-412-01																			
Date	Raw Water		Filter 1		Filter 2		Filter 3		Filter 4		Filter 5		Filter 6		Filter 7		Filter 8		
	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	
01-Jun-2019	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
02-Jun-2019	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
03-Jun-2019	0.64	0.86	0.11	0.09	0.09	0.06	0.10	0.16	OL	OL	0.10	0.02	0.12	0.03	0.14	0.06	OL	OL	
04-Jun-2019	0.86	0.94	0.13	0.09	0.09	0.06	0.08	0.19	0.16	0.09	0.12	0.02	OL	OL	0.08	<0.02	0.10	0.04	
05-Jun-2019	0.87	1.13	OL	OL	0.12	0.05	0.10	0.10	0.10	0.06	0.13	0.03	0.07	<0.02	0.09	<0.02	0.08	0.04	
06-Jun-2019	0.86	1.33	0.08	0.08	0.07	0.04	0.10	0.12	0.12	0.09	OL	OL	0.11	<0.02	0.12	<0.02	0.09	0.04	
07-Jun-2019	0.93	1.34	0.08	0.09	0.08	0.05	OL	OL	0.07	0.06	0.07	0.02	0.09	<0.02	0.12	0.02	0.11	0.06	
08-Jun-2019	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
09-Jun-2019	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
10-Jun-2019	0.79	1.90	OL	OL	0.08	0.05	0.10	0.13	0.10	0.09	0.12	0.05	0.10	<0.02	0.11	0.02	0.10	0.05	
11-Jun-2019	0.69	2.32	0.09	0.09	0.09	0.06	0.19	0.19	0.09	0.06	0.11	0.04	0.12	0.03	0.12	0.03	OL	OL	
12-Jun-2019	0.74	2.80	0.11	0.08	0.08	0.04	0.08	0.09	0.08	0.08	0.08	0.03	0.12	0.02	OL	OL	OL	OL	
13-Jun-2019	0.76	2.62	OL	OL	OL	OL	0.13	0.13	0.12	0.12	0.13	0.05	0.11	0.02	0.12	0.03	0.13	0.06	
14-Jun-2019	0.82	0.92	0.09	0.09	0.09	0.05	0.16	0.14	0.15	0.12	OL	OL	0.11	0.02	0.12	0.03	0.13	0.06	
15-Jun-2019	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
16-Jun-2019	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
17-Jun-2019	OL	OL	OL	OL	OL	OL	OL	OL	OL	OL	OL	OL	OL	OL	OL	OL	OL	OL	
18-Jun-2019	0.83	1.05	0.09	0.08	OL	OL	0.16	0.16	OL	OL	0.11	0.06	0.12	<0.02	0.11	0.03	0.14	0.07	
19-Jun-2019	0.90	1.00	0.10	0.08	0.09	0.05	OL	OL	0.10	0.06	0.12	0.07	0.11	0.02	0.12	0.04	OL	OL	
20-Jun-2019	0.95	1.11	0.11	0.09	0.10	0.06	0.11	0.12	0.15	0.08	OL	OL	0.15	0.06	OL	OL	0.10	0.05	
21-Jun-2019	0.93	1.18	OL	OL	0.11	0.07	0.10	0.12	0.11	0.07	0.11	0.04	OL	OL	0.11	0.02	0.10	0.04	
22-Jun-2019	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
23-Jun-2019	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
24-Jun-2019	1.12	2.48	0.09	0.07	0.09	0.05	OL	OL	OL	OL	0.13	0.06	0.13	0.03	0.11	0.05	0.14	0.07	
25-Jun-2019	1.02	3.02	0.11	0.08	0.11	0.07	0.10	0.13	OL	OL	OL	OL	0.13	0.05	0.13	0.07	0.10	0.05	
26-Jun-2019	1.01	2.33	0.11	0.08	0.11	0.07	0.11	0.14	0.11	0.07	OL	OL	0.18	0.11	OL	OL	0.13	0.02	
27-Jun-2019	1.09	2.02	0.12	0.09	OL	OL	0.13	0.07	0.11	0.07	0.12	0.05	OL	OL	0.11	0.05	0.16	0.07	
28-Jun-2019	1.15	0.51	OL	OL	0.09	0.06	OL	OL	0.11	0.06	0.10	0.03	0.11	0.06	0.12	0.05	0.14	0.08	
29-Jun-2019	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
30-Jun-2019	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
Total number of measurements taken, A:			14		16		15		15		14		16		16		15		
Turbidity Standard for Monitoring Location (NTU):			0.30		0.30		0.30		0.30		0.30		0.30		0.30		0.30		
Number of measurements meeting standard, B:			14		16		15		15		14		16		16		15		
Compliance with Turbidity Standard, C= B/A X 100%:			100%		100%		100%		100%		100%		100%		100%		100%		

NS: No Sample NA: Not Analyzed OL: Off-Line

Comments:

WTP offline for scheduled maintenance on June 17 from 8:00 am to 4:30 pm.

The raw water analyser is cleaned daily during warm water months because it is susceptible to frequent fouling.

Report Compiled By: H.Demchenko

Authorized in Sample Manager By: C.Diduck

Date Authorized: 5-Jul-19



WATER TREATMENT PLANT FREE CHLORINE ON-LINE MONITORING REPORT
Deacon Booster Pumping Station

Water System Code: **252.00**
Licence Number: **PWS-09-412-01**
Report Created: 01 July 2019

Report Period: June 2019

Date	BRANCH 1 [mg/L]		BRANCH 2 [mg/L]	
	Average	Minimum	Average	Minimum
01/06/2019	1.27	1.11	1.26	1.08
02/06/2019	1.25	1.05	1.22	1.02
03/06/2019	1.28	1.14	1.28	1.13
04/06/2019	1.26	1.16	1.25	1.14
05/06/2019	1.25	1.14	1.26	1.20
06/06/2019	1.26	1.16	1.28	1.17
07/06/2019	1.32	1.23	1.27	1.21
08/06/2019	1.33	1.09	1.25	1.18
09/06/2019	1.34	1.20	1.32	1.17
10/06/2019	1.38	1.29	1.36	1.26
11/06/2019	1.38	0.97	1.35	1.01
12/06/2019	1.40	0.97	1.48	1.06
13/06/2019	1.31	1.20	1.31	1.20
14/06/2019	1.35	1.22	1.34	1.26
15/06/2019	1.32	1.17	1.29	1.18
16/06/2019	1.27	1.14	1.25	1.17
17/06/2019	1.22	0.98	1.24	1.05
18/06/2019	1.25	1.09	1.23	1.17
19/06/2019	1.33	1.16	1.32	1.08
20/06/2019	1.40	1.30	1.40	1.29
21/06/2019	1.40	1.29	1.40	1.30
22/06/2019	1.34	1.24	1.32	1.24
23/06/2019	1.37	1.26	1.35	1.22
24/06/2019	1.41	1.22	1.41	1.09
25/06/2019	1.38	0.84	1.35	0.83
26/06/2019	1.39	1.29	1.37	1.26
27/06/2019	1.34	1.23	1.35	1.24
28/06/2019	1.38	1.18	1.48	1.30
29/06/2019	1.40	1.25	1.52	1.39
30/06/2019	1.35	1.24	1.44	1.35

Total Number of Measurements, A:	20880	20879
Minimum Free Chlorine Standard:	0.5	0.5
Number of Measurements Meeting Standard, B:	20880	20879
COMPLIANCE, C = B/A X 100%:	100.00	100.00

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Chlorine\2019\06-June

Submitted By (Print): D.Merredew

Original signed by D.Merredew



WATER TREATMENT PLANT CHLORINE GRAB MONITORING REPORT

Water System Code: 252.00		Deacon Booster Pumping Station Branch 1			Deacon Booster Pumping Station Branch 2		
Licence No. PWS-09-412-01							
Date	Free Chlorine (mg/L)		Total Chlorine (mg/L)	Free Chlorine (mg/L)		Total Chlorine (mg/L)	
	Analyser	Grab	Grab	Analyser	Grab	Grab	
01-Jun-2019	NA	NA	NA	NA	NA	NA	
02-Jun-2019	NA	NA	NA	NA	NA	NA	
03-Jun-2019	1.22	1.30	1.48	1.19	1.26	1.36	
04-Jun-2019	1.22	1.26	1.42	1.17	1.22	1.35	
05-Jun-2019	1.20	1.28	1.40	1.25	1.32	1.45	
06-Jun-2019	1.31	1.35	1.47	1.34	1.35	1.47	
07-Jun-2019	1.28	1.30	1.49	1.23	1.27	1.45	
08-Jun-2019	NA	NA	NA	NA	NA	NA	
09-Jun-2019	NA	NA	NA	NA	NA	NA	
10-Jun-2019	1.39	1.34	1.48	1.36	1.27	1.45	
11-Jun-2019	1.25	1.23	1.36	1.23	1.20	1.35	
12-Jun-2019	1.54	1.67	1.88	1.60	1.72	1.92	
13-Jun-2019	1.34	1.31	1.49	1.34	1.35	1.49	
14-Jun-2019	1.31	1.28	1.45	1.38	1.35	1.47	
15-Jun-2019	NA	NA	NA	NA	NA	NA	
16-Jun-2019	NA	NA	NA	NA	NA	NA	
17-Jun-2019	OL	OL	OL	OL	OL	OL	
18-Jun-2019	1.13	1.19	1.35	1.18	1.20	1.30	
19-Jun-2019	1.27	1.30	1.52	1.28	1.33	1.43	
20-Jun-2019	1.43	1.43	1.61	1.43	1.42	1.59	
21-Jun-2019	1.45	1.45	1.91	1.47	1.46	1.60	
22-Jun-2019	NA	NA	NA	NA	NA	NA	
23-Jun-2019	NA	NA	NA	NA	NA	NA	
24-Jun-2019	1.37	1.37	1.55	1.43	1.43	1.66	
25-Jun-2019	1.43	1.46	1.67	1.37	1.33	1.52	
26-Jun-2019	1.40	1.48	1.66	1.40	1.40	1.59	
27-Jun-2019	1.39	1.40	1.60	1.32	1.41	1.58	
28-Jun-2019	1.36	1.48	1.60	1.39	1.47	1.61	
29-Jun-2019	NA	NA	NA	NA	NA	NA	
30-Jun-2019	NA	NA	NA	NA	NA	NA	
Total number of measurements taken, A:		19		19			
Chlorine Standard for Monitoring Location (mg/L):		0.50		0.50			
Number of measurements meeting standard, B:		19		19			
Compliance with Chlorine Standard, C= B/A X 100%:		100%		100%			

NS: No Sample NA: Not Analyzed OL: Off-Line

Comments:
WTP offline for scheduled maintenance on June 17 from 8:00 am to 4:30 pm.

Report Compiled By: H.Demchenko

Authorized By: C.Diduck

Date Authorized: 5-Jul-19



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
WATER SERVICES

Water System Code: **252.00**
 Licence Number: **PWS-09-412-01**

WATER TREATMENT PLANT UV REPORT

Report Period: **June 2019**

Report Created: **Monday, July 01, 2019**

Date	Transmittance %	UVR-D100A				UVR-D200A				UVR-D300A				UVR-D400A				UVR-D500A				UVR-D600A				Total				% Volume Treated To Dose						
		Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]										
		Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	To	Total		Untreated	Below	To	Total		
01/06/2019	94.81	0.00	0.00	0.00	0.00	0.00	0.00	85.01	85.01	0.00	0.00	62.90	62.90	0.00	0.00	0.00	0.00	0.00	0.00	75.56	75.56	0.00	0.00	0.00	0.00	0.00	0.00	223.47	223.47	100.00						
02/06/2019	94.79	0.00	0.00	0.00	0.00	0.00	0.00	85.02	85.02	0.00	0.00	65.07	65.07	0.00	0.00	0.00	0.00	0.00	0.00	78.01	78.01	0.00	0.00	0.00	0.00	0.00	0.00	228.10	228.10	100.00						
03/06/2019	94.66	0.00	0.00	0.00	0.00	0.00	0.00	84.99	84.99	0.00	0.00	64.93	64.93	0.00	0.00	0.00	0.00	0.00	0.00	77.80	77.80	0.00	0.00	0.00	0.00	0.00	0.00	227.73	227.73	100.00						
04/06/2019	94.27	0.00	0.00	0.00	0.00	0.00	0.00	85.01	85.01	0.00	0.00	62.22	62.22	0.00	0.00	0.00	0.00	0.00	0.00	75.28	75.28	0.00	0.00	0.00	0.00	0.00	0.00	222.51	222.51	100.00						
05/06/2019	93.79	0.20	0.20	54.81	55.20	0.00	0.00	27.54	27.54	0.00	0.00	62.38	62.38	0.00	0.00	1.95	1.95	0.00	0.00	75.43	75.43	0.00	0.00	0.00	0.00	0.20	0.20	222.11	222.50	99.82						
06/06/2019	92.90	0.00	0.00	63.43	63.43	0.00	0.00	19.01	19.01	0.00	0.38	47.73	48.11	0.00	0.00	19.98	19.98	0.00	0.00	74.35	74.35	0.00	0.00	0.00	0.00	0.00	0.38	224.50	224.89	99.83						
07/06/2019	95.62	0.00	0.00	0.00	0.00	0.00	0.00	75.25	75.25	0.00	0.00	0.00	0.00	0.00	0.00	81.07	81.07	0.00	0.00	73.67	73.67	0.00	0.00	0.00	0.00	0.00	0.00	229.99	229.99	100.00						
08/06/2019	95.88	0.00	0.00	46.47	46.47	0.00	0.00	81.97	81.97	0.00	0.00	0.00	0.00	0.00	0.00	17.85	17.85	0.00	0.00	82.40	82.40	0.00	0.00	0.00	0.00	0.00	0.00	228.70	228.70	100.00						
09/06/2019	96.00	0.00	0.00	51.15	51.15	0.00	0.00	68.21	68.21	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	84.72	84.72	0.00	0.00	0.00	0.00	0.00	0.00	204.08	204.08	100.00						
10/06/2019	95.88	0.00	0.00	49.59	49.59	0.00	0.00	65.57	65.57	0.00	0.08	0.02	0.10	0.00	0.00	0.00	0.00	0.00	0.00	84.77	84.77	0.00	0.00	0.00	0.00	0.00	0.08	199.95	200.03	99.96						
11/06/2019	95.65	0.00	0.00	58.35	58.35	0.00	0.00	33.08	33.08	0.00	0.00	40.70	40.70	0.00	0.00	0.00	0.00	0.00	0.00	79.50	79.50	0.00	0.00	0.00	0.00	0.00	0.00	211.63	211.63	100.00						
12/06/2019	95.02	0.09	0.09	53.89	54.07	0.00	0.00	0.00	0.00	0.00	0.00	49.08	49.08	0.01	0.01	0.00	0.03	0.00	0.00	52.35	52.35	0.00	0.00	0.00	0.00	0.10	0.10	155.32	155.53	99.87						
13/06/2019	95.64	0.00	0.00	82.58	82.58	0.00	0.00	0.00	0.00	0.00	0.00	62.00	62.00	0.00	0.00	0.00	0.00	0.00	0.00	65.50	65.50	0.00	0.00	11.36	11.36	0.00	0.00	221.44	221.44	100.00						
14/06/2019	95.61	0.00	0.00	50.37	50.37	0.00	0.05	34.60	34.65	0.00	0.00	68.61	68.61	0.00	0.00	0.00	0.00	0.00	0.00	83.15	83.15	0.00	0.00	0.00	0.00	0.00	0.05	236.73	236.78	99.98						
15/06/2019	95.55	0.00	0.00	0.00	0.00	0.00	0.00	85.00	85.00	0.00	0.00	70.10	70.10	0.00	0.00	0.00	0.00	0.00	0.00	84.88	84.88	0.00	0.00	0.00	0.00	0.00	0.00	239.98	239.98	100.00						
16/06/2019	95.46	0.00	0.00	0.00	0.00	0.00	0.00	85.01	85.01	0.00	0.49	13.60	14.08	0.00	0.03	58.31	58.34	0.00	0.00	82.59	82.59	0.00	0.00	0.00	0.00	0.00	0.52	239.51	240.03	99.78						
17/06/2019	94.76	0.00	0.00	0.00	0.00	0.02	0.02	48.36	48.40	0.00	0.00	0.00	0.01	0.12	0.16	37.36	37.64	0.00	0.00	41.60	41.60	0.00	0.00	0.00	0.00	0.15	0.18	127.31	127.65	99.74						
18/06/2019	95.67	0.00	1.01	49.02	50.03	0.01	0.01	36.86	36.87	0.00	0.00	0.00	0.00	0.00	0.00	59.15	59.15	0.00	0.00	68.26	68.26	0.00	0.00	0.66	0.67	0.01	1.02	213.95	214.98	99.52						
19/06/2019	95.86	0.00	0.00	83.55	83.55	0.00	0.00	0.00	0.00	0.00	0.04	0.06	0.10	0.00	0.00	60.37	60.37	0.00	0.00	23.93	23.93	0.00	0.05	47.02	47.07	0.00	0.09	214.94	215.02	99.96						
20/06/2019	95.89	0.00	0.00	83.26	83.26	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	60.54	60.54	0.00	0.00	0.00	0.00	0.00	0.55	70.61	71.15	0.00	0.55	214.41	214.96	99.75						
21/06/2019	95.85	0.00	0.00	84.77	84.77	0.00	0.00	0.00	0.00	0.00	0.00	46.94	46.94	0.00	0.00	21.54	21.54	0.00	0.00	0.00	0.00	0.00	6.29	74.87	81.15	0.00	6.29	228.12	234.41	97.32						
22/06/2019	95.82	0.00	0.00	84.96	84.96	0.00	0.00	0.00	0.00	0.00	0.00	62.92	62.92	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	6.08	72.14	78.22	0.00	6.08	220.02	226.10	97.31						
23/06/2019	95.86	0.00	0.00	85.02	85.02	0.00	0.00	0.00	0.00	0.00	0.00	59.40	59.40	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	7.36	68.27	75.63	0.00	7.36	212.69	220.05	96.66						
24/06/2019	95.59	0.26	0.26	77.11	77.64	0.00	0.00	0.00	0.00	0.17	0.17	54.89	55.24	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.27	4.91	62.98	68.15	0.70	5.35	194.98	201.03	96.99						
25/06/2019	91.87	0.00	0.00	70.68	70.68	0.00	0.00	0.00	0.00	0.00	0.00	80.14	80.14	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	2.26	73.15	75.40	0.00	2.26	223.96	226.22	99.00						
26/06/2019	96.96	0.00	0.00	72.00	72.00	0.00	0.00	0.00	0.00	0.00	0.00	82.82	82.82	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.06	8.12	72.03	80.20	0.06	8.12	226.85	235.03	96.52						
27/06/2019	97.00	0.00	0.52	39.15	39.67	0.00	0.00	35.15	35.15	0.00	0.00	41.89	41.89	0.00	0.00	39.40	39.40	0.00	0.00	0.00	0.00	0.00	7.40	71.43	78.83	0.00	7.92	227.02	234.95	96.63						
28/06/2019	97.09	0.00	0.00	45.27	45.27	0.00	0.00	33.02	33.02	0.00	0.00	0.08	0.08	0.00	0.00	84.22	84.22	0.00	0.42	35.91	36.33	0.00	1.90	41.16	43.05	0.00	2.32	239.66	241.98	99.04						
29/06/2019	97.14	0.00	0.00	78.39	78.39	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	85.03	85.03	0.00	0.00	80.60	80.60	0.00	0.00	0.00	0.00	0.00	0.00	244.02	244.02	100.00						
30/06/2019	97.29	0.00	0.00	67.25	67.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	73.46	73.46	0.00	0.00	67.78	67.78	0.00	0.00	0.00	0.00	0.00	0.00	208.49	208.49	100.00						
Total [ML]:		0.55	2.08	1431.07	1433.70	0.03	0.08	1068.67	1068.78	0.18	1.17	1098.49	1099.83	0.14	0.21	700.23	700.57	0.00	0.42	1548.05	1548.47	0.33	44.91	665.66	710.90	1.22	48.87	6512.16	6562.25							

Water Volume [%]:
 Untreated: 0.02 %
 Below Dose: 0.74 %
 To Dose: 99.24 %
Notes: 1. UV Comparative Dose: 18.1 mJ/cm²

Submitted By (Print): D.Merredew

Signature: Original signed by D.Merredew