



## Water and Waste Eaux et déchets

Derek Clarke, Drinking Water Officer  
Office of Drinking Water, Manitoba Sustainable Development  
Box 6000  
Gimli, MB R0C 1B0

**June 6, 2019**

### **RE: MAY 2019 WATER QUALITY COMPLIANCE SUBMISSION FOR THE CITY OF WINNIPEG WATER SUPPLY SYSTEM**

Please find attached on-line and grab turbidity summary reports, on-line and grab chlorine summary reports and the UV summary report for the Water Treatment Plant for May 2019.

The May on-line and grab sampling turbidity reports include results obtained for the Water Treatment Plant raw water and the eight filters. Please note that on May 31, the maximum turbidity for Filter 4 was greater than 0.3 for a short period of time, which did not exceed 12 consecutive hours. The turbidity results for the effluent from the filters met the licence requirements.

The May on-line and grab sampling chlorine reports include results obtained for the Deacon Booster Pumping Station at the Water Treatment Plant. The free chlorine results at the Water Treatment Plant met the licence requirements.

The May UV summary report includes results obtained for the six UV reactors at the Water Treatment Plant. The UV disinfection results met the licence requirements.

Please let me know of any concerns or questions respecting this submission. I may be reached by telephone at 204-986-8359 or by e-mail at rgrosselle@winnipeg.ca.

Yours sincerely,

Original signed by:

R. Grosselle  
Manager of Environmental Standards

Enclosures

cc: Dr. L. Richards, Winnipeg Regional Health Authority (email)  
Dr. H. Chang, Winnipeg Regional Health Authority (email)  
Dr. S. Roberecki, Manitoba Health, Seniors and Active Living (email)  
M. L. Geer, CPA, CA (email)  
G. Patton, P.Eng. (email)  
T. Shanks, P.Eng. (email)  
M. Szmon, P.Eng. (email)  
C. Diduck (email)



**CITY OF WINNIPEG**  
WATER AND WASTE DEPARTMENT  
WATER SERVICES

Water System Code: **252.00**  
Licence Number: **PWS-09-412-01**

**WATER TREATMENT PLANT TURBIDITY ON-LINE MONITORING REPORT**

**May 2019 Turbidity (NTU)**

Date	Raw		Filter #1		Filter #2		Filter #3		Filter #4		Filter #5		Filter #6		Filter #7		Filter #8	
	Avg	Avg	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max
1/05/2019	0.62	0.03	0.07		0.02	0.07	0.07	0.09	0.02	0.09	0.01	0.04	0.02	0.04	0.05	0.08	0.03	0.07
2/05/2019	0.63	0.02	0.08		0.03	0.05	0.06	0.13	0.02	0.04	0.01	0.04	0.03	0.08	0.04	0.08	0.03	0.08
3/05/2019	0.67	0.04	0.06		0.02	0.07	0.06	0.14	0.03	0.08	0.01	0.03	0.02	0.07	0.04	0.09	0.03	0.05
4/05/2019	0.72	0.03	0.08		0.02	0.07	0.06	0.09	0.02	0.09	0.03	0.06	0.02	0.08	0.05	0.07	0.04	0.08
5/05/2019	0.73	0.02	0.08		0.02	0.04	0.08	0.13	0.02	0.04	0.03	0.07	0.04	0.06	0.05	0.10	0.03	0.08
6/05/2019	0.74	0.03	0.05		0.02	0.05	0.06	0.12	0.03	0.09	0.03	0.05	0.03	0.07	0.04	0.12	0.03	0.08
7/05/2019	0.76	0.03	0.07		0.02	0.06	0.06	0.14	0.03	0.12	0.06	0.11	0.03	0.10	0.05	0.07	0.04	0.06
8/05/2019	0.75	0.02	0.07		0.02	0.03	0.10	0.12	0.02	0.10	0.06	0.11	0.05	0.07	0.06	0.12	0.03	0.08
9/05/2019	0.78	0.02	0.04		0.03	0.06	0.08	0.16	0.04	0.07	0.06	0.14	0.06	0.11	0.05	0.13	0.03	0.08
10/05/2019	0.81	0.04	0.08		0.02	0.07	0.09	0.18	0.04	0.11	0.10	0.13	0.06	0.13	0.05	0.12	0.03	0.05
11/05/2019	0.84	0.03	0.09		0.02	0.07	0.08	0.14	0.04	0.13	0.03	0.16	0.06	0.15	0.07	0.09	0.05	0.08
12/05/2019	0.86	0.03	0.10		0.02	0.04	0.08	0.15	0.04	0.14	0.00	0.01	0.10	0.12	0.07	0.14	0.03	0.09
13/05/2019	0.82	0.04	0.22		0.04	0.12	0.07	0.23	0.08	0.30	0.00	0.01	0.10	0.17	0.06	0.15	0.03	0.09
14/05/2019	1.08	0.04	0.11		0.02	0.11	0.05	0.12	0.07	0.18	0.01	0.01	0.10	0.21	0.08	0.15	0.04	0.06
15/05/2019	0.87	0.03	0.08		0.02	0.08	0.07	0.14	0.07	0.18	0.00	0.01	0.12	0.18	0.10	0.12	0.05	0.08
16/05/2019	1.01	0.04	0.14		0.03	0.06	0.08	0.16	0.05	0.13	0.02	0.06	0.07	0.26	0.05	0.20	0.03	0.11
17/05/2019	0.94	0.05	0.08		0.04	0.13	0.07	0.21	0.03	0.08	0.01	0.03	0.01	0.08	0.01	0.10	0.02	0.09
18/05/2019	0.96	0.05	0.12		0.03	0.13	0.10	0.13	0.02	0.16	0.03	0.06	0.01	0.06	0.01	0.06	0.02	0.04
19/05/2019	1.00	0.04	0.13		0.03	0.06	0.09	0.20	0.02	0.14	0.03	0.08	0.01	0.03	0.01	0.03	0.03	0.07
20/05/2019	0.94	0.05	0.07		0.05	0.13	0.07	0.20	0.03	0.06	0.02	0.04	0.02	0.07	0.01	0.07	0.02	0.08
21/05/2019	0.80	0.05	0.13		0.04	0.12	0.11	0.14	0.02	0.15	0.05	0.09	0.02	0.07	0.01	0.07	0.02	0.05
22/05/2019	0.66	0.04	0.14		0.03	0.13	0.09	0.20	0.02	0.14	0.05	0.11	0.02	0.03	0.01	0.03	0.03	0.08
23/05/2019	0.77	0.04	0.14		0.05	0.07	0.08	0.21	0.02	0.04	0.05	0.13	0.03	0.08	0.01	0.07	0.03	0.09
24/05/2019	0.87	0.07	0.10		0.04	0.13	0.08	0.21	0.03	0.14	0.08	0.12	0.03	0.10	0.01	0.09	0.03	0.09
25/05/2019	1.00	0.05	0.13		0.04	0.12	0.11	0.14	0.02	0.12	0.10	0.15	0.04	0.12	0.01	0.06	0.03	0.05
26/05/2019	1.01	0.05	0.13		0.03	0.11	0.09	0.20	0.02	0.12	0.09	0.19	0.06	0.08	0.01	0.03	0.03	0.08
27/05/2019	1.02	0.04	0.10		0.05	0.07	0.09	0.20	0.02	0.04	0.07	0.14	0.06	0.14	0.02	0.06	0.03	0.08
28/05/2019	1.16	0.06	0.13		0.04	0.13	0.06	0.17	0.05	0.15	0.02	0.10	0.01	0.12	0.02	0.15	0.03	0.16
29/05/2019	1.18	0.06	0.15		0.05	0.13	0.12	0.23	0.05	0.18	0.03	0.14	0.01	0.10	0.02	0.12	0.05	0.08
30/05/2019	1.13	0.06	0.12		0.04	0.16	0.08	0.22	0.04	0.15	0.02	0.10	0.00	0.03	0.02	0.07	0.04	0.15
31/05/2019	1.15	0.07	0.14		0.04	0.07	0.08	0.18	0.04	0.31	0.01	0.07	0.01	0.10	0.02	0.13	0.04	0.13

Total Number of Measurements Taken, A: 13574      12123      14089      12412      13652      13143      13465      14574  
Turbidity Standard for Monitoring Location (NTU): 0.3      0.3      0.3      0.3      0.3      0.3      0.3      0.3  
Number of Measurements Meeting Standard, B: 13574      12123      14089      12411      13652      13143      13465      14574  
Compliance with Turbidity Standard, C = B/A X 100%: 100.000%      100.000%      100.000%      99.992%      100.000%      100.000%      100.000%      100.000%

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Turbidity\2019\05-May

Submitted By (Print): D.Merredew

Signature: Original signed by D.Merredew



CITY OF WINNIPEG  
WATER AND WASTE DEPARTMENT  
ENVIRONMENTAL STANDARDS DIVISION

**WATER TREATMENT PLANT TURBIDITY GRAB MONITORING REPORT**

Water System Code: 252.00	Turbidity (NTU)																	
	Raw Water		Filter 1		Filter 2		Filter 3		Filter 4		Filter 5		Filter 6		Filter 7		Filter 8	
Date	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser
01-May-2019	0.61	0.61	OL	OL	0.08	0.03	0.08	0.07	OL	OL	0.09	0.05	0.07	0.04	0.07	0.05	0.10	0.04
02-May-2019	0.51	0.57	0.11	0.02	0.08	0.03	0.12	0.08	0.09	0.02	OL	OL	0.07	0.04	0.09	0.06	OL	OL
03-May-2019	0.53	0.64	0.07	0.03	0.10	0.04	OL	OL	0.09	0.05	0.07	0.03	OL	OL	0.06	0.04	0.06	0.03
04-May-2019	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
05-May-2019	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
06-May-2019	0.60	0.70	0.07	0.02	0.08	0.03	OL	OL	0.08	0.04	0.06	0.07	0.08	0.06	OL	OL	0.06	0.03
07-May-2019	0.59	0.76	0.08	0.03	OL	OL	0.08	0.09	0.11	0.08	0.08	0.09	0.06	0.05	0.07	0.06	0.07	0.04
08-May-2019	0.56	0.70	OL	OL	0.08	0.03	0.10	0.10	0.08	0.03	OL	OL	0.09	0.06	0.09	0.07	0.08	0.05
09-May-2019	0.58	0.76	0.08	0.02	0.08	0.03	0.11	0.12	0.07	0.04	0.06	0.10	0.07	0.08	OL	OL	OL	OL
10-May-2019	0.63	0.78	0.07	0.03	0.09	0.05	OL	OL	0.08	0.06	0.06	0.13	OL	OL	0.06	0.06	0.07	0.04
11-May-2019	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
12-May-2019	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
13-May-2019	0.75	0.79	0.08	0.03	0.09	0.04	OL	OL	0.09	0.08	0.06	<0.02	0.09	0.15	OL	OL	0.08	0.04
14-May-2019	1.05	1.55	0.11	0.03	OL	OL	0.09	0.08	0.12	0.11	0.07	<0.02	OL	OL	0.08	0.09	0.11	0.04
15-May-2019	0.63	1.09	OL	OL	0.06	0.03	0.09	0.09	OL	OL	0.09	<0.02	0.11	0.17	0.07	0.10	0.08	0.05
16-May-2019	1.10	1.12	0.08	0.03	0.10	0.03	OL	OL	0.08	0.02	OL	OL	0.09	0.03	0.10	0.02	0.11	0.04
17-May-2019	0.68	0.89	0.10	0.05	0.11	0.07	0.10	0.11	0.11	0.03	0.07	0.02	0.10	0.04	OL	OL	OL	OL
18-May-2019	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
19-May-2019	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
20-May-2019	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
21-May-2019	0.86	0.64	0.12	0.06	OL	OL	0.11	0.11	0.14	0.07	0.13	0.06	OL	OL	0.09	<0.02	0.07	0.02
22-May-2019	0.71	0.49	0.13	0.08	0.10	0.05	0.13	0.13	0.09	0.03	0.10	0.09	0.09	0.02	0.07	<0.02	0.07	0.03
23-May-2019	0.85	0.86	0.09	0.04	0.10	0.05	OL	OL	0.13	0.02	0.06	0.07	0.09	0.04	0.09	0.02	OL	OL
24-May-2019	0.80	0.45	0.15	0.05	0.12	0.08	0.11	0.11	0.10	0.03	0.10	0.10	0.10	0.06	OL	OL	0.12	0.03
25-May-2019	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
26-May-2019	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
27-May-2019	0.89	0.90	0.18	0.05	0.14	0.07	OL	OL	0.15	0.04	OL	OL	0.11	0.11	0.08	<0.02	0.13	0.04
28-May-2019	0.97	1.05	0.07	0.05	0.08	0.06	0.07	0.10	0.09	0.03	0.09	0.02	OL	OL	0.17	0.06	0.09	0.04
29-May-2019	1.05	1.24	0.16	0.12	OL	OL	0.11	0.13	OL	OL	0.12	0.05	0.10	0.02	0.10	0.02	0.10	0.06
30-May-2019	1.03	1.28	OL	OL	0.08	0.04	0.08	0.11	OL	OL	0.09	0.03	0.14	<0.02	0.07	<0.02	0.08	0.03
31-May-2019	0.91	1.26	0.09	0.09	0.11	0.05	OL	OL	0.10	0.06	OL	OL	0.09	0.02	0.13	0.02	0.11	0.07
Total number of measurements taken, A:			18		18		14		18		17		17		17		18	
Turbidity Standard for Monitoring Location (NTU):			0.30		0.30		0.30		0.30		0.30		0.30		0.30		0.30	
Number of measurements meeting standard, B:			18		18		14		18		17		17		17		18	
Compliance with Turbidity Standard, C= B/A X 100%:			100%		100%		100%		100%		100%		100%		100%		100%	

NS: No Sample NA: Not Analyzed OL: Off-Line

Comments:

Report Compiled By: H.Demchenko

Authorized in Sample Manager By: C.Diduck

Date Authorized: 6-Jun-19



**WATER TREATMENT PLANT FREE CHLORINE ON-LINE MONITORING REPORT**  
**Deacon Booster Pumping Station**

Water System Code: **252.00**

Licence Number: **PWS-09-412-01**

Report Created: 01 June 2019

Report Period: May 2019

Date	BRANCH 1 [mg/L]		BRANCH 2 [mg/L]	
	Average	Minimum	Average	Minimum
01/05/2019	1.14	1.01	1.09	1.03
02/05/2019	1.03	0.92	1.07	0.99
03/05/2019	1.05	0.96	1.08	0.92
04/05/2019	1.13	1.00	1.13	1.01
05/05/2019	1.12	0.93	1.06	0.98
06/05/2019	1.13	0.98	1.04	0.98
07/05/2019	1.12	0.98	0.99	0.94
08/05/2019	1.11	0.98	0.97	0.93
09/05/2019	1.10	0.97	0.98	0.89
10/05/2019	1.10	0.92	1.13	0.93
11/05/2019	1.13	1.04	1.19	1.11
12/05/2019	1.09	0.95	1.16	1.04
13/05/2019	1.12	0.91	1.14	1.03
14/05/2019	1.17	1.08	1.13	0.99
15/05/2019	1.18	1.10	1.12	1.03
16/05/2019	1.15	1.08	1.13	1.05
17/05/2019	1.16	1.05	1.15	1.01
18/05/2019	1.11	1.01	1.07	0.98
19/05/2019	1.08	0.97	1.00	0.90
20/05/2019	1.07	0.98	0.98	0.92
21/05/2019	1.04	0.95	1.02	0.94
22/05/2019	1.03	0.98	1.07	1.02
23/05/2019	1.03	0.96	1.05	0.96
24/05/2019	1.14	0.99	1.13	0.99
25/05/2019	1.19	1.14	1.18	1.13
26/05/2019	1.19	1.13	1.12	1.04
27/05/2019	1.14	1.00	1.08	1.00
28/05/2019	1.10	0.83	1.06	0.74
29/05/2019	1.24	1.10	1.18	1.07
30/05/2019	1.21	1.11	1.16	1.09
31/05/2019	1.14	0.79	1.10	0.78

Total Number of Measurements, A: 21612 21612

Minimum Free Chlorine Standard: 0.5 0.5

Number of Measurements Meeting Standard, B: 21612 21612

COMPLIANCE, C = B/A X 100%: 100.00 100.00

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Chlorine\2019\05-May

Submitted By (Print): D.Merredew

Signature: Original signed by D.Merredew



CITY OF WINNIPEG  
WATER AND WASTE DEPARTMENT  
ENVIRONMENTAL STANDARDS DIVISION

**WATER TREATMENT PLANT CHLORINE GRAB MONITORING REPORT**

Water System Code: 252.00	Deacon Booster Pumping Station Branch 1			Deacon Booster Pumping Station Branch 2		
Licence No. PWS-09-412-01	Free Chlorine (mg/L)		Total Chlorine (mg/L)	Free Chlorine (mg/L)		Total Chlorine (mg/L)
Date	Analyser	Grab	Grab	Analyser	Grab	Grab
01-May-2019	1.21	1.22	1.35	1.12	1.11	1.23
02-May-2019	1.07	1.02	1.22	1.19	1.14	1.23
03-May-2019	1.06	1.07	1.20	1.15	1.05	1.17
04-May-2019	NA	NA	NA	NA	NA	NA
05-May-2019	NA	NA	NA	NA	NA	NA
06-May-2019	1.12	1.15	1.32	1.05	1.12	1.23
07-May-2019	1.10	1.14	1.36	0.97	1.04	1.23
08-May-2019	1.08	1.12	1.28	1.03	1.03	1.15
09-May-2019	1.15	1.11	1.26	0.92	0.96	1.08
10-May-2019	1.14	1.21	1.33	1.22	1.28	1.37
11-May-2019	NA	NA	NA	NA	NA	NA
12-May-2019	NA	NA	NA	NA	NA	NA
13-May-2019	1.14	1.16	1.32	1.14	1.17	1.32
14-May-2019	1.16	1.14	1.29	1.10	1.03	1.32
15-May-2019	1.22	1.17	1.30	1.16	1.12	1.28
16-May-2019	1.15	1.12	1.29	1.14	1.13	1.29
17-May-2019	1.17	1.12	1.29	1.15	1.07	1.29
18-May-2019	NA	NA	NA	NA	NA	NA
19-May-2019	NA	NA	NA	NA	NA	NA
20-May-2019	NA	NA	NA	NA	NA	NA
21-May-2019	1.06	1.01	1.19	1.03	0.99	1.11
22-May-2019	1.02	1.04	1.18	1.05	1.04	1.21
23-May-2019	1.03	1.01	1.18	1.01	1.06	1.18
24-May-2019	1.08	1.12	1.25	1.09	1.12	1.26
25-May-2019	NA	NA	NA	NA	NA	NA
26-May-2019	NA	NA	NA	NA	NA	NA
27-May-2019	1.05	1.10	1.24	1.01	1.17	1.29
28-May-2019	1.13	1.14	1.27	1.09	1.15	1.31
29-May-2019	1.28	1.23	1.45	1.30	1.30	1.45
30-May-2019	1.19	1.22	1.45	1.14	1.24	1.40
31-May-2019	1.30	1.26	1.44	1.25	1.25	1.42
<b>Total number of measurements taken, A:</b>	22				22	
<b>Chlorine Standard for Monitoring Location (mg/L):</b>					0.50	
<b>Number of measurements meeting standard, B:</b>					22	
<b>Compliance with Chlorine Standard, C= B/A X 100%:</b>					100%	

NS: No Sample    NA: Not Analyzed    OL: Off-Line

Comments:

Report Compiled By: \_\_\_\_\_ H.Demchenko

Authorized By: \_\_\_\_\_ C.Diduck



**CITY OF WINNIPEG**  
WATER AND WASTE DEPARTMENT  
WATER SERVICES

Water System Code: 252.00  
Licence Number: PWS-09-412-01

WATER TREATMENT PLANT UV REPORT

Report Period: May 2019

Report Created: Saturday, June 01, 2019

Date	Transmittance %	UVR-D100A				UVR-D200A				UVR-D300A				UVR-D400A				UVR-D500A				UVR-D600A				Total				% Volume Treated To Dose	
		Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]					
		Untreated	Below	To	Total	Untreated	Below	To	Total																						
01/05/2019	96.09	0.00	0.00	23.85	23.85	0.00	0.00	55.42	55.42	0.00	0.00	0.00	0.00	0.00	0.00	54.07	54.07	0.00	0.00	61.82	61.82	0.00	0.00	0.00	0.00	0.00	0.00	0.00	195.16	195.16	100.00
02/05/2019	96.14	0.00	0.00	74.40	74.40	0.00	0.00	2.19	2.19	0.00	0.00	17.97	17.97	0.00	0.00	36.40	36.40	0.00	0.00	41.35	41.35	0.00	0.00	22.71	22.71	0.00	0.00	195.01	195.01	100.00	
03/05/2019	96.14	0.00	0.00	74.91	74.91	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	53.94	53.94	0.00	0.00	0.00	0.00	0.00	0.00	62.39	62.39	0.00	0.00	191.24	191.24	100.00	
04/05/2019	96.14	0.00	0.00	42.87	42.87	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	61.36	61.36	0.00	0.03	16.65	16.68	0.00	0.00	63.18	63.18	0.00	0.03	184.06	184.09	99.98	
05/05/2019	96.12	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	67.99	67.99	0.00	0.00	40.59	40.59	0.00	0.00	73.29	73.29	0.00	0.00	181.87	181.87	100.00	
06/05/2019	95.52	0.00	0.00	0.00	0.00	0.00	0.00	32.30	32.30	0.00	0.00	0.00	0.00	0.00	0.00	56.75	56.75	0.00	0.00	22.52	22.52	0.00	0.10	70.34	70.45	0.00	0.10	181.91	182.01	99.94	
07/05/2019	96.12	0.00	0.00	0.00	0.00	0.00	0.00	71.96	71.96	0.00	0.00	0.00	0.00	0.00	0.00	44.49	44.49	0.00	0.00	0.00	0.00	0.00	0.00	65.56	65.56	0.00	0.00	182.00	182.00	100.00	
08/05/2019	96.05	0.00	0.00	0.00	0.00	0.00	0.00	74.21	74.21	0.00	0.00	0.00	0.00	0.00	0.00	45.29	45.29	0.00	0.00	0.00	0.00	0.00	0.00	68.75	68.75	0.00	0.00	188.24	188.24	100.00	
09/05/2019	96.04	0.00	0.00	30.00	30.00	0.00	0.00	43.99	43.99	0.00	0.00	30.53	30.53	0.00	0.00	19.07	19.07	0.00	0.38	0.06	0.44	0.00	0.05	69.96	70.00	0.00	0.42	193.61	194.03	99.78	
10/05/2019	96.00	0.00	0.00	60.29	60.29	0.00	0.00	11.80	11.80	0.00	0.00	47.75	47.75	0.00	0.00	0.00	0.00	47.10	47.10	0.00	0.00	27.08	27.08	0.00	0.00	194.02	194.02	100.00			
11/05/2019	95.90	0.00	0.00	71.73	71.73	0.00	0.00	0.00	0.00	0.00	0.00	48.00	48.00	0.00	0.00	0.00	0.00	74.48	74.48	0.00	0.00	0.00	0.00	0.00	0.00	194.21	194.21	100.00			
12/05/2019	95.90	0.00	0.00	71.83	71.83	0.00	0.00	0.00	0.00	0.00	0.00	48.02	48.02	0.00	0.00	0.00	0.00	74.59	74.59	0.00	0.00	0.00	0.00	0.00	0.00	194.43	194.43	100.00			
13/05/2019	95.57	0.00	0.00	23.12	23.12	0.00	0.00	52.73	52.73	0.00	0.00	15.69	15.69	0.00	0.00	31.22	31.22	0.00	0.00	72.23	72.23	0.00	0.00	0.00	0.00	0.00	0.00	194.98	194.98	100.00	
14/05/2019	96.00	0.00	0.00	0.00	0.00	0.00	0.00	78.37	78.37	0.00	0.00	0.00	0.00	0.00	0.00	47.30	47.30	0.00	0.00	71.74	71.74	0.00	0.00	0.00	0.00	0.00	0.00	197.41	197.41	100.00	
15/05/2019	96.01	0.00	0.00	0.00	0.00	0.00	0.00	79.76	79.76	0.00	0.00	0.00	0.00	0.00	0.00	48.97	48.97	0.00	0.00	74.05	74.05	0.00	0.00	0.00	0.00	0.00	0.00	202.79	202.79	100.00	
16/05/2019	95.47	0.00	0.00	0.00	0.00	0.00	0.00	80.41	80.41	0.00	0.00	0.00	0.00	0.00	0.00	49.30	49.30	0.00	0.00	74.95	74.95	0.00	0.00	0.00	0.00	0.00	0.00	204.65	204.65	100.00	
17/05/2019	95.37	0.00	0.00	0.00	0.00	0.00	0.00	79.91	79.91	0.00	0.00	0.00	0.00	0.00	0.00	48.93	48.93	0.00	0.00	74.17	74.17	0.00	0.00	0.00	0.00	0.00	0.00	203.01	203.01	100.00	
18/05/2019	95.88	0.00	0.00	0.00	0.00	0.00	0.00	78.24	78.24	0.00	0.00	0.00	0.00	0.00	0.00	47.99	47.99	0.00	0.00	71.77	71.77	0.00	0.00	0.00	0.00	0.00	0.00	198.00	198.00	100.00	
19/05/2019	95.88	0.00	0.00	0.00	0.00	0.00	0.00	73.25	73.25	0.00	0.00	0.00	0.00	0.00	0.00	44.82	44.82	0.00	0.00	65.91	65.91	0.00	0.00	0.00	0.00	0.00	0.00	183.98	183.98	100.00	
20/05/2019	95.90	0.00	0.00	0.00	0.00	0.00	0.00	69.50	69.50	0.00	0.00	0.00	0.00	0.00	0.00	42.24	42.24	0.00	0.00	61.97	61.97	0.00	0.00	0.00	0.00	0.00	0.00	173.72	173.72	100.00	
21/05/2019	95.87	0.00	0.00	25.79	25.79	0.00	0.00	69.74	69.74	0.00	0.00	0.00	0.00	0.03	0.03	23.47	23.54	0.00	0.00	71.32	71.32	0.00	0.00	0.00	0.00	0.03	0.03	190.32	190.39	99.96	
22/05/2019	95.88	0.00	0.00	55.43	55.43	0.00	0.00	66.88	66.88	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	78.40	78.40	0.00	0.00	0.00	0.00	0.00	0.00	200.72	200.72	100.00	
23/05/2019	95.85	0.00	0.00	56.18	56.18	0.00	0.00	67.25	67.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	78.84	78.84	0.00	0.00	0.00	0.00	0.00	0.00	202.28	202.28	100.00	
24/05/2019	95.73	0.00	0.00	55.48	55.48	0.00	0.00	66.50	66.50	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	78.01	78.01	0.00	0.00	0.00	0.00	0.00	0.00	199.99	199.99	100.00	
25/05/2019	95.91	0.00	0.00	55.44	55.44	0.00	0.00	66.55	66.55	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	78.01	78.01	0.00	0.00	0.00	0.00	0.00	0.00	200.00	200.00	100.00	
26/05/2019	95.96	0.00	0.00	55.34	55.34	0.00	0.00	66.62	66.62	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	78.03	78.03	0.00	0.00	0.00	0.00	0.00	0.00	199.99	199.99	100.00	
27/05/2019	95.77	0.00	0.00	62.49	62.49	0.00	0.00	26.77	26.77	0.00	0.00	33.35	33.35	0.00	0.00	0.71	0.71	0.00	0.00	76.65	76.65	0.00	0.00	0.00	0.00	0.00	0.00	199.98	199.98	100.00	
28/05/2019	94.94	0.00	0.00	64.03	64.04	0.00	0.00	0.00	0.00	0.10	0.10	44.48	44.68	0.00	0.00	0.00	0.00	0.00	0.00	59.83	59.83	0.00	0.00	0.00	0.00	0.10	0.10	168.34	168.54	99.88	
29/05/2019	94.99	0.00	0.00	34.86	34.86	0.00	0.00	47.35	47.35	0.00	0.00	57.43	57.43	0.00	0.00	0.00	0.00	0.00	0.00	70.50	70.50	0.00	0.00	0.00	0.00	0.00	0.00	210.14	210.14	100.00	
30/05/2019	94.80	0.00	0.00	0.00	0.00	0.00	0.00	85.00	85.00	0.00	0.00	60.17	60.17	0.00	0.00	0.00	0.00	0.00	0.00	73.56	73.56	0.00	0.00	0.00	0.00	0.00	0.00	218.72	218.72	100.00	
31/05/2019	95.22	0.00	0.00	0.00	0.00	0.00	0.00	85.01	85.01	0.00	0.00	64.12	64.12	0.00	0.00	0.00	0.00	0.00	0.00	77.41	77.41	0.00	0.00	0.00	0.00	0.00	0.00	226.54	226.54	100.00	

Total [ML]: 0.00 0.00 938.03 938.04 0.00 0.00 1531.71 1531.71 0.10 0.10 467.50 467.69 0.03 0.03 824.31 824.38 0.00 0.00 41 1766.53 1766.94 0.00 0.00 15 523.25 523.40 0.14 0.69 6051.34 6052.17