



Water and Waste Eaux et déchets

Derek Clarke, Drinking Water Officer
Office of Drinking Water, Manitoba Sustainable Development
Box 6000
Gimli, MB R0C 1B0

June 4, 2020

RE: MAY 2020 WATER QUALITY COMPLIANCE SUBMISSION FOR THE CITY OF WINNIPEG WATER SUPPLY SYSTEM

Please find attached on-line and grab turbidity summary reports, on-line and grab chlorine summary reports and the UV summary report for the Water Treatment Plant for May 2020.

The May on-line and grab sampling turbidity reports include results obtained for the Water Treatment Plant raw water and the eight filters. The turbidity results for the filter effluent met the licence requirements.

The May on-line and grab sampling chlorine reports include results obtained for the Deacon Booster Pumping Station at the Water Treatment Plant. The free chlorine results at the Water Treatment Plant met the licence requirements.

The May UV summary report includes results obtained for the six UV reactors at the Water Treatment Plant. The UV disinfection results met the licence requirements.

Please let me know of any concerns or questions respecting this submission. I can be reached by telephone at 204-986-8359 or by e-mail at rgrosselle@winnipeg.ca.

Yours sincerely,

Original signed by R. Grosselle
(Signed original available upon request)

R. Grosselle
Manager of Environmental Standards

Enclosures

cc: Dr. L. Richards, Winnipeg Regional Health Authority (email)
Dr. H. Chang, Winnipeg Regional Health Authority (email)
Dr. S. Roberecki, Manitoba Health, Seniors and Active Living (email)
M. L. Geer, CPA, CA (email)
G. Patton, P.Eng. (email)
T. Shanks, P.Eng. (email)
M. Szmon, P.Eng. (email)
B. Bradford (email)



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
WATER SERVICES

Water System Code: 252.00
Licence Number: PWS-09-412-01

WATER TREATMENT PLANT TURBIDITY ON-LINE MONITORING REPORT

May 2020 Turbidity (NTU)

Date	Raw		Filter #1		Filter #2		Filter #3		Filter #4		Filter #5		Filter #6		Filter #7		Filter #8	
	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max
1/05/2020	0.74	0.03	0.05	0.02	0.04	0.03	0.05	0.04	0.08	0.00	0.04	0.02	0.04	0.04	0.11	0.06	0.09	
2/05/2020	0.81	0.07	0.22	0.04	0.19	0.04	0.22	0.05	0.18	0.00	0.08	0.02	0.08	0.05	0.16	0.05	0.11	
3/05/2020	0.83	0.06	0.11	0.04	0.06	0.03	0.09	0.08	0.12	0.00	0.03	0.04	0.07	0.10	0.12	0.06	0.11	
4/05/2020	0.79	0.05	0.10	0.02	0.06	0.03	0.07	0.12	0.17	0.00	0.02	0.04	0.08	0.09	0.16	0.10	0.14	
5/05/2020	0.94	0.04	0.06	0.02	0.04	0.05	0.07	0.10	0.19	0.00	0.03	0.04	0.08	0.06	0.15	0.03	0.12	
6/05/2020	1.05	0.04	0.10	0.03	0.06	0.04	0.09	0.11	0.20	0.00	0.05	0.05	0.12	0.04	0.07	0.02	0.06	
7/05/2020	0.98	0.04	0.11	0.02	0.07	0.04	0.10	0.15	0.19	0.00	0.05	0.04	0.09	0.05	0.10	0.02	0.06	
8/05/2020	0.98	0.03	0.10	0.01	0.05	0.04	0.09	0.06	0.18	0.01	0.03	0.04	0.09	0.04	0.09	0.03	0.06	
9/05/2020	0.95	0.04	0.06	0.01	0.04	0.04	0.08	0.04	0.10	0.00	0.04	0.04	0.09	0.03	0.10	0.02	0.06	
10/05/2020	1.00	0.03	0.08	0.01	0.04	0.03	0.09	0.04	0.08	0.00	0.02	0.05	0.10	0.04	0.07	0.02	0.06	
11/05/2020	0.98	0.03	0.09	0.01	0.05	0.03	0.07	0.06	0.10	0.00	0.02	0.04	0.10	0.05	0.11	0.03	0.06	
12/05/2020	0.97	0.04	0.06	0.01	0.05	0.04	0.05	0.02	0.10	0.00	0.06	0.04	0.09	0.04	0.15	0.03	0.09	
13/05/2020	0.87	0.05	0.10	0.01	0.03	0.03	0.07	0.01	0.05	0.00	0.03	0.04	0.10	0.04	0.12	0.03	0.06	
14/05/2020	0.89	0.04	0.09	0.01	0.07	0.03	0.08	0.01	0.04	0.00	0.04	0.05	0.08	0.05	0.08	0.03	0.07	
15/05/2020	0.88	0.04	0.09	0.01	0.05	0.03	0.09	0.01	0.07	0.00	0.02	0.04	0.09	0.05	0.12	0.04	0.08	
16/05/2020	0.91	0.06	0.09	0.02	0.06	0.06	0.07	0.01	0.07	0.00	0.04	0.04	0.10	0.05	0.11	0.03	0.07	
17/05/2020	0.93	0.07	0.11	0.03	0.06	0.04	0.10	0.02	0.07	0.00	0.07	0.06	0.11	0.05	0.09	0.03	0.08	
18/05/2020	0.83	0.05	0.12	0.02	0.06	0.04	0.10	0.02	0.07	0.00	0.03	0.05	0.14	0.08	0.10	0.03	0.07	
19/05/2020	0.85	0.06	0.12	0.03	0.08	0.05	0.10	0.02	0.22	0.00	0.09	0.05	0.14	0.06	0.12	0.04	0.08	
20/05/2020	0.88	0.07	0.10	0.04	0.10	0.07	0.10	0.03	0.12	0.02	0.08	0.05	0.20	0.07	0.14	0.04	0.09	
21/05/2020	0.94	0.10	0.14	0.07	0.11	0.07	0.12	0.03	0.10	0.04	0.12	0.06	0.12	0.11	0.16	0.04	0.09	
22/05/2020	1.00	0.07	0.16	0.06	0.14	0.05	0.14	0.05	0.13	0.05	0.12	0.08	0.14	0.11	0.19	0.04	0.11	
23/05/2020	1.01	0.06	0.13	0.03	0.09	0.04	0.10	0.08	0.15	0.05	0.10	0.03	0.12	0.05	0.07	0.05	0.18	
24/05/2020	1.07	0.04	0.10	0.03	0.07	0.04	0.07	0.08	0.21	0.05	0.10	0.03	0.13	0.04	0.08	0.07	0.11	
25/05/2020	1.11	OL	OL	0.02	0.07	0.04	0.07	0.06	0.13	0.04	0.14	0.04	0.30	0.05	0.10	0.05	0.12	
26/05/2020	1.09	OL	OL	0.00	0.06	0.03	0.06	0.06	0.25	0.01	0.05	0.03	0.11	0.06	0.11	0.02	0.06	
27/05/2020	1.78	OL	OL	0.00	0.04	0.03	0.05	0.07	0.23	0.01	0.04	0.03	0.11	0.06	0.11	0.02	0.08	
28/05/2020	1.47	OL	OL	0.00	0.03	0.03	0.06	0.07	0.13	0.01	0.04	0.03	0.11	0.06	0.11	0.03	0.10	
29/05/2020	1.10	OL	OL	0.00	0.04	0.03	0.05	0.06	0.12	0.00	0.05	0.03	0.14	0.06	0.10	0.02	0.07	
30/05/2020	0.97	OL	OL	0.00	0.03	0.03	0.05	0.07	0.12	0.01	0.06	0.04	0.10	0.07	0.11	0.02	0.09	
31/05/2020	0.87	OL	OL	0.00	0.02	0.02	0.04	0.07	0.12	0.01	0.07	0.04	0.12	0.08	0.13	0.03	0.08	

Total Number of Measurements Taken, A: 9603 12662 13791 15119 9530 15724 14861 15890
Turbidity Standard for Monitoring Location (NTU): 0.3 0.3 0.3 0.3 0.3 0.3 0.3 0.3
Number of Measurements Meeting Standard, B: 9603 12662 13791 15119 9530 15724 14861 15890
Compliance with Turbidity Standard, C = B/A X 100%: 100.000% 100.000% 100.000% 100.000% 100.000% 100.000% 100.000% 100.000%

OL - Off Line

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Turbidity\2020\05-May

Submitted By (Print): D. Merredew

Signature: Original signed by D.Merredew



WATER TREATMENT PLANT TURBIDITY GRAB MONITORING REPORT

Water System Code: 252.00		Turbidity (NTU)																	
Licence No. PWS-09-412-01		Raw Water		Filter 1		Filter 2		Filter 3		Filter 4		Filter 5		Filter 6		Filter 7		Filter 8	
Date		Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser
01-May-2020		0.77	0.71	0.09	0.05	0.08	0.03	0.11	0.05	OL	OL	0.06	0.01	0.14	0.02	OL	OL	0.07	0.07
02-May-2020		NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
03-May-2020		NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
04-May-2020		0.56	0.80	0.08	0.09	0.08	0.05	0.08	0.05	0.09	0.12	0.07	0.00	0.07	0.07	0.07	0.11	0.06	0.10
05-May-2020		0.56	0.89	0.09	0.05	0.07	0.03	0.08	0.05	0.09	0.16	0.07	0.01	0.07	0.06	0.06	0.12	0.06	0.02
06-May-2020		0.62	1.01	0.09	0.06	0.10	0.03	0.10	0.06	0.09	0.16	0.07	0.01	0.07	0.08	0.06	0.05	0.06	0.02
07-May-2020		0.61	0.95	OL	OL	OL	OL	0.09	0.06	0.09	0.17	0.08	0.01	0.09	0.07	0.08	0.05	0.10	0.02
08-May-2020		0.83	0.94	0.08	0.05	0.07	0.02	0.11	0.05	0.10	0.16	0.10	0.02	OL	OL	OL	OL	0.08	0.03
09-May-2020		NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
10-May-2020		NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
11-May-2020		0.60	0.96	0.08	0.05	0.08	0.03	0.06	0.04	0.10	0.06	0.06	0.00	0.07	0.06	0.07	0.05	0.07	0.03
12-May-2020		0.55	0.93	0.07	0.06	0.07	0.02	0.07	0.05	0.08	0.02	0.07	0.01	0.07	0.05	0.07	0.06	0.07	0.03
13-May-2020		0.59	0.79	0.08	0.06	0.07	0.02	0.07	0.05	0.06	0.01	0.07	0.00	0.07	0.06	0.06	0.05	0.07	0.04
14-May-2020		0.82	0.83	OL	OL	0.08	0.02	OL	OL	0.07	0.02	0.10	0.00	0.09	0.07	0.09	0.05	0.08	0.03
15-May-2020		0.65	0.81	0.09	0.06	OL	OL	0.10	0.05	0.08	0.02	0.08	0.00	OL	OL	0.08	0.06	0.06	0.03
16-May-2020		NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
17-May-2020		NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
18-May-2020		NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
19-May-2020		0.56	0.92	0.07	0.08	0.06	0.04	0.06	0.07	0.08	0.03	0.06	0.00	0.08	0.07	0.07	0.09	0.06	0.04
20-May-2020		0.63	0.82	0.08	0.10	0.07	0.06	0.07	0.08	0.11	0.04	0.07	0.02	0.06	0.08	0.06	0.09	0.07	0.05
21-May-2020		0.67	0.82	0.10	0.12	0.09	0.08	0.11	0.10	0.10	0.04	0.08	0.06	0.08	0.09	0.08	0.13	0.07	0.05
22-May-2020		0.68	0.96	OL	OL	0.12	0.10	OL	OL	0.11	0.07	0.08	0.08	0.10	0.12	0.08	0.17	0.08	0.04
23-May-2020		NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
24-May-2020		0.75	1.02	0.10	0.09	0.08	0.04	0.07	0.05	0.09	0.15	0.08	0.07	0.08	0.05	0.09	0.04	0.10	0.07
25-May-2020		0.62	1.02	OL	OL	0.09	0.05	0.07	0.05	0.12	0.09	0.08	0.07	0.07	0.05	0.08	0.06	0.07	0.09
26-May-2020		NA	NA	OL	OL	NA													
27-May-2020		0.76	1.11	OL	OL	0.08	0.01	0.07	0.03	0.07	0.07	0.08	0.02	0.09	0.04	0.08	0.08	0.09	0.03
28-May-2020		0.87	1.08	OL	OL	0.09	0.00	0.07	0.04	0.10	0.07	0.09	0.02	0.09	0.05	0.09	0.06	OL	OL
29-May-2020		0.69	1.09	OL	OL	0.08	0.00	0.08	0.04	0.12	0.09	0.11	0.02	0.16	0.04	0.10	0.06	OL	OL
30-May-2020		NA	NA	OL	OL	NA													
31-May-2020		0.65	0.90	OL	OL	OL	OL	0.07	0.03	0.08	0.08	0.09	0.01	0.11	0.05	0.08	0.12	0.07	0.02
Total number of measurements taken, A:				13			18			19			20			21			19
Turbidity Standard for Monitoring Location (NTU):				0.30			0.30			0.30			0.30			0.30			0.30
Number of measurements meeting standard, B:				13			18			19			20			21			19
Compliance with Turbidity Standard, C= B/A X 100%:				100%			100%			100%			100%			100%			100%

NS: No Sample NA: Not Analyzed OL: Off-Line NR: No Result IM: Instrument Maintenance

Comments:
Filter 1 was offline for maintenance from May 25-31, 2020.

Report Compiled By: H. Demchenko

Authorized in Sample Manager By: B. Bradford



City Of Winnipeg

Water and Waste Department

Water Services

WATER TREATMENT PLANT FREE CHLORINE ON-LINE MONITORING REPORT
Deacon Booster Pumping Station

Water System Code: **252.00**

Licence Number: **PWS-09-412-01**

Report Created: 01 June 2020

Report Period: May 2020

Date	BRANCH 1 [mg/L]		BRANCH 2 [mg/L]	
	Average	Minimum	Average	Minimum
01/05/2020	1.28	1.19	1.33	1.23
02/05/2020	1.26	0.87	1.28	0.99
03/05/2020	1.21	1.01	1.16	1.07
04/05/2020	1.10	1.03	1.10	1.02
05/05/2020	1.11	1.01	1.10	1.01
06/05/2020	1.11	1.05	1.10	1.03
07/05/2020	1.09	1.05	1.08	1.02
08/05/2020	1.33	0.64	1.12	0.89
09/05/2020	1.10	1.06	1.05	0.98
10/05/2020	1.15	1.10	1.09	1.03
11/05/2020	1.14	1.07	1.15	1.09
12/05/2020	1.14	1.08	1.14	1.02
13/05/2020	1.16	1.07	1.11	1.01
14/05/2020	1.16	1.09	1.14	1.05
15/05/2020	1.13	1.08	1.11	1.03
16/05/2020	1.11	1.09	1.12	1.06
17/05/2020	1.13	1.08	1.11	1.02
18/05/2020	1.24	1.18	1.19	1.13
19/05/2020	1.22	1.11	1.21	1.14
20/05/2020	1.20	1.14	1.23	1.17
21/05/2020	1.16	1.10	1.18	1.08
22/05/2020	1.22	1.12	1.24	1.18
23/05/2020	1.23	1.16	1.25	1.18
24/05/2020	1.22	1.14	1.26	1.19
25/05/2020	1.20	1.10	1.22	1.11
26/05/2020	1.25	1.18	1.24	1.17
27/05/2020	1.23	1.17	1.23	1.16
28/05/2020	1.14	1.05	1.17	0.99
29/05/2020	1.16	1.09	1.14	1.06
30/05/2020	1.18	1.11	1.16	1.11
31/05/2020	1.21	1.15	1.18	1.10

Total Number of Measurements, A: 21583 21600

Minimum Free Chlorine Standard: 0.5 0.5

Number of Measurements Meeting Standard, B: 21583 21600

COMPLIANCE, C = B/A X 100%: 100.00 100.00

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Chlorine\2020\05-May

Submitted By (Print): D. Merredew

Signature: Original signed by D. Merredew



Water and Waste
Eaux et déchets

CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENVIRONMENTAL STANDARDS DIVISION

WATER TREATMENT PLANT CHLORINE GRAB MONITORING REPORT

Water System Code: 252.00	Deacon Booster Pumping Station Branch 1			Deacon Booster Pumping Station Branch 2		
Date	Free Chlorine (mg/L)		Total Chlorine (mg/L)	Free Chlorine (mg/L)		Total Chlorine (mg/L)
	Analyser	Grab	Grab	Analyser	Grab	Grab
01-May-2020	1.33	1.29	1.45	1.30	1.33	1.42
02-May-2020	NA	NA	NA	NA	NA	NA
03-May-2020	NA	NA	NA	NA	NA	NA
04-May-2020	1.11	1.08	1.26	1.16	1.13	1.20
05-May-2020	1.09	1.13	1.33	1.08	1.08	1.30
06-May-2020	1.12	1.17	1.29	1.10	1.13	1.24
07-May-2020	1.10	1.18	1.31	1.10	1.13	1.26
08-May-2020	1.10	1.12	1.28	1.07	1.12	1.25
09-May-2020	NA	NA	NA	NA	NA	NA
10-May-2020	NA	NA	NA	NA	NA	NA
11-May-2020	1.18	1.13	1.34	1.11	1.17	1.29
12-May-2020	1.11	1.06	1.25	1.19	1.13	1.28
13-May-2020	1.16	1.20	1.38	1.09	1.15	1.30
14-May-2020	1.21	1.17	1.37	1.16	1.18	1.37
15-May-2020	1.13	1.16	1.38	1.12	1.18	1.35
16-May-2020	NA	NA	NA	NA	NA	NA
17-May-2020	NA	NA	NA	NA	NA	NA
18-May-2020	NA	NA	NA	NA	NA	NA
19-May-2020	1.25	1.22	1.36	1.22	1.20	1.38
20-May-2020	1.22	1.19	1.38	1.25	1.22	1.33
21-May-2020	1.17	1.12	1.32	1.20	1.20	1.37
22-May-2020	1.20	1.25	1.39	1.22	1.24	1.47
23-May-2020	NA	NA	NA	NA	NA	NA
24-May-2020	1.22	1.23	1.43	1.31	1.31	1.44
25-May-2020	1.17	1.15	1.36	1.18	1.22	1.39
26-May-2020	NA	NA	NA	NA	NA	NA
27-May-2020	1.26	1.20	1.42	1.24	1.27	1.40
28-May-2020	1.14	1.16	1.34	1.19	1.18	1.28
29-May-2020	1.19	1.13	1.33	1.17	1.15	1.33
30-May-2020	NA	NA	NA	NA	NA	NA
31-May-2020	1.20	1.20	1.38	1.16	1.23	1.38
Total number of measurements taken, A:	21				21	
Chlorine Standard for Monitoring Location (mg/L):					0.50	
Number of measurements meeting standard, B:					21	
Compliance with Chlorine Standard, C= B/A X 100%:					100%	

NS: No Sample NA: Not Analyzed OL: Off-Line NR: No Result IM: Instrument Maintenance

Comments:

Report Compiled By: H. Demchenko

Authorized By: B. Bradford



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
WATER SERVICES

WATER TREATMENT PLANT UV REPORT

Report Period: **May 2020**

Water System Code: **252.00**
Licence Number: **PWS-09-412-01**

Report Created: **Monday, June 01, 2020**

Date	Transmittance %		UVR-D100A			UVR-D200A			UVR-D300A			UVR-D400A			UVR-D500A			UVR-D600A			
	UV Tag	Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	Total	
			Water Volume [ML]			Water Volume [ML]			Water Volume [ML]			Water Volume [ML]			Water Volume [ML]			Water Volume [ML]			
01/05/2020	94.28	0.00	0.00	67.09	67.09	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	50.55	0.00	0.00	67.41	0.00	0.00	185.04	
02/05/2020	94.08	0.04	0.04	61.00	61.08	0.00	0.00	0.00	0.03	0.06	32.93	33.02	0.01	0.07	23.88	0.05	0.05	61.67	61.77	0.00	185.04
03/05/2020	94.43	0.00	0.00	59.75	59.75	0.00	0.00	0.00	0.00	0.00	63.15	63.64	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	100.00
04/05/2020	94.58	0.00	0.00	57.50	57.50	0.00	0.00	0.00	0.00	0.00	63.67	63.80	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	99.79
05/05/2020	94.62	0.00	0.05	60.26	60.41	0.00	0.00	0.00	0.00	0.00	56.20	56.37	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	99.73
06/05/2020	94.59	0.00	0.00	67.77	67.77	0.00	0.00	0.00	0.00	0.00	44.41	44.57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	98.91
07/05/2020	94.63	0.00	0.00	68.32	68.32	0.00	0.00	0.00	0.00	0.00	44.32	44.41	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	99.95
08/05/2020	94.52	0.00	0.00	75.23	75.23	0.00	0.00	0.00	0.00	0.00	26.31	26.38	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	99.33
09/05/2020	94.39	0.00	0.00	69.81	69.81	0.00	0.00	0.00	0.00	0.13	46.03	46.16	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	99.33
10/05/2020	94.07	0.00	0.00	70.38	70.38	0.00	0.00	0.00	0.00	0.00	46.70	46.90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	99.89
11/05/2020	93.89	0.00	0.00	70.31	70.31	0.00	0.00	0.00	0.00	0.00	46.66	46.72	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	99.96
12/05/2020	93.78	0.00	0.00	68.73	68.73	0.00	0.00	0.00	0.00	0.00	13	46.57	46.71	0.00	0.00	0.00	0.00	0.00	0.00	0.00	99.33
13/05/2020	93.54	0.00	0.00	69.16	69.16	0.00	0.00	0.00	0.00	0.00	13	45.59	46.72	0.00	0.00	0.00	0.00	0.00	0.00	0.00	99.33
14/05/2020	93.08	0.00	0.00	69.29	69.29	0.00	0.00	0.00	0.00	0.13	45.98	46.12	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	99.33
15/05/2020	92.56	0.00	0.00	69.47	69.47	0.00	0.00	0.00	0.00	0.06	43.34	43.40	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	99.87
16/05/2020	91.77	0.00	0.05	68.60	68.65	0.00	0.00	0.00	0.00	0.06	42.68	42.74	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	99.94
17/05/2020	91.64	0.00	0.00	70.40	70.40	0.00	0.00	0.00	0.00	0.22	43.67	43.89	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	99.88
18/05/2020	91.77	0.00	0.00	71.87	71.87	0.00	0.00	0.00	0.00	0.13	47.19	47.33	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	99.33
19/05/2020	91.03	0.00	0.39	76.78	77.17	0.00	0.00	0.00	0.00	0.24	49.97	50.21	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	99.99
20/05/2020	90.21	0.00	0.11	79.33	79.45	0.00	0.00	0.00	0.00	0.14	50.42	50.57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	99.98
21/05/2020	92.13	0.00	0.56	78.96	79.51	0.00	0.00	0.00	0.00	0.18	51.14	51.32	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	99.85
22/05/2020	93.26	0.00	0.33	78.89	79.23	0.00	0.00	0.00	0.00	0.07	53.04	53.11	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	99.31
23/05/2020	93.04	0.00	0.22	79.01	79.23	0.00	0.00	0.00	0.00	0.07	53.02	53.09	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	99.86
24/05/2020	92.24	0.00	0.33	78.24	78.57	0.00	0.00	0.00	0.00	0.19	52.62	52.81	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	99.76
25/05/2020	93.66	0.00	0.16	74.31	74.48	0.00	0.00	0.00	0.16	0.31	34.28	34.75	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	99.70
26/05/2020	94.10	0.00	0.00	69.64	69.64	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	74.18	0.00	0.00	68.52	0.00	0.00	212.34
27/05/2020	94.15	0.00	0.00	68.60	68.60	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	72.61	0.00	0.00	67.41	0.00	0.00	216.51
28/05/2020	94.19	0.00	0.00	68.81	68.81	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	71.67	0.05	0.05	44.98	0.04	0.04	208.02
29/05/2020	94.33	0.00	0.00	62.31	62.31	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	66.88	0.00	0.00	61.67	0.00	0.00	190.87
30/05/2020	94.45	0.00	0.00	60.78	60.78	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	65.25	0.00	0.00	60.51	0.00	0.00	186.55
31/05/2020	94.47	0.00	0.00	61.05	61.05	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	65.58	0.00	0.00	61.03	0.00	0.00	187.66

Total [ML]: **0.04** **2.35** **2150.05** **2152.44** **0.00** **0.00** **0.00** **0.00** **0.18** **3.66** **1130.88** **1134.73** **0.01** **0.33** **516.49** **516.82** **0.11** **0.11** **1969.50** **1969.71** **0.04** **0.04** **230.25** **230.34** **0.39** **6.48** **5987.17** **6004.04**

Water Volume [%]:
Untreated: **0.01 %**
Below Dose: **0.11 %**
To Dose: **98.89 %**

Notes: **1.** UV Comparative Dose: **18.1 mJ/cm²**

Submitted By (Print): **D.Merradow**

Signature:

Signature: D.Merradow