



Water and Waste
Eaux et déchets

Kale Black, Sr. Drinking Water Officer
Office of Drinking Water, Manitoba Conservation and Climate
309 – 25 Tupper Street North
Portage La Prairie, MB R1N 3K1

May 7, 2021

RE: APRIL 2021 WATER QUALITY COMPLIANCE SUBMISSION FOR THE CITY OF WINNIPEG WATER SUPPLY SYSTEM

Please find attached on-line and grab turbidity summary reports, on-line and grab chlorine summary reports and the UV summary report for the Water Treatment Plant for April 2021.

The April on-line and grab sampling turbidity reports include results obtained for the Water Treatment Plant raw water and the eight filters. On April 2nd the maximum turbidity for Filter 4 was greater than 0.30 NTU; the elevated turbidity occurred for less than 12 consecutive hours. The turbidity results for the filter effluent met the licence requirements.

The April on-line and grab sampling chlorine reports include results obtained for the Deacon Booster Pumping Station at the Water Treatment Plant. On April 8th the Branch 1 free chlorine residual fell below 0.5 mg/L; additional information for this event is provided separately in a Corrective Action Report. With the exception of this event, the free chlorine results at the Water Treatment Plant met the licence requirements.

The April UV summary report includes results obtained for the six UV reactors at the Water Treatment Plant. The UV disinfection results met the licence requirements.

Please let me know of any concerns or questions respecting this submission. I can be reached by telephone at 204-986-8359 or by e-mail at rgrosselle@winnipeg.ca.

Yours sincerely,

Original signed by R. Grosselle
(Signed original available upon request)

R. Grosselle
Manager of Environmental Standards

Enclosures

cc: Dr. L. Richards, Winnipeg Regional Health Authority (email)
Dr. H. Chang, Winnipeg Regional Health Authority (email)
Dr. S. Roberecki, Manitoba Health, Seniors and Active Living (email)
M. L. Geer, CPA, CA (email)
M. Szmon, P.Eng. (email)
C. Diduck (email)



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
WATER SERVICES

Water System Code: 252.00
Licence Number: PWS-09-412-02

WATER TREATMENT PLANT TURBIDITY ON-LINE MONITORING REPORT

April 2021 Turbidity (NTU)

Date	Raw		Filter #1		Filter #2		Filter #3		Filter #4		Filter #5		Filter #6		Filter #7		Filter #8	
	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max
1/04/2021	0.62	0.07	0.13		0.03	0.06	0.01	0.02	0.03	0.09	0.02	0.09	0.07	0.11	0.05	0.06	0.06	0.15
2/04/2021	0.62	0.08	0.10		0.02	0.06	0.01	0.05	0.03	0.43	0.01	0.06	0.06	0.11	0.05	0.10	0.07	0.14
3/04/2021	0.62	0.08	0.12		0.02	0.03	0.01	0.04	0.03	0.05	0.02	0.04	0.05	0.10	0.04	0.08	0.06	0.12
4/04/2021	0.61	0.08	0.12		0.03	0.06	0.01	0.02	0.03	0.07	0.02	0.06	0.06	0.08	0.04	0.08	0.06	0.17
5/04/2021	0.60	0.07	0.10		0.03	0.06	0.01	0.05	0.03	0.07	0.02	0.07	0.06	0.16	0.05	0.07	0.07	0.08
6/04/2021	0.61	0.09	0.12		0.03	0.04	0.01	0.04	0.04	0.05	0.02	0.04	0.04	0.12	0.05	0.09	0.06	0.13
7/04/2021	0.61	0.08	0.12		0.03	0.06	0.01	0.02	0.03	0.07	0.02	0.26	0.07	0.10	0.04	0.05	0.06	0.12
8/04/2021	0.62	0.04	0.09		0.02	0.05	0.01	0.04	0.02	0.04	0.01	0.05	0.04	0.21	0.04	0.08	0.04	0.09
9/04/2021	0.64	0.00	0.00		0.01	0.03	0.01	0.03	0.02	0.03	0.01	0.05	0.03	0.08	0.03	0.05	0.01	0.06
10/04/2021	0.60	0.00	0.00		0.02	0.05	0.01	0.01	0.02	0.04	0.01	0.04	0.04	0.06	0.03	0.07	0.02	0.06
11/04/2021	0.59	0.00	0.00		0.02	0.05	0.01	0.04	0.02	0.06	0.01	0.06	0.04	0.08	0.04	0.06	0.02	0.03
12/04/2021	0.59	0.00	0.00		0.01	0.02	0.01	0.04	0.02	0.03	0.01	0.03	0.03	0.07	0.03	0.07	0.02	0.06
13/04/2021	0.59	0.00	0.00		0.02	0.02	0.01	0.04	0.02	0.07	0.02	0.05	0.03	0.05	0.03	0.07	0.02	0.06
14/04/2021	0.58	0.00	0.00		0.02	0.05	0.01	0.02	0.02	0.09	0.01	0.05	0.04	0.08	0.03	0.04	0.02	0.05
15/04/2021	0.61	O/L	O/L		0.01	0.05	0.01	0.03	0.01	0.11	0.01	0.06	0.03	0.14	0.03	0.10	0.02	0.08
16/04/2021	0.62	O/L	O/L		0.02	0.05	0.01	0.04	0.02	0.06	0.02	0.05	0.04	0.08	0.03	0.07	0.02	0.05
17/04/2021	0.63	O/L	O/L		0.03	0.05	0.01	0.05	0.02	0.07	0.02	0.06	0.04	0.06	0.03	0.07	0.02	0.07
18/04/2021	0.72	O/L	O/L		0.02	0.06	0.01	0.03	0.02	0.06	0.01	0.05	0.04	0.08	0.03	0.06	0.02	0.06
19/04/2021	0.65	O/L	O/L		0.02	0.06	0.01	0.04	0.02	0.06	0.01	0.05	0.04	0.08	0.03	0.06	0.02	0.05
20/04/2021	0.64	O/L	O/L		0.02	0.04	0.01	0.03	0.02	0.04	0.01	0.04	0.03	0.07	0.03	0.05	0.02	0.14
21/04/2021	0.64	O/L	O/L		0.02	0.04	0.01	0.03	0.02	0.03	0.02	0.04	0.03	0.07	0.03	0.05	0.02	0.04
22/04/2021	0.63	O/L	O/L		0.02	0.10	0.01	0.04	0.03	0.09	0.01	0.12	0.03	0.16	0.04	0.24	0.03	0.22
23/04/2021	0.62	O/L	O/L		0.02	0.04	0.01	0.03	0.02	0.04	0.01	0.09	0.02	0.09	0.03	0.05	0.03	0.06
24/04/2021	0.62	O/L	O/L		0.02	0.04	0.01	0.03	0.02	0.04	0.02	0.04	0.00	0.04	0.03	0.05	0.03	0.05
25/04/2021	0.63	O/L	O/L		0.02	0.04	0.01	0.03	0.02	0.04	0.02	0.09	0.00	0.03	0.03	0.20	0.03	0.05
26/04/2021	0.62	O/L	O/L		0.02	0.04	0.01	0.03	0.02	0.04	0.02	0.05	0.00	0.03	0.03	0.05	0.04	0.06
27/04/2021	0.61	O/L	O/L		0.02	0.05	0.01	0.03	0.02	0.03	0.02	0.04	0.00	0.04	0.03	0.06	0.03	0.05
28/04/2021	0.63	O/L	O/L		0.02	0.05	0.01	0.03	0.03	0.05	0.02	0.04	0.00	0.05	0.03	0.06	0.03	0.05
29/04/2021	0.66	O/L	O/L		0.02	0.05	0.01	0.05	0.02	0.04	0.03	0.09	0.02	0.08	0.03	0.06	0.03	0.05
30/04/2021	0.66	O/L	O/L		0.02	0.04	0.01	0.03	0.02	0.04	0.06	0.10	0.06	0.10	0.03	0.05	0.03	0.07

Total Number of Measurements Taken, A: 3049
Turbidity Standard for Monitoring Location (NTU): 0.3
Number of Measurements Meeting Standard, B: 3049
Compliance with Turbidity Standard, C = B/A X 100%: 100.000%
O/L= Offline

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Turbidity\2021\04-April

Submitted By (Print): D.Merredew

Signature: Original signed by D.Merredew



Water and Waste
Eaux et déchets

CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENVIRONMENTAL STANDARDS DIVISION

WATER TREATMENT PLANT TURBIDITY GRAB MONITORING REPORT

Water System Code: 252.00		Turbidity (NTU)																	
Licence No. PWS-09-412-02		Raw Water		Filter 1		Filter 2		Filter 3		Filter 4		Filter 5		Filter 6		Filter 7		Filter 8	
Date		Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser
01-Apr-2021		0.66	0.60	0.07	0.09	0.10	0.05	0.07	0.02	OL	OL	0.08	0.03	0.11	0.08	0.08	0.04	0.08	0.06
02-Apr-2021		NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
03-Apr-2021		NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
04-Apr-2021		NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
05-Apr-2021		NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
06-Apr-2021		0.65	0.56	0.08	0.10	0.07	0.03	0.06	<0.02	0.07	0.04	0.07	0.03	0.09	0.07	0.09	0.05	0.10	0.08
07-Apr-2021		0.70	0.66	0.06	0.09	0.08	0.04	0.06	<0.02	0.08	0.06	0.08	0.04	0.08	0.07	0.07	0.04	0.07	0.06
08-Apr-2021		0.66	0.61	0.05	0.08	0.05	0.03	0.08	0.02	0.05	0.03	0.05	0.03	0.08	0.05	0.07	0.04	0.06	0.06
09-Apr-2021		0.63	0.62	0.07	<0.02	0.06	0.02	0.06	<0.02	0.07	0.02	0.08	<0.02	0.08	0.04	0.06	0.02	OL	OL
10-Apr-2021		NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
11-Apr-2021		NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
12-Apr-2021		0.65	0.57	0.06	<0.02	0.06	0.02	0.08	0.02	0.05	0.03	0.06	<0.02	0.06	0.04	0.09	0.04	0.07	0.02
13-Apr-2021		0.57	0.57	0.07	<0.02	0.05	0.02	0.06	<0.02	0.06	0.03	0.07	0.03	0.07	0.05	0.06	0.02	0.07	<0.02
14-Apr-2021		0.63	0.57	0.06	<0.02	0.08	0.03	0.06	0.02	0.08	0.04	0.06	0.02	0.08	0.05	0.08	0.02	0.08	<0.02
15-Apr-2021		0.57	0.58	OL	OL	0.05	0.02	0.08	0.02	0.06	0.02	0.06	0.03	OL	OL	0.07	0.03	0.07	<0.02
16-Apr-2021		0.64	0.59	OL	OL	0.08	0.03	0.06	<0.02	0.07	0.03	0.08	0.03	0.07	0.05	0.07	0.02	OL	OL
17-Apr-2021		NS	NS	OL	OL	NS													
18-Apr-2021		NS	NS	OL	OL	NS													
19-Apr-2021		0.63	0.61	OL	OL	0.08	0.04	0.07	0.02	0.05	0.02	0.06	0.02	0.09	0.06	0.07	0.03	0.06	<0.02
20-Apr-2021		0.57	0.62	OL	OL	0.05	0.02	0.06	0.02	0.05	0.02	0.05	0.02	0.07	0.05	0.06	0.03	0.06	0.02
21-Apr-2021		0.58	0.63	OL	OL	0.05	0.02	0.07	0.02	0.05	0.02	0.06	0.02	0.06	0.04	0.07	0.03	0.06	0.02
22-Apr-2021		0.64	0.60	OL	OL	0.06	0.02	0.06	0.02	0.06	0.03	0.07	0.02	0.06	0.04	OL	OL	0.08	0.03
23-Apr-2021		0.63	0.60	OL	OL	0.06	0.03	0.06	0.02	0.07	0.04	OL	OL	0.08	0.04	0.06	0.02	0.07	0.02
24-Apr-2021		NS	NS	OL	OL	NS													
25-Apr-2021		NS	NS	OL	OL	NS													
26-Apr-2021		0.61	0.63	OL	OL	0.07	0.03	0.07	0.03	0.06	0.03	0.06	0.03	0.07	<0.02	0.08	0.03	0.08	0.03
27-Apr-2021		0.58	0.57	OL	OL	0.06	0.02	0.07	0.03	0.05	0.03	0.08	0.03	0.07	<0.02	0.09	0.03	0.07	0.03
28-Apr-2021		0.60	0.60	OL	OL	0.06	0.03	0.05	0.02	0.05	0.02	0.07	0.04	0.07	<0.02	0.07	0.03	0.08	0.04
29-Apr-2021		0.61	0.61	OL	OL	0.06	0.02	0.05	<0.02	0.06	0.03	0.07	0.03	0.06	<0.02	0.06	0.02	OL	OL
30-Apr-2021		0.57	0.62	OL	OL	0.06	0.03	0.06	0.02	OL	OL	0.05	0.07	0.06	0.07	0.06	0.03	0.05	0.02
Total number of measurements taken, A:				8		20		20		18		19		19		19		17	
Turbidity Standard for Monitoring Location (NTU):				0.30		0.30		0.30		0.30		0.30		0.30		0.30		0.30	
Number of measurements meeting standard, B:				8		20		20		18		19		19		19		17	
Compliance with Turbidity Standard, C= B/A X 100%:				100%		100%		100%		100%		100%		100%		100%		100%	

NS: No Sample NA: Not Analyzed OL: Off-Line NR: No Result IM: Instrument Maintenance

Comments:

Filter 1 was taken offline for maintenance on April 14th at 4:24 pm and remained offline for the rest of the month.

Compiled By: H.Demchenko

Authorized By: C. Diduck

Report Date: 6-May-21

**City Of Winnipeg**

Water and Waste Department

Water Services

WATER TREATMENT PLANT FREE CHLORINE ON-LINE MONITORING REPORT
Deacon Booster Pumping StationWater System Code: **252.00**Licence Number: **PWS-09-412-02**Report Created: **01 May 2021**

Report Period: April 2021

Date	BRANCH 1 [mg/L]		BRANCH 2 [mg/L]	
	Average	Minimum	Average	Minimum
01/04/2021	1.21	1.10	1.25	1.19
02/04/2021	1.21	1.11	1.22	1.12
03/04/2021	1.29	1.21	1.27	1.23
04/04/2021	1.31	1.21	1.32	1.24
05/04/2021	1.28	1.23	1.33	1.29
06/04/2021	1.29	1.14	1.33	1.18
07/04/2021	1.17	1.09	1.15	1.09
08/04/2021	1.12	0.34	1.13	0.90
09/04/2021	1.12	1.05	1.29	1.18
10/04/2021	1.11	1.04	1.20	1.12
11/04/2021	1.12	1.04	1.23	1.16
12/04/2021	1.06	0.98	1.17	1.10
13/04/2021	1.12	1.02	1.23	1.16
14/04/2021	1.21	1.07	1.36	1.21
15/04/2021	1.07	0.85	1.09	0.79
16/04/2021	1.03	0.87	1.14	0.99
17/04/2021	1.09	0.95	1.20	1.10
18/04/2021	1.03	0.95	1.11	1.02
19/04/2021	1.16	0.68	1.11	0.78
20/04/2021	1.25	1.09	1.26	1.12
21/04/2021	1.16	1.02	1.18	1.11
22/04/2021	1.10	0.81	1.08	0.90
23/04/2021	1.17	1.02	1.15	1.10
24/04/2021	1.14	1.06	1.12	1.09
25/04/2021	1.14	1.01	1.11	1.07
26/04/2021	1.11	0.99	1.19	1.07
27/04/2021	1.07	1.01	1.19	1.15
28/04/2021	1.09	1.02	1.19	1.16
29/04/2021	1.07	0.96	1.15	1.08
30/04/2021	1.09	0.92	1.14	0.99

Total Number of Measurements, A: **20880** 20880Minimum Free Chlorine Standard: **0.5** 0.5Number of Measurements Meeting Standard, B: **20874** 20880COMPLIANCE, C = B/A X 100%: **99.97** 100.00

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Chlorine\2021\04-April

Submitted By (Print): D.MerredewSignature: Original signed by D.Merredew



Water and Waste
Eaux et déchets

CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENVIRONMENTAL STANDARDS DIVISION

WATER TREATMENT PLANT CHLORINE GRAB MONITORING REPORT

Water System Code: 252.00 Licence No. PWS-09-412-02	Deacon Booster Pumping Station Branch 1			Deacon Booster Pumping Station Branch 2		
	Free Chlorine (mg/L)		Total Chlorine (mg/L)	Free Chlorine (mg/L)		Total Chlorine (mg/L)
	Date	Analyser	Grab	Grab	Analyser	Grab
01-Apr-2021	1.18	1.22	1.40	1.22	1.24	1.41
02-Apr-2021	NS	NS	NS	NS	NS	NS
03-Apr-2021	NS	NS	NS	NS	NS	NS
04-Apr-2021	NS	NS	NS	NS	NS	NS
05-Apr-2021	NS	NS	NS	NS	NS	NS
06-Apr-2021	1.28	1.27	1.43	1.33	1.27	1.51
07-Apr-2021	1.18	1.21	1.40	1.14	1.22	1.41
08-Apr-2021	1.15	1.14	1.32	1.22	1.16	1.37
09-Apr-2021	1.07	1.11	1.26	1.40	1.12	1.31
10-Apr-2021	NS	NS	NS	NS	NS	NS
11-Apr-2021	NS	NS	NS	NS	NS	NS
12-Apr-2021	1.05	1.07	1.27	1.21	1.22	1.39
13-Apr-2021	1.10	1.10	1.27	1.20	1.22	1.41
14-Apr-2021	1.22	1.23	1.40	1.38	1.32	1.53
15-Apr-2021	1.11	1.12	1.34	1.19	1.18	1.35
16-Apr-2021	1.09	1.09	1.25	1.21	1.19	1.39
17-Apr-2021	NS	NS	NS	NS	NS	NS
18-Apr-2021	NS	NS	NS	NS	NS	NS
19-Apr-2021	1.21	1.15	1.38	1.17	1.17	1.31
20-Apr-2021	1.24	1.30	1.42	1.29	1.27	1.45
21-Apr-2021	1.16	1.16	1.41	1.18	1.20	1.41
22-Apr-2021	1.11	1.11	1.32	1.10	1.07	1.25
23-Apr-2021	1.14	1.17	1.35	1.13	1.11	1.30
24-Apr-2021	NS	NS	NS	NS	NS	NS
25-Apr-2021	NS	NS	NS	NS	NS	NS
26-Apr-2021	1.02	1.05	1.18	1.14	1.13	1.31
27-Apr-2021	1.07	1.07	1.23	1.18	1.19	1.37
28-Apr-2021	1.11	1.06	1.26	1.20	1.18	1.40
29-Apr-2021	1.09	1.03	1.26	1.17	1.12	1.38
30-Apr-2021	0.98	0.94	1.10	1.05	1.05	1.23
Total number of measurements taken, A:		20			20	
Chlorine Standard for Monitoring Location (mg/L):		0.50			0.50	
Number of measurements meeting standard, B:		20			20	
Compliance with Chlorine Standard, C= B/A X 100%:		100%			100%	

NS: No Sample NA: Not Analyzed OL: Off-Line NR: No Result IM: Instrument Maintenance

Comments:

Compiled By: H. Demchenko

Authorized By: C. Diduck



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
WATER SERVICES

Water System Code: 252.00
Licence Number: PWS-09-412-02

WATER TREATMENT PLANT UV REPORT

Report Period: April 2021

Report Created: Saturday, May 01, 2021

Date	UVR-D100A				UVR-D200A				UVR-D300A				UVR-D400A				UVR-D500A				UVR-D600A				Total				% Volume Treated To Dose	
	Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]					
	Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	To	Total		
01/04/2021	0.00	1.08	69.55	70.63	0.00	0.00	0.00	0.00	0.00	0.00	0.00	50.95	50.95	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	58.57	58.57	0.00	1.08	179.07	180.14	99.40		
02/04/2021	0.00	0.77	68.37	69.13	0.00	0.00	0.00	0.00	0.00	0.00	0.00	49.88	49.88	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	56.99	56.99	0.00	0.77	175.23	176.00	99.56		
03/04/2021	0.00	1.00	67.90	68.90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	49.56	49.56	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	56.98	56.98	0.00	1.00	174.44	175.45	99.43		
04/04/2021	0.00	1.05	67.69	68.74	0.00	0.00	0.00	0.00	0.00	0.00	0.00	49.48	49.48	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	56.28	56.80	0.00	1.56	173.45	175.02	99.11		
05/04/2021	0.00	1.29	67.39	68.67	0.00	0.00	0.00	0.00	0.00	0.00	0.00	49.56	49.56	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	56.06	56.77	0.00	2.00	173.01	175.01	98.86		
06/04/2021	0.00	1.10	67.59	68.69	0.00	0.00	0.00	0.00	0.00	0.00	0.00	49.77	49.77	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	56.02	56.57	0.00	1.65	173.38	175.03	99.06		
07/04/2021	0.00	1.42	67.09	68.52	0.00	0.00	0.00	0.00	0.00	0.00	0.00	49.95	49.95	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	55.98	56.53	0.00	1.97	173.02	174.99	98.87		
08/04/2021	0.01	0.89	61.42	62.32	0.00	0.00	0.00	0.00	0.00	0.00	0.00	47.73	47.75	0.00	0.00	0.00	0.00	0.02	0.81	49.58	50.41	0.04	1.71	158.73	160.48	98.91				
09/04/2021	0.00	0.50	58.80	59.30	0.00	0.00	0.00	0.00	0.00	0.00	0.00	59.80	59.80	0.00	0.00	0.00	0.00	0.00	0.48	56.67	57.15	0.00	0.98	175.27	176.26	99.44				
10/04/2021	0.00	0.49	58.36	58.85	0.00	0.00	0.00	0.00	0.00	0.00	0.00	64.31	64.31	0.00	0.00	0.00	0.00	0.00	0.60	60.74	61.34	0.00	1.09	183.41	184.50	99.41				
11/04/2021	0.00	0.70	58.14	58.84	0.00	0.00	0.00	0.00	0.00	0.00	0.00	64.05	64.05	0.00	0.00	0.00	0.00	0.00	0.47	60.66	61.12	0.00	1.16	182.86	184.02	99.37				
12/04/2021	0.00	1.04	58.48	59.51	0.00	0.00	0.00	0.00	0.00	0.00	0.00	65.01	65.01	0.00	0.00	0.00	0.00	0.00	0.64	61.71	62.35	0.00	1.68	185.20	186.88	99.10				
13/04/2021	0.00	1.35	59.23	60.58	0.00	0.00	0.00	0.00	0.00	0.00	0.00	66.42	66.42	0.00	0.00	38.58	38.58	0.00	0.31	26.58	26.89	0.00	1.65	190.82	192.47	99.14				
14/04/2021	0.00	1.25	56.55	57.79	0.00	0.00	0.00	0.00	0.00	0.00	0.00	63.26	63.26	0.00	0.00	60.87	60.87	0.00	0.00	0.00	0.00	0.00	1.25	180.68	181.93	99.32				
15/04/2021	0.00	0.80	41.67	42.47	0.00	0.00	0.00	0.00	0.00	0.00	0.00	42.27	42.27	0.00	0.00	39.45	39.45	0.00	0.00	0.00	0.00	0.00	0.80	123.39	124.20	99.35				
16/04/2021	0.00	1.03	61.00	62.04	0.00	0.00	0.00	0.00	0.00	0.00	0.00	61.24	61.24	0.00	0.00	59.95	59.95	0.00	0.00	0.00	0.00	0.00	1.03	182.20	183.23	99.44				
17/04/2021	0.00	1.33	58.71	60.04	0.00	0.00	0.00	0.00	0.00	0.00	0.00	59.95	59.95	0.00	0.00	58.02	58.02	0.00	0.00	0.00	0.00	0.00	1.33	176.68	178.01	99.25				
18/04/2021	0.00	1.17	59.13	60.31	0.00	0.00	0.00	0.00	0.00	0.00	0.00	59.84	59.84	0.00	0.00	57.85	57.85	0.00	0.00	0.00	0.00	0.00	1.17	176.83	178.00	99.34				
19/04/2021	0.04	0.84	35.31	36.18	0.00	0.00	55.36	55.36	0.00	0.12	10.73	10.86	0.15	0.15	4.30	4.60	0.00	0.00	64.32	64.32	0.00	0.00	0.00	0.00	0.19	1.11	170.01	171.31	99.24	
20/04/2021	0.00	0.00	0.00	0.00	0.00	0.00	58.33	58.33	0.00	0.96	58.85	59.81	0.00	0.00	0.00	0.00	0.00	0.00	59.88	59.88	0.00	0.00	0.00	0.00	0.00	0.96	177.07	178.03	99.46	
21/04/2021	0.00	0.00	0.00	0.00	0.00	58.10	58.10	0.00	0.87	59.00	59.88	0.00	0.00	0.00	0.00	0.00	0.00	60.49	60.49	0.00	0.00	0.00	0.00	0.00	0.87	177.59	178.46	99.51		
22/04/2021	0.08	0.61	17.84	18.53	0.00	0.00	56.70	56.70	0.02	0.23	21.88	22.13	0.06	0.15	9.38	9.60	0.00	0.00	60.65	60.65	0.00	0.00	0.00	0.00	0.16	0.99	166.46	167.61	99.31	
23/04/2021	0.00	0.87	43.85	44.72	0.00	0.00	63.30	63.30	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	71.96	71.96	0.00	0.00	0.00	0.00	0.00	0.87	179.11	179.98	99.52	
24/04/2021	0.00	0.99	43.74	44.73	0.00	0.00	63.26	63.26	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	71.99	71.99	0.00	0.00	0.00	0.00	0.00	0.99	178.99	179.98	99.45	
25/04/2021	0.00	0.93	45.06	45.98	0.00	0.00	64.61	64.61	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	73.80	73.80	0.00	0.00	0.00	0.00	0.00	0.93	183.46	184.39	99.50	
26/04/2021	0.00	1.30	52.22	53.51	0.00	0.00	17.88	17.88	0.00	0.46	46.92	47.38	0.00	0.00	0.00	0.00	0.00	0.00	67.38	67.38	0.00	0.00	0.00	0.00	0.00	1.75	184.39	186.15	99.06	
27/04/2021	0.00	1.27	54.66	55.93	0.00	0.00	0.00	0.00	0.59	64.30	64.88	0.00	0.00	0.00	0.00	0.00	0.00	64.18	64.18	0.00	0.00	0.00	0.00	0.00	1.86	183.13	184.99	98.99		
28/04/2021	0.00	1.14	55.43	56.58	0.00	0.00	0.00	0.00	0.60	65.47	66.07	0.00	0.00	0.00	0.00	0.00	0.00	66.19	66.19	0.00	0.00	0.00	0.00	0.00	1.74	187.10	188.84	99.08		
29/04/2021	0.00	1.10	55.63	56.74	0.00	0.00	0.00	0.00	0.00	0.00	66.40	66.40	0.00	0.00	0.00	0.00	0.00	0.00	66.88	66.88	0.00	0.00	0.00	0.00	0.00	1.10	188.91	190.02	99.42	
30/04/2021	0.00	1.26	55.49	56.75	0.00	0.00	0.00	0.00	0.00	0.46	65.96	66.43	0.00	0.00	0.00	0.00	0.00	0.00	66.81	66.81	0.00	0.00	0.00	0.00	0.00	1.73	188.26	189.99	99.09	

Notes: 1. UV Comparative Dose: 18.1 mJ/cm²

Submitted By (Print): D.Merredew

Signature: Original signed by D.Merredew

Page 1 of 2

CITY OF WINNIPEG
 WATER AND WASTE DEPARTMENT
 WATER SERVICES

Water System Code: 252.00
 Licence Number: PWS-09-412-02

Report Period: April 2021

Report Created: Saturday, May 01, 2021

WATER TREATMENT PLANT UV REPORT

Date	Transmittance (%)				UVR_D100A			UVR_D200A			UVR_D300A			UVR_D400A			UVR_D500A			UVR_D600A		
	Branch 1		Branch 2		UV Dose [mJ/cm ²]																	
01/04/2021	94.3	93.9	95.5	95.2	16.6	21.7	21.1	OL	OL	OL	OL	OL	OL	20.5	29.1	24.2	OL	OL	OL	18.4	24.8	23.2
02/04/2021	94.6	93.6	95.7	95.3	16.7	23.2	21.1	OL	OL	OL	OL	OL	OL	20.0	28.4	23.8	OL	OL	OL	18.5	24.3	23.2
03/04/2021	94.9	94.5	95.9	95.6	16.8	23.5	21.1	OL	OL	OL	OL	OL	OL	19.2	27.7	23.0	OL	OL	OL	17.8	23.8	22.4
04/04/2021	95.0	94.6	95.8	95.5	16.7	21.8	21.1	OL	OL	OL	OL	OL	OL	18.2	26.3	21.8	OL	OL	OL	17.3	24.1	21.6
05/04/2021	95.1	94.5	95.9	95.4	16.7	21.7	21.1	OL	OL	OL	OL	OL	OL	18.2	24.9	21.4	OL	OL	OL	17.1	22.1	21.2
06/04/2021	95.3	94.8	96.0	95.5	16.5	21.8	21.1	OL	OL	OL	OL	OL	OL	18.3	23.8	21.4	OL	OL	OL	17.2	24.0	21.2
07/04/2021	95.4	94.9	96.1	95.8	16.5	23.3	21.1	OL	OL	OL	OL	OL	OL	18.1	22.8	21.3	OL	OL	OL	17.0	22.1	21.2
08/04/2021	95.7	0.0	96.2	0.0	0.0	79.3	21.3	OL	OL	OL	OL	OL	OL	0.0	69.3	21.3	OL	OL	OL	0.0	97.7	21.5
09/04/2021	95.6	94.7	96.1	95.3	16.4	23.5	21.2	OL	OL	OL	OL	OL	OL	18.2	21.9	21.2	OL	OL	OL	17.2	23.2	21.3
10/04/2021	95.9	94.8	96.3	96.1	16.6	23.2	21.2	OL	OL	OL	OL	OL	OL	18.3	21.9	21.2	OL	OL	OL	17.1	23.1	21.2
11/04/2021	95.8	95.1	96.3	95.4	16.6	22.7	21.2	OL	OL	OL	OL	OL	OL	18.1	22.6	21.2	OL	OL	OL	17.0	23.3	21.2
12/04/2021	96.0	95.4	96.5	96.1	15.6	29.7	21.3	OL	OL	OL	OL	OL	OL	18.3	22.5	21.2	OL	OL	OL	16.9	22.2	21.2
13/04/2021	96.0	95.4	96.4	96.2	15.3	22.7	21.4	OL	OL	OL	OL	OL	OL	18.2	21.8	21.2	27.0	90.9	28.6	0.0	35.8	21.2
14/04/2021	95.8	94.2	96.2	95.4	15.6	22.5	21.4	OL	OL	OL	OL	OL	OL	18.3	21.8	21.2	25.3	29.2	27.5	OL	OL	OL
15/04/2021	95.0	94.3	95.6	94.4	0.0	59.0	21.4	OL	OL	OL	OL	OL	OL	0.0	79.5	21.2	0.0	103.0	25.2	OL	OL	OL
16/04/2021	95.7	95.1	96.3	96.0	15.5	23.1	21.4	OL	OL	OL	OL	OL	OL	18.1	21.9	21.2	23.9	26.5	25.3	OL	OL	OL
17/04/2021	95.5	94.2	96.3	95.9	15.5	22.3	21.4	OL	OL	OL	OL	OL	OL	18.3	21.9	21.2	21.7	28.7	26.4	OL	OL	OL
18/04/2021	95.4	94.8	96.3	95.8	15.5	23.6	21.4	OL	OL	OL	OL	OL	OL	18.3	21.8	21.2	22.5	28.7	26.4	OL	OL	OL
19/04/2021	95.3	89.2	96.3	95.6	0.0	25.4	21.6	0.0	88.1	21.8	0.0	90.3	22.2	0.0	45.5	21.3	0.0	104.0	24.1	OL	OL	OL
20/04/2021	94.2	93.6	95.2	94.7	OL	OL	OL	18.8	23.9	21.3	17.1	22.0	21.2	OL	OL	OL	19.0	24.9	22.7	OL	OL	OL
21/04/2021	94.0	93.4	94.7	94.3	OL	OL	OL	18.7	31.6	21.2	16.9	28.1	21.2	OL	OL	OL	18.5	25.7	21.4	OL	OL	OL
22/04/2021	93.8	92.7	94.5	92.6	0.0	50.1	21.6	0.0	105.6	21.4	0.0	30.5	21.2	0.0	73.0	21.7	0.0	100.7	21.3	OL	OL	OL
23/04/2021	93.8	93.3	94.5	93.9	15.5	22.8	21.6	18.7	21.7	21.2	OL	OL	OL	OL	OL	OL	18.5	23.1	21.2	OL	OL	OL
24/04/2021	93.9	93.3	94.3	93.8	15.5	22.9	21.6	18.8	21.8	21.2	OL	OL	OL	OL	OL	OL	18.5	23.2	21.2	OL	OL	OL
25/04/2021	93.9	93.2	94.2	93.8	15.6	22.7	21.6	18.7	21.9	21.2	OL	OL	OL	OL	OL	OL	18.5	21.8	21.1	OL	OL	OL
26/04/2021	93.7	92.6	93.9	93.6	14.8	24.8	21.5	0.0	37.1	21.3	16.3	89.5	21.2	OL	OL	OL	18.3	22.9	21.2	OL	OL	OL
27/04/2021	93.7	93.3	93.7	93.3	15.8	23.1	21.4	OL	OL	OL	17.1	22.2	21.2	OL	OL	OL	18.3	22.8	21.2	OL	OL	OL
28/04/2021	93.7	93.4	93.5	93.0	15.5	22.7	21.4	OL	OL	OL	17.0	22.1	21.1	OL	OL	OL	18.4	22.8	21.2	OL	OL	OL
29/04/2021	93.7	93.2	93.6	93.0	15.6	22.8	21.4	OL	OL	OL	16.6	22.2	21.1	OL	OL	OL	18.4	21.9	21.2	OL	OL	OL
30/04/2021	93.9	93.4	93.6	92.7	15.3	22.6	21.4	OL	OL	OL	16.8	23.1	21.1	OL	OL	OL	18.2	21.9	21.2	OL	OL	OL

Notes: 1. UV Comparative Dose: 18.1 mJ/cm²

2. OL - Off Line

Submitted By (Print): D.Merredew

Signature: Original signed by D.Merredew

Page 2 of 2