



Water and Waste Eaux et déchets

Kale Black, Sr. Drinking Water Officer
Office of Drinking Water, Manitoba Conservation and Climate
309 – 25 Tupper Street North
Portage La Prairie, MB R1N 3K1

April 7, 2021

RE: MARCH 2021 WATER QUALITY COMPLIANCE SUBMISSION FOR THE CITY OF WINNIPEG WATER SUPPLY SYSTEM

Please find attached on-line and grab turbidity summary reports, on-line and grab chlorine summary reports and the UV summary report for the Water Treatment Plant for March 2021.

The March on-line and grab sampling turbidity reports include results obtained for the Water Treatment Plant raw water and the eight filters. The turbidity results for the filter effluent met the licence requirements.

The March on-line and grab sampling chlorine reports include results obtained for the Deacon Booster Pumping Station at the Water Treatment Plant. The free chlorine results at the Water Treatment Plant met the licence requirements.

The March UV summary report includes results obtained for the six UV reactors at the Water Treatment Plant. The UV disinfection results met the licence requirements.

Please let me know of any concerns or questions respecting this submission. I can be reached by telephone at 204-986-8359 or by e-mail at rgrosselle@winnipeg.ca.

Yours sincerely,

Original signed by R. Grosselle
(Signed original available upon request)

R. Grosselle
Manager of Environmental Standards

Enclosures

cc: Dr. L. Richards, Winnipeg Regional Health Authority (email)
Dr. H. Chang, Winnipeg Regional Health Authority (email)
Dr. S. Roberecki, Manitoba Health, Seniors and Active Living (email)
M. L. Geer, CPA, CA (email)
M. Szmon, P.Eng. (email)
C. Diduck (email)



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
WATER SERVICES

Water System Code: **252.00**
Licence Number: **PWS-09-412-01**

WATER TREATMENT PLANT TURBIDITY ON-LINE MONITORING REPORT

March 2021 Turbidity (NTU)

Date	Raw		Filter #1		Filter #2		Filter #3		Filter #4		Filter #5		Filter #6		Filter #7		Filter #8	
	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max
1/03/2021	0.32	0.07	0.10		0.01	0.05	0.01	0.06	0.06	0.11	0.01	0.02	0.00	0.03	0.05	0.09	0.02	0.07
2/03/2021	0.32	0.06	0.10		0.02	0.02	0.01	0.05	0.08	0.10	0.01	0.04	0.00	0.04	0.05	0.09	0.02	0.07
3/03/2021	0.31	0.06	0.10		0.02	0.05	0.01	0.03	0.06	0.10	0.01	0.05	0.02	0.07	0.04	0.06	0.02	0.06
4/03/2021	0.31	0.06	0.08		0.02	0.06	0.01	0.04	0.06	0.10	0.01	0.07	0.05	0.10	0.05	0.08	0.02	0.04
5/03/2021	0.32	OL	OL		0.02	0.05	0.01	0.04	0.06	0.12	0.01	0.04	0.05	0.10	0.05	0.10	0.02	0.07
6/03/2021	0.32	0.05	0.11		0.02	0.03	0.01	0.05	0.07	0.10	0.01	0.06	0.05	0.07	0.05	0.09	0.02	0.11
7/03/2021	0.33	0.06	0.11		0.02	0.05	0.01	0.02	0.06	0.10	0.01	0.05	0.05	0.09	0.05	0.06	0.02	0.08
8/03/2021	0.34	0.07	0.08		0.01	0.05	0.01	0.05	0.07	0.10	0.00	0.05	0.05	0.09	0.05	0.09	0.03	0.05
9/03/2021	0.37	0.06	0.12		0.02	0.05	0.02	0.10	0.07	0.11	0.02	0.11	0.05	0.30	0.05	0.25	0.03	0.20
10/03/2021	0.36	0.07	0.11		0.02	0.06	0.01	0.05	0.07	0.10	0.01	0.09	0.06	0.26	0.04	0.21	0.02	0.17
11/03/2021	0.38	0.07	0.08		0.01	0.04	0.01	0.06	0.06	0.12	0.01	0.05	0.05	0.09	0.05	0.08	0.03	0.16
12/03/2021	0.37	0.07	0.11		0.01	0.06	0.01	0.04	0.07	0.09	0.01	0.03	0.05	0.09	0.05	0.08	0.03	0.07
13/03/2021	0.39	0.07	0.11		0.02	0.05	0.01	0.02	0.06	0.12	0.01	0.05	0.06	0.07	0.04	0.08	0.03	0.07
14/03/2021	0.39	0.07	0.08		0.02	0.05	0.01	0.04	0.07	0.12	0.01	0.05	0.05	0.09	0.05	0.07	0.03	0.04
15/03/2021	0.41	0.07	0.10		0.02	0.05	0.01	0.04	0.07	0.08	0.01	0.03	0.05	0.10	0.04	0.08	0.03	0.16
16/03/2021	0.41	0.06	0.10		0.02	0.03	0.01	0.04	0.07	0.10	0.01	0.04	0.05	0.07	0.04	0.07	0.03	0.06
17/03/2021	0.42	0.06	0.11		0.01	0.04	0.01	0.03	0.06	0.10	0.00	0.05	0.05	0.09	0.05	0.07	0.02	0.07
18/03/2021	0.43	0.07	0.09		0.01	0.05	0.01	0.06	0.07	0.11	0.01	0.02	0.05	0.10	0.05	0.08	0.04	0.07
19/03/2021	0.44	0.07	0.11		0.02	0.03	0.01	0.05	0.07	0.08	0.02	0.04	0.05	0.10	0.04	0.08	0.03	0.12
20/03/2021	0.44	0.07	0.11		0.02	0.05	0.01	0.02	0.06	0.13	0.02	0.06	0.06	0.08	0.04	0.06	0.03	0.09
21/03/2021	0.44	0.08	0.09		0.01	0.04	0.01	0.04	0.06	0.09	0.02	0.04	0.06	0.11	0.05	0.09	0.04	0.07
22/03/2021	0.46	0.07	0.11		0.01	0.02	0.01	0.04	0.07	0.08	0.02	0.05	0.05	0.07	0.05	0.09	0.04	0.13
23/03/2021	0.48	0.07	0.11		0.01	0.04	0.01	0.02	0.06	0.09	0.01	0.05	0.06	0.09	0.04	0.06	0.03	0.08
24/03/2021	0.51	0.07	0.09		0.01	0.04	0.01	0.04	0.06	0.09	0.01	0.03	0.05	0.08	0.05	0.08	0.04	0.06
25/03/2021	0.98	0.04	0.11		0.01	0.04	0.01	0.05	0.05	0.12	0.01	0.12	0.04	0.17	0.03	0.14	0.02	0.14
26/03/2021	0.53	0.06	0.08		0.02	0.04	0.01	0.03	0.05	0.08	0.00	0.04	0.05	0.09	0.05	0.07	0.05	0.07
27/03/2021	0.54	0.08	0.12		0.02	0.05	0.01	0.04	0.03	0.04	0.01	0.03	0.05	0.09	0.04	0.07	0.04	0.08
28/03/2021	0.56	0.07	0.10		0.02	0.03	0.01	0.03	0.03	0.05	0.01	0.04	0.05	0.08	0.04	0.08	0.05	0.09
29/03/2021	0.57	0.06	0.12		0.02	0.05	0.01	0.02	0.03	0.06	0.01	0.06	0.06	0.09	0.05	0.06	0.05	0.08
30/03/2021	0.61	0.09	0.10		0.02	0.06	0.01	0.05	0.03	0.07	0.02	0.04	0.07	0.13	0.05	0.10	0.07	0.12
31/03/2021	0.62	0.08	0.13		0.02	0.05	0.01	0.05	0.04	0.06	0.02	0.06	0.06	0.07	0.05	0.10	0.06	0.14

Total Number of Measurements Taken, A: 12133 13657 13951 13855 14886 14896 15335 16929
Turbidity Standard for Monitoring Location (NTU): 0.3 0.3 0.3 0.3 0.3 0.3 0.3 0.3
Number of Measurements Meeting Standard, B: 12133 13657 13951 13855 14886 14896 15335 16929
Compliance with Turbidity Standard, C = B/A X 100%: 100.000% 100.000% 100.000% 100.000% 100.000% 100.000% 100.000% 100.000%

OL - Offline

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Turbidity\2021\03-March

Submitted By (Print): D.Merredew

Signature: Original signed by D.Merredew

WATER TREATMENT PLANT TURBIDITY GRAB MONITORING REPORT																		
Water System Code: 252.00		Turbidity (NTU)																
Date	Raw Water		Filter 1		Filter 2		Filter 3		Filter 4		Filter 5		Filter 6		Filter 7		Filter 8	
	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser
01-Mar-2021	0.43	0.32	0.08	0.08	0.07	0.02	0.10	0.04	0.07	0.08	0.09	0.02	0.08	<0.02	0.12	0.06	0.10	0.03
02-Mar-2021	0.42	0.30	0.11	0.10	0.08	0.02	0.11	0.02	0.09	0.09	0.10	0.03	0.09	<0.02	0.09	0.04	0.14	0.04
03-Mar-2021	0.46	0.30	0.09	0.06	0.09	0.02	0.08	0.02	0.09	0.09	0.11	0.03	0.11	<0.02	0.10	0.04	0.08	0.02
04-Mar-2021	0.44	0.30	0.08	0.07	OL	OL	0.11	0.03	0.07	0.07	0.08	<0.02	0.14	0.09	0.10	0.05	0.10	0.02
05-Mar-2021	0.44	0.30	OL	OL	0.07	0.02	OL	OL	0.09	0.08	0.08	0.02	0.08	0.06	0.12	0.07	0.10	0.03
06-Mar-2021	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
07-Mar-2021	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
08-Mar-2021	0.45	0.33	0.08	0.07	0.07	0.02	0.09	0.03	0.07	0.08	0.08	0.02	0.11	0.08	0.09	0.05	0.09	0.02
09-Mar-2021	0.43	0.32	0.09	0.08	0.09	0.02	0.08	0.02	0.08	0.08	0.09	0.02	0.09	0.06	0.20	0.12	0.11	0.04
10-Mar-2021	0.45	0.33	0.08	0.08	0.09	0.03	0.08	0.02	0.08	0.09	0.11	0.04	0.10	0.06	0.10	0.04	0.08	<0.02
11-Mar-2021	0.46	0.34	0.07	0.08	OL	OL	0.07	0.02	0.07	0.08	0.09	<0.02	0.14	0.09	0.13	0.05	0.10	0.02
12-Mar-2021	0.45	0.35	0.08	0.09	0.06	<0.02	0.06	<0.02	0.06	0.08	0.08	0.02	0.10	0.06	OL	OL	0.10	0.04
13-Mar-2021	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
14-Mar-2021	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
15-Mar-2021	0.45	0.39	0.08	0.09	0.07	0.02	0.07	<0.02	0.06	0.07	0.08	<0.02	0.08	0.05	0.10	0.05	0.10	0.03
16-Mar-2021	0.47	0.40	0.10	0.09	0.07	0.02	0.08	0.02	0.07	0.08	0.10	0.03	0.09	0.06	0.08	0.04	0.08	0.02
17-Mar-2021	0.51	0.41	0.09	0.08	0.09	0.03	0.07	0.02	0.09	0.10	0.07	<0.02	0.10	0.06	0.08	0.04	0.09	0.02
18-Mar-2021	0.54	0.40	0.08	0.08	0.07	0.02	0.09	0.04	0.06	0.08	0.08	<0.02	0.12	0.04	0.09	0.09	0.09	0.09
19-Mar-2021	0.51	0.42	0.08	0.09	0.08	0.02	0.07	<0.02	0.09	0.07	0.09	0.02	0.11	0.07	0.13	0.04	OL	OL
20-Mar-2021	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
21-Mar-2021	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
22-Mar-2021	0.52	0.45	0.09	0.09	0.08	0.02	0.06	<0.02	0.07	0.07	0.08	0.03	0.09	0.07	0.09	0.04	0.11	0.06
23-Mar-2021	0.54	0.46	0.09	0.08	0.09	0.03	0.06	<0.02	0.09	0.08	0.08	<0.02	0.10	0.07	0.08	0.04	0.09	0.03
24-Mar-2021	0.58	0.49	0.06	0.08	0.06	0.02	0.09	0.02	0.06	0.07	0.08	<0.02	0.16	0.08	0.10	0.05	0.10	0.04
25-Mar-2021	0.58	0.53	0.09	0.10	0.06	0.02	0.06	<0.02	0.06	0.07	0.08	0.02	0.07	0.06	0.07	0.04	OL	OL
26-Mar-2021	0.59	0.51	0.06	0.08	0.05	0.02	0.08	0.02	0.06	0.08	0.07	<0.02	OL	OL	0.08	0.04	0.07	0.04
27-Mar-2021	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
28-Mar-2021	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
29-Mar-2021	0.60	0.53	0.12	0.08	0.08	0.03	0.08	<0.02	0.09	0.05	0.07	<0.02	0.09	0.07	0.08	0.04	0.07	0.05
30-Mar-2021	0.59	0.57	0.08	0.09	0.06	0.02	0.10	0.04	0.07	0.03	0.08	0.03	0.10	0.07	0.13	0.07	0.11	0.07
31-Mar-2021	0.61	0.61	0.11	0.13	0.07	0.03	0.07	<0.02	0.07	0.05	0.10	0.04	0.10	0.07	0.10	0.04	0.15	0.09
Total number of measurements taken, A:			22		21		22		23		23		22		22		21	
Turbidity Standard for Monitoring Location (NTU):			0.30		0.30		0.30		0.30		0.30		0.30		0.30		0.30	
Number of measurements meeting standard, B:			22		21		22		23		23		22		22		21	
Compliance with Turbidity Standard, C= B/A X 100%:			100%		100%		100%		100%		100%		100%		100%		100%	

NS: No Sample NA: Not Analyzed OL: Off-Line NR: No Result IM: Instrument Maintenance

Comments:

Compiled By: H.Demchenko

Authorized By: C. Diduck

Report Date: 1-Apr-21



City Of Winnipeg

Water and Waste Department

Water Services

WATER TREATMENT PLANT FREE CHLORINE ON-LINE MONITORING REPORT
Deacon Booster Pumping Station

Water System Code: **252.00**

Licence Number: **PWS-09-412-01**

Report Created: 01 April 2021

Report Period: March 2021

Date	BRANCH 1 [mg/L]		BRANCH 2 [mg/L]	
	Average	Minimum	Average	Minimum
01/03/2021	1.11	1.03	1.18	1.13
02/03/2021	1.12	0.99	1.17	1.10
03/03/2021	1.14	1.04	1.15	1.10
04/03/2021	1.12	1.04	1.13	1.07
05/03/2021	1.16	1.02	1.13	1.01
06/03/2021	1.16	1.08	1.12	1.05
07/03/2021	1.11	1.00	1.07	0.99
08/03/2021	1.09	0.99	1.08	1.02
09/03/2021	1.06	0.71	1.05	0.77
10/03/2021	1.10	1.01	1.08	0.96
11/03/2021	1.15	1.06	1.11	1.06
12/03/2021	1.13	1.04	1.12	1.06
13/03/2021	1.21	1.09	1.20	1.14
14/03/2021	1.26	1.16	1.23	1.12
15/03/2021	1.20	1.13	1.15	1.09
16/03/2021	1.23	1.10	1.19	1.06
17/03/2021	1.19	1.12	1.17	1.13
18/03/2021	1.17	1.11	1.16	1.10
19/03/2021	1.21	1.09	1.27	0.99
20/03/2021	1.16	1.01	1.22	1.03
21/03/2021	1.11	1.00	1.10	1.06
22/03/2021	1.14	1.03	1.17	1.08
23/03/2021	1.20	1.13	1.23	1.14
24/03/2021	1.27	1.10	1.30	1.14
25/03/2021	1.28	1.15	1.25	0.88
26/03/2021	1.26	1.15	1.15	1.03
27/03/2021	1.25	1.17	1.18	1.13
28/03/2021	1.23	1.09	1.22	1.15
29/03/2021	1.32	1.17	1.32	1.22
30/03/2021	1.29	1.19	1.28	1.23
31/03/2021	1.21	1.11	1.23	1.19

Total Number of Measurements, A:	21570	21570
Minimum Free Chlorine Standard:	0.5	0.5
Number of Measurements Meeting Standard, B:	21570	21570
COMPLIANCE, C = B/A X 100%:	100.00	100.00

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Chlorine\2021\03-March

Submitted By (Print): D.Merredew

Signature: Original signed by D.Merredew



WATER TREATMENT PLANT CHLORINE GRAB MONITORING REPORT

Water System Code: 252.00	Deacon Booster Pumping Station Branch 1			Deacon Booster Pumping Station Branch 2		
Date	Free Chlorine (mg/L)		Total Chlorine (mg/L)	Free Chlorine (mg/L)		Total Chlorine (mg/L)
	Analyser	Grab	Grab	Analyser	Grab	Grab
01-Mar-2021	1.08	1.17	1.35	1.16	1.22	1.41
02-Mar-2021	1.13	1.17	1.34	1.13	1.13	1.34
03-Mar-2021	1.19	1.18	1.40	1.18	1.16	1.39
04-Mar-2021	1.10	1.21	1.41	1.12	1.24	1.38
05-Mar-2021	1.19	1.19	1.35	1.18	1.17	1.38
06-Mar-2021	NS	NS	NS	NS	NS	NS
07-Mar-2021	NS	NS	NS	NS	NS	NS
08-Mar-2021	1.10	1.11	1.32	1.07	1.10	1.27
09-Mar-2021	1.11	1.13	1.35	1.10	1.12	1.33
10-Mar-2021	1.06	1.07	1.18	1.04	1.06	1.25
11-Mar-2021	1.18	1.16	1.34	1.11	1.16	1.33
12-Mar-2021	1.13	1.13	1.33	1.11	1.14	1.32
13-Mar-2021	NS	NS	NS	NS	NS	NS
14-Mar-2021	NS	NS	NS	NS	NS	NS
15-Mar-2021	1.23	1.18	1.40	1.17	1.17	1.37
16-Mar-2021	1.24	1.23	1.38	1.19	1.16	1.38
17-Mar-2021	1.19	1.16	1.34	1.16	1.11	1.33
18-Mar-2021	1.21	1.18	1.38	1.20	1.20	1.38
19-Mar-2021	1.20	1.14	1.34	1.19	1.12	1.27
20-Mar-2021	NS	NS	NS	NS	NS	NS
21-Mar-2021	NS	NS	NS	NS	NS	NS
22-Mar-2021	1.07	1.16	1.29	1.12	1.21	1.36
23-Mar-2021	1.25	1.17	1.35	1.27	1.21	1.36
24-Mar-2021	1.14	1.25	1.42	1.16	1.33	1.47
25-Mar-2021	1.36	1.30	1.54	1.39	1.31	1.54
26-Mar-2021	1.28	1.35	1.55	1.05	1.35	1.54
27-Mar-2021	NS	NS	NS	NS	NS	NS
28-Mar-2021	NS	NS	NS	NS	NS	NS
29-Mar-2021	1.24	1.25	1.43	1.29	1.33	1.47
30-Mar-2021	1.28	1.25	1.47	1.30	1.27	1.46
31-Mar-2021	1.18	1.20	1.40	1.22	1.21	1.41
Total number of measurements taken, A:	23				23	
Chlorine Standard for Monitoring Location (mg/L):					0.50	
Number of measurements meeting standard, B:					23	
Compliance with Chlorine Standard, C= B/A X 100%:					100%	

NS: No Sample NA: Not Analyzed OL: Off-Line NR: No Result IM: Instrument Maintenance

Comments:

Compiled By: H. Demchenko

Authorized By: C. Diduck



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
WATER SERVICES

Water System Code: 252.00
Licence Number: PWS-09-412-01

WATER TREATMENT PLANT UV REPORT

Report Period: March 2021

Report Created: Tuesday, April 06, 2021

Date	Transmittance %	UVR-D100A				UVR-D200A				UVR-D300A				UVR-D400A				UVR-D500A				UVR-D600A				Total				% Volume Treated To Dose	
		Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]					
Date	UVTavg	Untreated	Below	To	Total	Untreated	Below	To	Total																						
01/03/2021	92.04	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.64	52.43	53.07	0.00	0.10	69.70	69.80	0.00	0.37	74.77	75.14	0.00	0.00	0.00	0.00	0.00	1.10	196.90	198.00	99.44	
02/03/2021	91.96	0.00	0.00	0.00	0.00	0.00	0.00	41.46	41.46	0.00	0.82	60.43	61.25	0.00	0.05	24.58	24.63	0.00	0.33	69.63	69.96	0.00	0.00	0.00	0.00	0.00	1.20	196.11	197.31	99.39	
03/03/2021	91.95	0.00	0.00	0.00	0.00	0.00	0.00	61.44	61.44	0.00	0.96	61.34	62.29	0.00	0.00	0.00	0.00	0.00	0.09	61.96	62.05	0.00	0.00	0.00	0.00	0.00	1.05	184.73	185.78	99.44	
04/03/2021	91.99	0.00	0.00	0.00	0.00	0.00	0.00	61.48	61.48	0.00	0.72	60.34	61.06	0.00	0.00	0.00	0.00	0.00	0.00	60.46	60.46	0.00	0.00	0.00	0.00	0.00	0.72	182.28	183.00	99.61	
05/03/2021	91.96	0.00	0.00	0.00	0.00	0.00	0.00	61.53	61.53	0.00	0.89	60.15	61.04	0.00	0.00	0.00	0.00	0.00	0.08	60.35	60.43	0.00	0.00	0.00	0.00	0.00	0.98	182.03	183.00	99.47	
06/03/2021	91.98	0.00	0.00	0.00	0.00	0.00	0.00	60.27	60.27	0.00	1.22	59.25	60.48	0.00	0.00	0.00	0.00	0.00	0.08	59.78	59.87	0.00	0.00	0.00	0.00	0.00	1.31	179.30	180.61	99.28	
07/03/2021	92.06	0.00	0.00	0.00	0.00	0.00	0.00	59.90	59.90	0.00	0.76	59.62	60.38	0.00	0.00	0.00	0.00	0.00	0.04	59.68	59.73	0.00	0.00	0.00	0.00	0.00	0.80	179.20	180.00	99.56	
08/03/2021	92.04	0.00	0.00	0.00	0.00	0.00	0.00	59.78	59.78	0.00	0.63	59.75	60.38	0.00	0.00	0.00	0.00	0.00	0.13	59.71	59.83	0.00	0.00	0.00	0.00	0.00	0.75	179.25	180.00	99.58	
09/03/2021	91.76	0.05	0.16	25.46	25.68	0.02	0.02	29.64	29.68	0.02	0.35	29.55	29.92	0.02	0.02	19.15	19.18	0.07	0.15	51.59	51.81	0.00	0.00	0.00	0.00	0.17	0.70	155.40	156.27	99.44	
10/03/2021	91.93	0.00	0.24	67.47	67.70	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.09	62.69	62.78	0.00	0.00	62.82	62.82	0.00	0.00	0.00	0.00	0.00	0.32	192.97	193.30	99.83	
11/03/2021	92.04	0.00	0.36	65.40	65.77	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	62.01	62.05	0.00	0.00	60.45	60.45	0.00	0.00	0.00	0.00	0.00	0.41	187.86	188.27	99.78	
12/03/2021	92.18	0.00	0.34	61.79	62.13	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	63.83	63.83	0.00	0.00	62.51	62.51	0.00	0.00	0.00	0.00	0.00	0.34	188.12	188.47	99.82	
13/03/2021	92.12	0.00	0.43	61.33	61.75	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.08	63.97	64.05	0.00	0.00	62.51	62.51	0.00	0.00	0.00	0.00	0.00	0.50	187.81	188.31	99.73	
14/03/2021	92.13	0.00	0.51	60.86	61.37	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	64.79	64.79	0.00	0.00	60.93	60.93	0.00	0.00	0.00	0.00	0.00	0.51	186.58	187.10	99.73	
15/03/2021	92.18	0.00	0.38	60.79	61.18	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.09	64.65	64.74	0.00	0.00	61.05	61.05	0.00	0.00	0.00	0.00	0.00	0.47	186.50	186.97	99.75	
16/03/2021	92.18	0.00	0.21	60.94	61.15	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.09	64.71	64.80	0.00	0.00	61.07	61.07	0.00	0.00	0.00	0.00	0.00	0.30	186.71	187.02	99.84	
17/03/2021	92.24	0.00	0.46	59.92	60.38	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.09	63.44	63.53	0.00	0.00	60.60	60.60	0.00	0.00	0.00	0.00	0.00	0.55	183.96	184.52	99.70	
18/03/2021	92.33	0.00	0.29	59.46	59.75	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.22	61.93	62.14	0.00	0.00	60.11	60.11	0.00	0.00	0.00	0.00	0.00	0.51	181.50	182.00	99.72	
19/03/2021	92.60	0.00	0.40	56.71	57.11	0.00	0.00	9.37	9.37	0.16	0.16	13.65	13.96	0.00	0.04	39.59	39.63	0.00	0.00	62.06	62.06	0.00	0.00	0.00	0.00	0.16	0.60	181.37	182.13	99.58	
20/03/2021	92.65	0.00	0.32	45.35	45.67	0.00	0.00	64.90	64.90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	71.39	71.39	0.00	0.00	0.00	0.00	0.00	0.32	181.64	181.96	99.82	
21/03/2021	92.54	0.00	0.25	44.06	44.30	0.00	0.00	64.71	64.71	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	70.72	70.72	0.00	0.00	0.00	0.00	0.00	0.25	179.49	179.73	99.86	
22/03/2021	92.70	0.00	0.36	49.55	49.90	0.00	0.00	22.94	22.94	0.00	0.00	39.81	39.81	0.00	0.00	0.00	0.00	0.00	0.00	64.04	64.04	0.00	0.00	0.00	0.00	0.00	0.36	176.34	176.69	99.80	
23/03/2021	92.82	0.00	0.22	52.11	52.33	0.01	0.01	8.07	8.09	0.00	0.00	53.78	53.78	0.00	0.00	0.00	0.00	0.00	0.00	61.73	61.73	0.00	0.00	0.00	0.00	0.01	0.23	175.71	175.94	99.87	
24/03/2021	92.77	0.00	0.21	43.75	43.97	0.00	0.00	61.95	61.95	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	69.99	70.04	0.00	0.00	0.00	0.00	0.00	0.26	175.70	175.96	99.85		
25/03/2021	87.12	0.00	0.10	28.73	28.83	0.00	0.00	38.74	38.74	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.19	41.25	41.44	0.00	0.00	0.00	0.00	0.00	0.29	108.73	109.02	99.74		
26/03/2021	92.62	0.00	0.49	49.63	50.12	0.00	0.00	67.50	67.50	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.75	71.61	72.36	0.00	0.00	0.00	0.00	0.00	1.24	188.74	189.98	99.35		
27/03/2021	92.63	0.00	0.59	49.47	50.06	0.00	0.00	67.48	67.48	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.50	71.95	72.45	0.00	0.00	0.00	0.00	0.00	1.09	188.89	189.98	99.43		
28/03/2021	92.61	0.00	0.59	49.26	49.85	0.00	0.00	67.28	67.28	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.20	24.22	24.42	0.00	0.00	48.48	48.48	0.00	0.79	189.24	190.03	99.59		
29/03/2021	93.03	0.00	0.93	59.00	59.94	0.00	0.00	39.16	39.16	0.00	0.00	21.04	21.04	0.00	0.00	0.00	0.00	0.00	0.00	60.71	60.71	0.00	0.00	0.35	69.42	69.78	0.00	1.29	188.62	189.91	99.32
30/03/2021	93.95	0.00	1.00	70.82	71.82	0.00	0.00	0.00	0.00	0.00	0.00	48.77	48.77	0.00	0.00	0.00	0.00	0.00	0.00	62.74	62.74	0.00	0.00	1.00	182.34	183.34	99.45				
31/03/2021	94.32	0.00	1.00	70.83	71.82	0.00	0.00	0.00	0.00	0.00	0.00	20.78	20.78	0.00	0.00	29.70	29.70	0.00	0.00	0.00	0.00	0.00	0.00	60.71	0.00	1.00	182.02	183.01	99.46		

Water Volume [%]:

Untreated: 0.01 %

Below Dose: 0.38 %

To Dose: 99.62 %

Notes: 1. UV Comparative Dose: 18.1 mJ/cm²

Submitted By (Print): D.Merredew