



Kale Black, Sr. Drinking Water Officer  
Office of Drinking Water, Manitoba Conservation and Climate  
309 – 25 Tupper Street North  
Portage La Prairie, MB R1N 3K1

March 7, 2022

**RE: FEBRUARY 2022 WATER QUALITY COMPLIANCE SUBMISSION FOR THE CITY OF WINNIPEG WATER SUPPLY SYSTEM**

Please find attached on-line and grab turbidity summary reports, on-line and grab chlorine summary reports and the UV summary report for the Water Treatment Plant for February 2022.

The February on-line and grab sampling turbidity reports include results obtained for the Water Treatment Plant raw water and the eight filters. The turbidity results for the filter effluent met the licence requirements.

The February on-line and grab sampling chlorine reports include results obtained for the Deacon Booster Pumping Station at the Water Treatment Plant. The free chlorine results at the Water Treatment Plant met the licence requirements.

The February UV summary report includes results obtained for the six UV reactors at the Water Treatment Plant. The UV disinfection results met the licence requirements.

Please let me know of any concerns or questions respecting this submission. I can be reached by telephone at 204-986-8359 or by e-mail at [rgrosselle@winnipeg.ca](mailto:rgrosselle@winnipeg.ca).

Yours sincerely,

*Original signed by,  
(Signed original available upon request)*

R. Grosselle  
Manager of Environmental Standards

Enclosures

cc: Dr. L. Richards, Winnipeg Regional Health Authority (email)  
Dr. H. Chang, Winnipeg Regional Health Authority (email)  
Dr. S. Roberecki, Manitoba Health and Seniors Care (email)  
T. Shanks, M. Eng., P. Eng. (e-mail)  
C. Wiebe, P. Eng., CAMP (e-mail)  
C. Diduck (email)



**CITY OF WINNIPEG**  
 WATER AND WASTE DEPARTMENT  
 WATER SERVICES

Water System Code: 252.00  
 Licence Number: PWS-09-412-02

**WATER TREATMENT PLANT TURBIDITY ON-LINE MONITORING REPORT**

February 2022 Turbidity (NTU)

Date	Raw	Filter #1		Filter #2		Filter #3		Filter #4		Filter #5		Filter #6		Filter #7		Filter #8	
	Avg	Avg	Max														
1/02/2022	0.80	0.04	0.08	0.06	0.08	0.10	0.13	0.02	0.06	0.06	0.09	0.05	0.09	0.04	0.08	0.04	0.09
2/02/2022	0.80	0.05	0.07	0.05	0.09	0.07	0.13	0.04	0.06	0.09	0.13	0.05	0.11	0.03	0.09	0.04	0.08
3/02/2022	0.79	0.05	0.09	0.04	0.09	0.07	0.14	0.03	0.06	0.07	0.14	0.07	0.12	0.03	0.06	0.07	0.10
4/02/2022	0.79	0.04	0.08	0.05	0.07	0.12	0.13	0.02	0.06	0.06	0.11	0.06	0.11	0.04	0.09	0.04	0.10
5/02/2022	0.78	0.78	0.06	0.05	0.09	0.09	0.19	0.03	0.05	0.10	0.13	0.05	0.11	0.03	0.08	0.04	0.10
6/02/2022	0.78	OL	OL	0.06	0.10	0.12	0.17	0.04	0.06	0.09	0.13	0.07	0.14	0.04	0.08	0.06	0.08
7/02/2022	0.77	OL	OL	0.06	0.11	0.14	0.19	0.04	0.06	0.09	0.14	0.07	0.09	0.03	0.07	0.07	0.10
8/02/2022	0.75	OL	OL	0.07	0.12	0.13	0.21	0.04	0.07	0.09	0.14	0.07	0.11	0.04	0.05	0.06	0.10
9/02/2022	0.88	OL	OL	0.05	0.10	0.04	0.20	0.02	0.05	0.06	0.11	0.04	0.11	0.03	0.07	0.03	0.08
10/02/2022	0.73	OL	OL	0.07	0.12	0.02	0.06	0.03	0.05	0.06	0.11	0.05	0.10	0.03	0.07	0.04	0.06
11/02/2022	0.71	OL	OL	0.08	0.13	0.01	0.04	0.02	0.05	0.08	0.12	0.05	0.07	0.03	0.07	0.05	0.08
12/02/2022	0.70	OL	OL	0.09	0.13	0.02	0.05	0.03	0.06	0.08	0.12	0.06	0.09	0.03	0.05	0.04	0.08
13/02/2022	0.70	0.07	0.12	0.08	0.10	0.01	0.02	0.02	0.05	0.07	0.11	0.05	0.09	0.04	0.06	0.04	0.08
14/02/2022	0.69	0.07	0.12	0.10	0.14	0.01	0.05	0.02	0.04	0.08	0.11	0.05	0.09	0.04	0.07	0.04	0.08
15/02/2022	0.68	0.07	0.15	0.10	0.15	0.02	0.05	0.03	0.05	0.07	0.12	0.05	0.08	0.04	0.07	0.05	0.07
16/02/2022	0.71	0.07	0.14	0.07	0.16	0.02	0.06	0.00	0.05	0.03	0.16	0.04	0.10	0.03	0.06	0.03	0.10
17/02/2022	0.65	0.11	0.18	0.12	0.20	0.05	0.09	OL	OL	0.10	0.15	0.06	0.12	0.05	0.09	0.05	0.11
18/02/2022	0.64	0.10	0.14	0.07	0.19	0.04	0.14	OL	OL	0.12	0.18	0.06	0.10	0.05	0.09	0.05	0.09
19/02/2022	0.63	0.07	0.13	0.04	0.10	0.02	0.06	OL	OL	0.10	0.17	0.05	0.08	0.04	0.24	0.05	0.09
20/02/2022	0.62	0.08	0.10	0.05	0.11	0.01	0.06	OL	OL	0.11	0.17	0.06	0.10	0.04	0.08	0.05	0.09
21/02/2022	0.61	0.09	0.14	0.04	0.06	0.02	0.04	0.01	0.08	0.10	0.17	0.06	0.11	0.04	0.05	0.05	0.09
22/02/2022	0.60	0.06	0.14	0.05	0.10	0.01	0.05	0.03	0.05	0.10	0.15	0.05	0.10	0.04	0.08	0.04	0.09
23/02/2022	0.58	0.06	0.13	0.03	0.09	0.01	0.05	0.03	0.05	0.12	0.17	0.06	0.08	0.03	0.07	0.05	0.07
24/02/2022	0.58	0.09	0.11	0.03	0.11	0.01	0.02	0.02	0.08	0.05	0.17	0.07	0.10	0.03	0.05	0.04	0.09
25/02/2022	0.58	0.05	0.11	0.03	0.06	0.00	0.04	0.02	0.04	0.04	0.08	0.05	0.10	0.04	0.09	0.04	0.08
26/02/2022	0.56	0.04	0.10	0.03	0.06	0.00	0.02	0.03	0.05	0.05	0.07	0.04	0.09	0.03	0.06	0.04	0.06
27/02/2022	0.55	0.06	0.07	0.02	0.07	0.00	0.00	0.02	0.05	0.03	0.08	0.07	0.09	0.02	0.06	0.05	0.08
28/02/2022	0.54	0.05	0.09	0.03	0.04	0.00	0.03	0.02	0.03	0.03	0.07	0.05	0.10	0.04	0.05	0.03	0.08

Total Number of Measurements Taken, A:	7502	10576	9790	9025	12465	12686	12557	13725
Turbidity Standard for Monitoring Location (NTU):	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3
Number of Measurements Meeting Standard, B:	7502	10576	9790	9025	12465	12686	12557	13725
Compliance with Turbidity Standard, C = B/A X 100%:	100.000%	100.000%	100.000%	100.000%	100.000%	100.000%	100.000%	100.000%

OL = Offline

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Turbidity\2022\02-February

Submitted By (Print): D.Merredew

Signature: Original signed by D.Merredew

**WATER TREATMENT PLANT TURBIDITY GRAB MONITORING REPORT**

Water System Code: 252.00		Turbidity (NTU)																	
Licence No. PWS-09-412-02																			
Date	Raw Water		Filter 1		Filter 2		Filter 3		Filter 4		Filter 5		Filter 6		Filter 7		Filter 8		
	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	
01-Feb-2022	0.69	0.79	0.07	0.05	0.08	0.07	0.08	0.11	0.07	0.04	0.08	0.09	0.10	0.09	0.11	0.05	0.12	0.08	
02-Feb-2022	0.74	0.84	0.08	0.07	0.11	0.09	0.10	0.12	0.08	0.04	0.10	0.12	0.10	0.08	0.13	0.07	0.09	0.06	
03-Feb-2022	0.63	0.76	0.08	0.08	0.11	0.10	0.07	0.11	0.10	0.05	0.08	0.09	0.09	0.08	0.09	0.04	0.09	0.06	
04-Feb-2022	0.68	0.77	0.10	0.09	0.07	0.06	0.08	0.12	0.07	0.03	0.08	0.11	0.11	0.11	0.09	0.04	0.09	0.07	
05-Feb-2022	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	
06-Feb-2022	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	
07-Feb-2022	0.71	0.74	o/l	o/l	0.07	0.06	0.07	0.15	0.08	0.05	0.09	0.12	0.10	0.09	0.09	0.04	0.09	0.07	
08-Feb-2022	0.65	0.74	o/l	o/l	0.09	0.08	0.08	0.17	0.09	0.05	0.07	0.11	0.09	0.08	0.08	0.03	0.09	0.07	
09-Feb-2022	0.63	0.73	o/l	o/l	0.09	0.09	0.09	0.03	0.07	0.04	0.08	0.11	0.10	0.10	0.09	0.04	0.07	0.06	
10-Feb-2022	0.65	0.78	o/l	o/l	0.11	0.11	0.09	0.02	0.08	0.04	0.10	0.09	0.08	0.05	0.07	0.03	0.08	0.04	
11-Feb-2022	0.58	0.69	o/l	o/l	0.08	0.08	0.08	<0.02	0.09	0.04	0.09	0.10	0.08	0.06	0.07	0.03	0.09	0.05	
12-Feb-2022	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	
13-Feb-2022	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	
14-Feb-2022	0.57	0.66	0.13	0.08	0.09	0.12	0.10	0.03	0.07	0.03	0.08	0.10	0.10	0.06	0.08	0.04	0.07	0.04	
15-Feb-2022	0.57	0.66	0.08	0.08	0.09	0.11	0.08	0.02	0.09	0.04	0.09	0.09	0.08	0.06	0.07	0.03	0.08	0.05	
16-Feb-2022	0.54	0.65	0.13	0.12	0.14	0.15	0.13	0.05	o/l	o/l	0.09	0.09	0.11	0.08	0.09	0.04	0.09	0.05	
17-Feb-2022	0.54	0.63	0.11	0.11	0.13	0.16	0.15	0.06	o/l	o/l	0.10	0.12	0.09	0.07	0.10	0.05	0.08	0.05	
18-Feb-2022	0.56	0.63	0.14	0.13	0.13	0.15	0.12	0.03	o/l	o/l	0.15	0.16	0.10	0.08	0.09	0.04	0.10	0.06	
19-Feb-2022	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	
20-Feb-2022	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	
21-Feb-2022	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	
22-Feb-2022	0.54	0.58	0.15	0.13	0.12	0.07	0.12	0.03	0.10	0.04	0.09	0.15	0.08	0.07	0.10	0.05	0.07	0.05	
23-Feb-2022	0.51	0.59	0.09	0.10	0.12	0.07	0.09	<0.02	0.13	0.06	0.09	0.15	0.09	0.08	0.11	0.06	0.08	0.05	
24-Feb-2022	0.50	0.58	0.10	0.09	0.09	0.05	0.10	<0.02	0.07	0.02	0.15	0.18	0.10	0.09	0.08	0.03	0.10	0.07	
25-Feb-2022	0.52	0.56	0.08	0.08	0.09	0.04	0.10	<0.02	0.08	0.03	0.08	0.07	0.10	0.08	0.09	0.04	0.08	0.05	
26-Feb-2022	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	
27-Feb-2022	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	
28-Feb-2022	0.49	0.54	0.10	0.09	0.09	0.04	0.10	<0.02	0.07	0.02	0.07	0.05	0.09	0.09	0.07	0.03	0.09	0.07	
<b>Total number of measurements taken, A:</b>			14		19		19		16		19		19		19		19		
<b>Turbidity Standard for Monitoring Location (NTU):</b>			0.30		0.30		0.30		0.30		0.30		0.30		0.30		0.30		
<b>Number of measurements meeting standard, B:</b>			14		19		19		16		19		19		19		19		
<b>Compliance with Turbidity Standard, C= B/A X 100%:</b>			100%		100%		100%		100%		100%		100%		100%		100%		

na: not analyzed nr: no result ns: no sample o/l: offline im: instrument maintenance

**Comments:**

Filter 1 – offline for maintenance from February 5 at 5:41pm until February 13, 3:53am  
Filter 4 – offline for maintenance from February 16 at 1:15am until February 21 at 12:42pm

**Report Date:** 3-Mar-2022



WATER TREATMENT PLANT FREE CHLORINE ON-LINE MONITORING REPORT  
Deacon Booster Pumping Station

Water System Code: 252.00  
Licence Number: PWS-09-412-02  
Report Created: 01 March 2022

Report Period: February 2022

Date	BRANCH 1 [mg/L]		BRANCH 2 [mg/L]	
	Average	Minimum	Average	Minimum
01/02/2022	1.16	1.07	1.07	0.94
02/02/2022	1.23	1.15	1.08	1.01
03/02/2022	1.26	1.18	1.13	1.06
04/02/2022	1.25	1.18	1.17	1.10
05/02/2022	1.30	1.20	1.21	1.11
06/02/2022	1.24	1.12	1.17	1.02
07/02/2022	1.22	1.14	1.18	1.07
08/02/2022	1.19	1.08	1.18	1.10
09/02/2022	1.23	1.04	1.26	1.11
10/02/2022	1.24	1.17	1.33	1.24
11/02/2022	1.22	1.14	1.36	1.30
12/02/2022	1.27	1.21	1.36	1.28
13/02/2022	1.26	1.21	1.34	1.26
14/02/2022	1.21	1.14	1.30	1.23
15/02/2022	1.22	1.16	1.29	1.22
16/02/2022	1.14	1.02	1.08	0.96
17/02/2022	1.11	1.07	1.10	0.98
18/02/2022	1.10	1.06	1.12	1.05
19/02/2022	1.10	0.78	1.09	0.75
20/02/2022	1.14	1.08	1.14	1.09
21/02/2022	1.18	1.14	1.13	1.01
22/02/2022	1.17	1.12	1.14	1.08
23/02/2022	1.18	1.10	1.15	1.10
24/02/2022	1.16	1.07	1.18	1.10
25/02/2022	1.12	1.06	1.15	1.06
26/02/2022	1.06	0.95	1.14	1.08
27/02/2022	1.01	0.95	1.14	1.06
28/02/2022	1.03	0.95	1.13	1.07

Total Number of Measurements, A:	19440	19440
Minimum Free Chlorine Standard:	0.5	0.5
Number of Measurements Meeting Standard, B:	19440	19440
COMPLIANCE, C = B/A X 100%:	100.00	100.00

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Chlorine\2022\02-February

Submitted By (Print): D.Merredew

Signature: Original signed by D.Merredew



WATER TREATMENT PLANT CHLORINE GRAB MONITORING REPORT						
Water System Code: 252.00	Deacon Booster Pumping Station Branch 1			Deacon Booster Pumping Station Branch 2		
Licence No. PWS-09-412-02						
Date	Free Chlorine (mg/L)		Total Chlorine (mg/L)	Free Chlorine (mg/L)		Total Chlorine (mg/L)
	Analyser	Grab	Grab	Analyser	Grab	Grab
01-Feb-2022	1.15	1.14	1.36	1.03	1.09	1.29
02-Feb-2022	1.25	1.21	1.43	1.08	1.14	1.35
03-Feb-2022	1.24	1.25	1.44	1.17	1.18	1.36
04-Feb-2022	1.27	1.26	1.44	1.19	1.16	1.38
05-Feb-2022	ns	ns	ns	ns	ns	ns
06-Feb-2022	ns	ns	ns	ns	ns	ns
07-Feb-2022	1.24	1.17	1.40	1.14	1.16	1.36
08-Feb-2022	1.19	1.18	1.40	1.15	1.19	1.36
09-Feb-2022	1.15	1.15	1.39	1.20	1.29	1.47
10-Feb-2022	1.25	1.26	1.49	1.30	1.37	1.62
11-Feb-2022	1.21	1.18	1.41	1.34	1.34	1.56
12-Feb-2022	ns	ns	ns	ns	ns	ns
13-Feb-2022	ns	ns	ns	ns	ns	ns
14-Feb-2022	1.21	1.18	1.43	1.29	1.34	1.55
15-Feb-2022	1.25	1.22	1.48	1.32	1.40	1.60
16-Feb-2022	1.16	1.11	1.37	1.23	1.27	1.48
17-Feb-2022	1.11	1.07	1.32	1.12	1.14	1.35
18-Feb-2022	1.06	1.08	1.31	1.07	1.06	1.29
19-Feb-2022	ns	ns	ns	ns	ns	ns
20-Feb-2022	ns	ns	ns	ns	ns	ns
21-Feb-2022	ns	ns	ns	ns	ns	ns
22-Feb-2022	1.19	1.19	1.40	1.16	1.20	1.40
23-Feb-2022	1.16	1.18	1.40	1.14	1.18	1.40
24-Feb-2022	1.18	1.21	1.43	1.22	1.22	1.43
25-Feb-2022	1.08	1.10	1.31	1.10	1.11	1.31
26-Feb-2022	ns	ns	ns	ns	ns	ns
27-Feb-2022	ns	ns	ns	ns	ns	ns
28-Feb-2022	1.01	1.03	1.26	1.14	1.17	1.40
<b>Total number of measurements taken, A:</b>			19			19
<b>Chlorine Standard for Monitoring Location (mg/L):</b>			0.50			0.50
<b>Number of measurements meeting standard, B:</b>			19			19
<b>Compliance with Chlorine Standard, C= B/A X 100%:</b>			100%			100%

na: not analyzed nr: no result ns: no sample o/l: offline im: instrument maintenance

Comments:

Report Date: 3-Mar-2022



**CITY OF WINNIPEG**  
 WATER AND WASTE DEPARTMENT  
 WATER SERVICES

Water System Code: 252.00  
 Licence Number: PWS-09-412-02

**WATER TREATMENT PLANT UV REPORT**

Report Period: February 2022

Report Created: Tuesday, March 01, 2022

Date	UVR-D100A				UVR-D200A				UVR-D300A				UVR-D400A				UVR-D500A				UVR-D600A				Total				% Volume Treated To Dose		
	Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	To	Total		Untreated	Below
01/02/2022	0.00	1.31	80.65	81.96	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	40.38	40.38	0.00	1.71	59.35	61.05	0.00	3.01	180.38	183.39	98.36			
02/02/2022	0.00	1.27	81.47	82.74	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	40.04	40.04	0.00	1.99	60.21	62.20	0.00	3.25	181.73	184.98	98.24			
03/02/2022	0.00	1.03	81.70	82.73	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	39.70	39.70	0.00	1.92	60.61	62.52	0.00	2.95	182.01	184.96	98.40			
04/02/2022	0.00	1.46	82.78	84.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	40.00	40.00	0.00	1.91	63.60	65.51	0.00	3.38	186.39	189.76	98.22			
05/02/2022	0.00	1.36	83.65	85.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	40.38	40.38	0.00	2.14	64.48	66.62	0.00	3.49	188.51	192.00	98.18			
06/02/2022	0.00	1.42	83.51	84.93	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	39.79	39.79	0.00	2.14	64.98	67.12	0.00	3.56	188.28	191.84	98.14			
07/02/2022	0.00	1.18	81.78	82.95	0.00	0.00	2.57	2.57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	39.58	39.58	0.00	2.26	67.01	69.28	0.00	3.44	190.94	194.37	98.23			
08/02/2022	0.00	0.41	78.51	78.92	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	46.68	46.68	0.00	2.01	70.34	72.35	0.00	2.42	195.53	197.95	98.78			
09/02/2022	0.00	0.30	44.11	44.41	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	15.79	15.79	0.00	0.00	37.89	37.89	0.00	0.61	18.63	19.24	0.00	0.91	116.42	117.33	99.22		
10/02/2022	0.00	0.94	69.94	70.88	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	54.40	54.40	0.00	0.00	69.48	69.48	0.00	0.00	0.00	0.00	0.00	0.94	193.82	194.76	99.52		
11/02/2022	0.00	1.26	68.74	70.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	60.00	60.00	0.00	0.00	70.00	70.00	0.00	0.00	0.00	0.00	0.00	1.26	198.74	200.00	99.37		
12/02/2022	0.00	1.36	68.63	69.99	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	60.00	60.00	0.00	0.00	70.02	70.02	0.00	0.00	0.00	0.00	0.00	1.36	198.65	200.01	99.32		
13/02/2022	0.00	1.41	68.57	69.99	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	59.98	59.98	0.00	0.00	70.01	70.01	0.00	0.00	0.00	0.00	0.00	1.41	198.56	199.97	99.29		
14/02/2022	0.00	1.21	68.80	70.02	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	59.99	59.99	0.00	0.00	69.99	69.99	0.00	0.00	0.00	0.00	0.00	1.21	198.78	199.99	99.39		
15/02/2022	0.00	1.36	68.63	69.99	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	58.04	58.04	0.00	0.00	69.99	69.99	0.00	0.00	0.00	0.00	0.00	1.36	196.66	198.02	99.31		
16/02/2022	0.00	0.86	40.62	41.48	0.00	0.00	0.00	0.00	0.00	0.53	14.15	14.68	0.00	0.00	15.25	15.25	0.00	0.00	40.73	40.73	0.00	0.00	0.00	0.00	0.00	1.39	110.74	112.13	98.76		
17/02/2022	0.00	1.44	70.26	71.70	0.00	0.00	0.00	0.00	0.00	1.46	46.77	48.23	0.00	0.00	0.00	0.00	0.00	0.00	71.55	71.55	0.00	0.00	0.00	0.00	0.00	2.90	188.58	191.48	98.48		
18/02/2022	0.00	1.43	69.40	70.83	0.00	0.00	0.00	0.00	0.00	1.41	47.84	49.25	0.00	0.00	0.00	0.00	0.00	0.00	70.82	70.82	0.00	0.00	0.00	0.00	0.00	2.84	188.07	190.90	98.51		
19/02/2022	0.02	1.14	63.32	64.49	0.00	0.00	0.00	0.00	0.00	1.14	43.15	44.29	0.00	0.00	0.00	0.00	0.00	0.00	63.58	63.58	0.00	0.00	0.00	0.00	0.02	2.29	170.05	172.36	98.66		
20/02/2022	0.00	1.12	68.89	70.01	0.00	0.00	0.00	0.00	0.00	1.33	46.69	48.02	0.00	0.00	0.00	0.00	0.00	0.00	70.00	70.00	0.00	0.00	0.00	0.00	0.00	2.46	185.58	188.04	98.69		
21/02/2022	0.00	1.03	68.56	69.59	0.00	0.00	0.00	0.00	0.00	1.88	47.61	49.50	0.00	0.00	0.00	0.00	0.00	0.00	65.02	65.02	0.00	0.00	0.00	0.00	0.00	2.91	181.20	184.11	98.42		
22/02/2022	0.00	1.36	68.69	70.05	0.00	0.00	0.00	0.00	0.00	1.47	49.93	51.40	0.00	0.00	0.00	0.00	0.00	0.00	61.57	61.57	0.00	0.00	0.00	0.00	0.00	2.83	180.19	183.02	98.45		
23/02/2022	0.00	1.46	68.53	69.99	0.00	0.00	0.00	0.00	0.00	1.47	51.25	52.72	0.00	0.00	0.00	0.00	0.00	0.00	63.01	63.01	0.00	0.00	0.00	0.00	0.00	2.93	182.79	185.72	98.42		
24/02/2022	0.00	1.27	68.74	70.01	0.00	0.00	0.00	0.00	0.00	1.68	51.91	53.59	0.00	0.00	0.00	0.00	0.00	0.00	64.09	64.09	0.00	0.00	0.00	0.00	0.00	2.95	184.74	187.69	98.43		
25/02/2022	0.00	1.07	68.94	70.01	0.00	0.00	0.00	0.00	0.00	2.04	51.31	53.35	0.00	0.00	0.00	0.00	0.00	0.00	63.67	63.67	0.00	0.00	0.00	0.00	0.00	3.11	183.91	187.02	98.34		
26/02/2022	0.00	0.93	44.57	45.50	0.00	0.00	0.00	0.00	0.00	2.52	56.97	59.49	0.00	0.00	0.00	0.00	0.00	0.00	56.31	56.31	0.00	0.80	24.88	25.68	0.00	4.24	182.73	186.97	97.73		
27/02/2022	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	2.32	68.60	70.91	0.00	0.00	0.00	0.00	0.00	0.00	42.79	42.79	0.00	1.93	71.43	73.36	0.00	4.25	182.82	187.06	97.73		
28/02/2022	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	2.17	67.36	69.53	0.00	0.00	0.00	0.00	0.00	0.00	41.97	41.97	0.00	2.19	69.45	71.65	0.00	4.37	178.78	183.15	97.62		
<b>Total [ML]:</b>	0.02	30.40	1812.00	1842.42	0.00	0.00	2.57	2.57	0.00	21.42	643.54	664.96	0.00	0.00	383.44	383.44	0.00	0.00	1559.03	1559.03	0.00	21.61	694.99	716.60	0.02	73.42	5095.57	5169.02			

**Water Volume [%]:**

Untreated: 0.00 %  
 Below Dose: 1.42 %  
 To Dose: 98.58 %

**Notes:** 1. UV Comparative Dose: 18.1 mJ/cm<sup>2</sup>

Submitted By (Print):  D.Merredew

Signature:  Original signed by D.Merredew

