



## Water and Waste Eaux et déchets

Kale Black, Sr. Drinking Water Officer  
Office of Drinking Water, Manitoba Conservation and Climate  
309 – 25 Tupper Street North  
Portage La Prairie, MB R1N 3K1

**July 7, 2022**

**RE: JUNE 2022 WATER QUALITY COMPLIANCE SUBMISSION FOR THE CITY OF WINNIPEG WATER SUPPLY SYSTEM**

Please find attached on-line and grab turbidity summary reports, on-line and grab chlorine summary reports and the UV summary report for the Water Treatment Plant for June 2022.

The June on-line and grab sampling turbidity reports include results obtained for the Water Treatment Plant raw water and the eight filters. The turbidity results for the filter effluent met the licence requirements.

The June on-line and grab sampling chlorine reports include results obtained for the Deacon Booster Pumping Station at the Water Treatment Plant. On June 21, 2022, the Branch 1 free chlorine online analyzer readings were below 0.5mg/L for 8 minutes while the Water Treatment Plant was offline for scheduled maintenance, but water was flowing to the Branch 1 surge tower; additional information is provided in CAR-02-2022. With the exception of this incident, the free chlorine results at the Water Treatment Plant met the licence requirements.

The June UV summary report includes results obtained for the six UV reactors at the Water Treatment Plant. The UV disinfection results met the licence requirements.

Please let me know of any concerns or questions respecting this submission. I can be reached by telephone at 204-986-8359 or by e-mail at rgrosselle@winnipeg.ca.

Yours sincerely,

N. Crawford  
Acting Manager of Environmental Standards

Enclosures

cc: Dr. L. Richards, Winnipeg Regional Health Authority (email)  
Dr. H. Chang, Winnipeg Regional Health Authority (email)  
Dr. S. Roberecki, Manitoba Health and Seniors Care (email)  
T. Shanks, M. Eng., P. Eng. (e-mail)  
M.Szmon, M. Eng. (e-mail)  
C. Diduck (email)



**CITY OF WINNIPEG**  
WATER AND WASTE DEPARTMENT  
WATER SERVICES

Water System Code: 252.00  
Licence Number: PWS-09-412-02

**WATER TREATMENT PLANT TURBIDITY ON-LINE MONITORING REPORT**

June 2022 Turbidity (NTU)

Date	Raw		Filter #1		Filter #2		Filter #3		Filter #4		Filter #5		Filter #6		Filter #7		Filter #8	
	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max
1/06/2022	1.56	0.04	0.13		0.07	0.10	0.03	0.13	0.06	0.13	0.03	0.08	0.01	0.06	0.03	0.09	0.08	0.11
2/06/2022	1.68	0.04	0.10		0.06	0.13	0.03	0.12	0.08	0.12	0.02	0.08	0.01	0.03	0.03	0.10	0.10	0.16
3/06/2022	1.51	0.04	0.07		0.06	0.14	0.03	0.12	0.08	0.15	0.02	0.07	0.02	0.07	0.03	0.09	0.09	0.16
4/06/2022	1.27	0.05	0.12		0.04	0.18	0.05	0.08	0.08	0.15	0.02	0.08	0.02	0.06	0.03	0.05	0.11	0.16
5/06/2022	1.28	0.04	0.12		0.05	0.14	0.05	0.13	0.08	0.16	0.03	0.06	0.01	0.08	0.04	0.09	0.09	0.20
6/06/2022	1.25	0.04	0.15		0.06	0.10	0.05	0.13	0.08	0.20	0.03	0.07	0.02	0.09	0.04	0.10	0.09	0.18
7/06/2022	1.32	0.04	0.12		0.06	0.16	0.05	0.13	0.09	0.17	0.02	0.10	0.01	0.03	0.03	0.11	0.13	0.21
8/06/2022	1.28	0.08	0.15		0.06	0.20	0.09	0.22	0.10	0.15	0.04	0.11	0.04	0.10	0.06	0.13	0.09	0.23
9/06/2022	1.27	0.09	0.15		0.08	0.14	0.10	0.14	0.09	0.13	0.05	0.09	0.04	0.10	0.06	0.12	0.09	0.16
10/06/2022	1.29	0.08	0.11		0.07	0.12	0.10	0.16	0.08	0.12	0.04	0.08	0.03	0.08	0.06	0.09	0.09	0.15
11/06/2022	1.23	0.09	0.13		0.06	0.13	0.12	0.14	0.07	0.12	0.04	0.05	0.03	0.08	0.05	0.10	0.08	0.18
12/06/2022	1.26	0.08	0.14		0.08	0.10	0.13	0.19	0.07	0.13	0.04	0.06	0.02	0.08	0.05	0.09	0.09	0.11
13/06/2022	1.27	0.09	0.15		0.07	0.15	0.13	0.21	0.08	0.10	0.04	0.07	0.03	0.06	0.05	0.09	0.09	0.14
14/06/2022	1.24	0.11	0.12		0.07	0.12	0.15	0.18	0.08	0.12	0.04	0.08	0.03	0.09	0.06	0.07	0.08	0.14
15/06/2022	1.10	0.06	0.16		0.07	0.16	0.12	0.23	0.08	0.14	0.04	0.07	0.03	0.06	0.05	0.10	0.08	0.13
16/06/2022	1.20	0.04	0.09		0.10	0.13	0.07	0.13	0.08	0.13	0.04	0.09	0.02	0.08	0.05	0.09	0.07	0.10
17/06/2022	1.19	0.03	0.08		0.07	0.16	0.07	0.16	0.08	0.12	0.04	0.08	0.01	0.04	0.05	0.08	0.08	0.13
18/06/2022	1.77	0.02	0.07		0.07	0.14	0.07	0.14	0.08	0.11	0.03	0.06	0.01	0.04	0.04	0.06	0.06	0.11
19/06/2022	1.50	0.02	0.06		0.06	0.13	0.09	0.10	0.07	0.11	0.02	0.06	0.00	0.03	0.04	0.11	0.06	0.11
20/06/2022	0.99	0.02	0.08		0.07	0.09	0.10	0.16	0.07	0.12	0.02	0.05	0.00	0.05	0.04	0.09	0.05	0.11
21/06/2022	1.12	0.02	0.06		0.04	0.14	0.09	0.17	0.06	0.12	0.02	0.08	0.00	0.04	0.04	0.09	0.07	0.12
22/06/2022	1.16	0.02	0.04		0.07	0.11	0.12	0.21	0.08	0.13	0.02	0.07	0.01	0.04	0.05	0.07	0.07	0.12
23/06/2022	1.26	0.03	0.10		0.07	0.14	0.15	0.18	0.08	0.12	0.02	0.05	0.01	0.04	0.05	0.12	0.07	0.11
24/06/2022	1.40	0.03	0.08		0.08	0.11	0.07	0.21	0.08	0.15	0.02	0.04	0.01	0.04	0.05	0.09	0.07	0.12
25/06/2022	1.83	0.03	0.07		0.07	0.13	0.06	0.11	0.07	0.15	0.02	0.05	0.00	0.01	0.05	0.09	0.08	0.10
26/06/2022	2.66	0.03	0.09		0.07	0.12	0.07	0.13	0.09	0.11	0.02	0.04	0.01	0.05	0.04	0.07	0.07	0.16
27/06/2022	1.69	0.04	0.07		0.06	0.10	0.08	0.11	0.07	0.13	0.02	0.10	0.02	0.08	0.05	0.12	0.07	0.18
28/06/2022	1.69	0.05	0.11		0.08	0.17	0.08	0.14	0.07	0.14	0.05	0.07	0.03	0.11	0.05	0.11	0.08	0.22
29/06/2022	1.65	0.05	0.12		0.07	0.14	0.09	0.18	0.09	0.10	0.04	0.09	0.05	0.07	0.05	0.06	0.08	0.15
30/06/2022	1.62	0.07	0.09		0.06	0.08	0.11	0.13	0.08	0.15	0.04	0.08	0.04	0.13	0.05	0.16	0.08	0.15

Total Number of Measurements Taken, A: 13202      13084      13218      14297      14566      13355      14595      15759  
Turbidity Standard for Monitoring Location (NTU): 0.3      0.3      0.3      0.3      0.3      0.3      0.3      0.3  
Number of Measurements Meeting Standard, B: 13202      13084      13218      14297      14566      13355      14595      15759  
Compliance with Turbidity Standard, C = B/A X 100%: 100.000%      100.000%      100.000%      100.000%      100.000%      100.000%      100.000%

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Turbidity\2022\06-June

Submitted By (Print): D.Merredew

Signature: Original signed by D.Merredew



**Water and Waste**  
**Eaux et déchets**

CITY OF WINNIPEG  
WATER AND WASTE DEPARTMENT  
ENVIRONMENTAL STANDARDS DIVISION

**WATER TREATMENT PLANT TURBIDITY GRAB MONITORING REPORT**

Water System Code: 252.00	Turbidity (NTU)																	
	Raw Water		Filter 1		Filter 2		Filter 3		Filter 4		Filter 5		Filter 6		Filter 7		Filter 8	
Date	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser
01-Jun-2022	0.77	1.49	0.11	0.10	0.09	0.07	0.11	0.08	0.08	0.09	0.08	0.06	0.10	0.02	0.10	0.05	0.10	0.10
02-Jun-2022	0.92	1.59	0.08	0.09	0.10	0.08	0.08	0.04	0.08	0.09	0.08	0.05	0.08	<0.02	0.10	0.05	0.10	0.11
03-Jun-2022	0.85	1.70	0.09	0.05	0.10	0.09	0.08	0.05	0.09	0.10	0.09	0.06	0.09	0.02	0.07	0.03	0.10	0.13
04-Jun-2022	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns
05-Jun-2022	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns
06-Jun-2022	0.81	1.18	0.11	0.07	0.09	0.07	0.12	0.09	0.16	0.19	0.08	0.04	0.09	0.03	0.09	0.05	0.09	0.13
07-Jun-2022	0.88	1.27	0.08	0.05	0.09	0.08	0.10	0.08	0.07	0.11	0.09	0.04	0.08	0.02	0.10	0.05	0.08	0.13
08-Jun-2022	0.93	1.35	0.11	0.08	0.13	0.10	0.11	0.08	0.10	0.13	0.12	0.09	0.10	0.05	0.09	0.05	0.11	0.09
09-Jun-2022	1.04	1.28	0.11	0.10	0.12	0.09	0.11	0.11	0.11	0.11	0.09	0.06	0.11	0.05	0.10	0.05	0.13	0.12
10-Jun-2022	0.88	1.34	0.10	0.09	0.09	0.07	0.10	0.11	0.10	0.09	0.08	0.05	0.13	0.06	0.10	0.06	0.11	0.11
11-Jun-2022	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns
12-Jun-2022	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns
13-Jun-2022	0.97	1.23	0.09	0.10	0.12	0.10	0.09	0.15	0.09	0.09	0.10	0.06	0.10	0.04	0.09	0.04	0.09	0.09
14-Jun-2022	0.81	1.24	0.10	0.11	0.09	0.08	0.10	0.17	0.10	0.10	0.08	0.04	0.13	0.07	0.10	0.05	0.09	0.09
15-Jun-2022	0.82	1.07	0.12	0.14	0.10	0.08	0.11	0.19	0.14	0.10	0.08	0.05	0.09	0.03	0.13	0.07	0.09	0.09
16-Jun-2022	0.70	1.13	0.15	0.06	0.13	0.10	0.16	0.11	0.11	0.10	0.12	0.08	0.10	0.02	0.09	0.04	0.10	0.07
17-Jun-2022	0.72	1.09	0.12	0.04	0.19	0.14	0.12	0.07	0.11	0.09	0.12	0.06	0.10	0.03	0.11	0.04	0.11	0.08
18-Jun-2022	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns
19-Jun-2022	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns
20-Jun-2022	0.78	0.78	0.13	0.04	0.10	0.08	0.11	0.12	0.09	0.07	0.08	0.03	0.08	<0.02	0.11	0.05	0.08	0.05
21-Jun-2022	0.80	1.07	0.10	0.02	0.13	0.10	0.10	0.12	0.10	0.09	0.09	0.04	0.10	<0.02	0.09	0.04	0.10	0.06
22-Jun-2022	0.79	1.13	0.12	0.03	0.12	0.07	0.12	0.14	0.12	0.09	0.09	0.03	0.12	0.03	0.10	0.05	0.11	0.08
23-Jun-2022	0.80	1.18	0.12	0.04	0.11	0.08	0.11	0.16	0.12	0.10	0.08	0.02	0.09	<0.02	0.11	0.06	0.08	0.06
24-Jun-2022	0.81	1.33	0.13	0.06	0.11	0.09	0.12	0.08	0.10	0.08	0.08	0.02	0.09	<0.02	0.13	0.07	0.10	0.07
25-Jun-2022	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns
26-Jun-2022	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns
27-Jun-2022	1.04	1.67	0.11	0.05	0.10	0.09	0.10	0.09	0.11	0.11	0.08	0.03	0.12	0.02	0.11	0.05	0.09	0.07
28-Jun-2022	1.00	1.71	0.10	0.06	0.11	0.09	0.12	0.11	0.09	0.08	0.09	0.06	0.10	0.05	0.09	0.04	0.10	0.08
29-Jun-2022	1.02	1.61	0.10	0.07	0.13	0.11	0.10	0.10	0.10	0.09	0.11	0.08	0.11	0.05	0.10	0.04	0.12	0.10
30-Jun-2022	1.03	1.53	0.11	0.08	0.10	0.08	0.10	0.11	0.13	0.11	0.09	0.06	0.16	0.10	0.11	0.06	0.09	0.08
<b>Total number of measurements taken, A:</b>				22	0.30	22	0.30	22	0.30	22	0.30	22	0.30	22	0.30	22	0.30	
<b>Turbidity Standard for Monitoring Location (NTU):</b>				0.30		0.30		0.30		0.30		0.30		0.30		0.30		0.30
<b>Number of measurements meeting standard, B:</b>				22		22		22		22		22		22		22		22
<b>Compliance with Turbidity Standard, C= B/A X 100%:</b>				100%		100%		100%		100%		100%		100%		100%		100%

na: not analyzed nr: no result ns: no sample o/l: offline im: instrument maintenance

**Comments:**

The raw water analyzer is cleaned daily during warm water months because it is susceptible to frequent fouling

**Report Date:** 4-Jul-2022

**City Of Winnipeg**

Water and Waste Department

Water Services

**WATER TREATMENT PLANT FREE CHLORINE ON-LINE MONITORING REPORT**  
Deacon Booster Pumping StationWater System Code: **252.00**Licence Number: **PWS-09-412-02**

Report Created: 01 July 2022

Report Period: June 2022

Date	BRANCH 1 [mg/L]		BRANCH 2 [mg/L]	
	Average	Minimum	Average	Minimum
01/06/2022	1.15	1.03	1.16	1.06
02/06/2022	1.26	1.11	1.22	1.08
03/06/2022	1.35	1.19	1.27	1.14
04/06/2022	1.41	1.27	1.31	1.23
05/06/2022	1.39	1.27	1.27	1.15
06/06/2022	1.38	1.22	1.32	1.17
07/06/2022	1.28	1.16	1.37	1.32
08/06/2022	1.27	1.19	1.36	1.30
09/06/2022	1.31	1.23	1.39	1.32
10/06/2022	1.29	1.11	1.40	1.17
11/06/2022	1.46	1.11	1.52	1.27
12/06/2022	1.40	1.20	1.48	1.38
13/06/2022	1.40	1.28	1.55	1.39
14/06/2022	1.35	1.25	1.48	1.33
15/06/2022	1.31	1.23	1.41	1.33
16/06/2022	1.31	1.02	1.37	1.13
17/06/2022	1.32	1.21	1.33	1.21
18/06/2022	1.33	1.13	1.36	1.26
19/06/2022	1.30	1.17	1.37	1.28
20/06/2022	1.23	1.08	1.32	1.20
21/06/2022	1.25	0.37	1.32	0.53
22/06/2022	1.42	1.25	1.45	1.22
23/06/2022	1.39	1.25	1.39	1.25
24/06/2022	1.40	1.23	1.33	1.22
25/06/2022	1.42	1.20	1.33	1.14
26/06/2022	1.30	1.17	1.25	1.16
27/06/2022	1.33	0.81	1.28	0.98
28/06/2022	1.36	1.22	1.33	1.17
29/06/2022	1.25	1.12	1.19	1.07
30/06/2022	1.28	1.16	1.17	1.07

Total Number of Measurements, A: 20884 20884

Minimum Free Chlorine Standard: 0.5 0.5

Number of Measurements Meeting Standard, B: 20850 20884

COMPLIANCE, C = B/A X 100%: 99.84 100.00

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Chlorine\2022\06-June

Submitted By (Print): D.MerredewSignature: Original signed by D.Merredew



**Water and Waste**  
**Eaux et déchets**

CITY OF WINNIPEG  
WATER AND WASTE DEPARTMENT  
ENVIRONMENTAL STANDARDS DIVISION

**WATER TREATMENT PLANT CHLORINE GRAB MONITORING REPORT**

Water System Code: 252.00	Deacon Booster Pumping Station Branch 1			Deacon Booster Pumping Station Branch 2		
	Date	Free Chlorine (mg/L)	Total Chlorine (mg/L)	Free Chlorine (mg/L)	Total Chlorine (mg/L)	
		Analyser	Grab	Grab	Analyser	Grab
01-Jun-2022		1.11	1.14	1.32	1.16	1.17
02-Jun-2022		1.20	1.24	1.41	1.17	1.23
03-Jun-2022		1.35	1.33	1.53	1.31	1.33
04-Jun-2022		ns	ns	ns	ns	ns
05-Jun-2022		ns	ns	ns	ns	ns
06-Jun-2022		1.47	1.40	1.63	1.46	1.41
07-Jun-2022		1.29	1.20	1.35	1.39	1.41
08-Jun-2022		1.31	1.29	1.50	1.41	1.41
09-Jun-2022		1.34	1.32	1.55	1.38	1.46
10-Jun-2022		1.16	1.16	1.39	1.22	1.31
11-Jun-2022		ns	ns	ns	ns	ns
12-Jun-2022		ns	ns	ns	ns	ns
13-Jun-2022		1.36	1.42	1.65	1.58	1.57
14-Jun-2022		1.35	1.40	1.60	1.47	1.51
15-Jun-2022		1.37	1.35	1.56	1.42	1.42
16-Jun-2022		1.20	1.23	1.43	1.35	1.40
17-Jun-2022		1.36	1.35	1.56	1.36	1.40
18-Jun-2022		ns	ns	ns	ns	ns
19-Jun-2022		ns	ns	ns	ns	ns
20-Jun-2022		1.20	1.27	1.51	1.32	1.34
21-Jun-2022		1.22	1.28	1.52	1.30	1.37
22-Jun-2022		1.34	1.34	1.55	1.43	1.43
23-Jun-2022		1.41	1.36	1.59	1.41	1.37
24-Jun-2022		1.32	1.31	1.53	1.32	1.35
25-Jun-2022		ns	ns	ns	ns	ns
26-Jun-2022		ns	ns	ns	ns	ns
27-Jun-2022		1.35	1.33	1.51	1.32	1.30
28-Jun-2022		1.44	1.36	1.58	1.37	1.33
29-Jun-2022		1.25	1.23	1.45	1.17	1.23
30-Jun-2022		1.30	1.25	1.48	1.18	1.16
<b>Total number of measurements taken, A:</b>		22			22	
<b>Chlorine Standard for Monitoring Location (mg/L):</b>		0.50			0.50	
<b>Number of measurements meeting standard, B:</b>		22			22	
<b>Compliance with Chlorine Standard, C= B/A X 100%:</b>		100%			100%	

na: not analyzed nr: no result ns: no sample o/l: offline im: instrument maintenance

Comments:

Report Date: 4-Jul-2022

**CITY OF WINNIPEG**  
WATER AND WASTE DEPARTMENT  
WATER SERVICES

Water System Code: 252.00  
Licence Number: PWS-09-412-02

WATER TREATMENT PLANT UV REPORT

Report Period: June 2022

Report Created: Friday, July 01, 2022

Date	UVR-D100A				UVR-D200A				UVR-D300A				UVR-D400A				UVR-D500A				UVR-D600A				Total				% Volume Treated To Dose					
	Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]									
	Untreated	Below	To	Total	Untreated	Below	To	Total																										
01/06/2022	0.00	0.00	0.00	0.00	0.00	0.00	76.11	76.11	0.00	0.00	0.00	0.00	0.00	0.00	55.82	55.82	0.00	0.00	64.23	64.23	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	196.16	196.16	100.00			
02/06/2022	0.00	0.00	0.00	0.00	0.00	0.00	83.14	83.14	0.00	0.00	0.00	0.00	0.00	0.00	53.05	53.05	0.00	0.00	61.82	61.82	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	198.00	198.00	100.00			
03/06/2022	0.00	0.00	0.00	0.00	0.00	0.00	83.15	83.15	0.00	0.00	0.00	0.00	0.00	0.00	53.04	53.04	0.00	0.00	61.75	61.75	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	197.94	197.94	100.00			
04/06/2022	0.00	0.00	0.00	0.00	0.00	0.00	83.13	83.13	0.00	0.00	0.00	0.00	0.00	0.00	53.09	53.09	0.00	0.00	61.95	61.95	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	198.17	198.17	100.00			
05/06/2022	0.00	0.00	0.00	0.00	0.00	0.00	83.94	83.94	0.00	0.00	0.00	0.00	0.00	0.00	53.79	53.79	0.00	0.00	62.54	62.54	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	200.26	200.26	100.00			
06/06/2022	0.00	0.00	0.00	0.00	0.00	0.00	84.93	84.93	0.00	0.00	0.00	0.00	0.00	0.00	54.60	54.60	0.00	0.00	63.36	63.36	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	202.90	202.90	100.00			
07/06/2022	0.00	0.00	0.00	0.00	0.00	0.00	76.59	76.59	0.00	0.00	0.00	0.00	0.00	0.00	60.54	60.54	0.00	0.00	69.60	69.60	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	206.73	206.73	100.00			
08/06/2022	0.00	0.04	0.31	0.35	0.00	0.00	75.00	75.00	0.00	0.00	0.00	0.00	0.00	0.00	63.25	63.25	0.00	0.00	72.23	72.23	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	210.79	210.83	99.98			
09/06/2022	0.00	0.00	0.00	0.00	0.00	0.00	75.00	75.00	0.00	0.00	0.00	0.00	0.00	0.00	64.90	64.90	0.00	0.00	73.56	73.56	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	213.46	213.46	100.00			
10/06/2022	0.00	0.00	0.00	0.00	0.00	0.00	74.98	74.98	0.00	0.00	33.43	33.43	0.00	0.00	28.62	28.62	0.00	0.00	34.12	34.12	0.00	0.00	0.37	39.43	39.79	0.00	0.37	210.58	210.94	99.83				
11/06/2022	0.00	0.00	0.00	0.00	0.00	0.00	74.99	74.99	0.00	0.00	62.93	62.93	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.59	77.43	78.02	0.00	0.59	215.35	215.95	99.72							
12/06/2022	0.00	0.00	0.00	0.00	0.00	0.00	75.00	75.00	0.00	0.00	63.10	63.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	2.11	75.77	77.87	0.00	2.11	213.87	215.97	99.02							
13/06/2022	0.00	0.00	0.00	0.00	0.00	0.00	74.99	74.99	0.00	0.00	61.83	61.83	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.79	75.22	76.01	0.00	0.79	212.04	212.82	99.63							
14/06/2022	0.00	0.00	0.00	0.00	0.00	0.00	74.95	75.01	0.00	0.00	59.25	59.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.02	72.87	73.89	0.00	1.08	207.07	208.15	99.48							
15/06/2022	0.00	0.00	0.00	0.00	0.00	0.00	74.99	74.99	0.00	0.00	58.33	58.33	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.66	73.00	73.66	0.00	0.66	206.33	206.99	99.68							
16/06/2022	0.00	0.30	42.47	42.77	0.00	0.00	30.11	30.11	0.00	0.00	61.21	61.21	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.76	75.97	76.73	0.00	1.06	209.77	210.82	99.50							
17/06/2022	0.00	0.24	69.68	69.92	0.00	0.00	0.00	0.00	0.00	0.00	62.11	62.11	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.68	76.33	78.01	0.00	1.93	208.11	210.04	99.08							
18/06/2022	0.00	0.38	67.85	68.22	0.00	0.00	0.00	0.00	0.00	0.00	62.46	62.46	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.59	76.58	77.17	0.00	0.97	206.88	207.85	99.53							
19/06/2022	0.00	0.33	68.67	69.01	0.00	0.00	0.00	0.00	0.00	0.00	63.23	63.23	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.87	77.31	78.17	0.00	1.20	209.21	210.41	99.43							
20/06/2022	0.00	0.34	70.09	70.44	0.00	0.00	0.00	0.00	0.00	0.00	62.53	62.53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.26	77.77	79.03	0.00	1.61	210.39	212.00	99.24							
21/06/2022	0.02	0.56	62.12	62.70	0.00	0.00	0.00	0.00	0.89	26.92	27.81	0.00	0.00	32.44	32.44	0.00	0.00	43.31	43.90	0.00	0.00	0.58	25.55	26.13	0.02	2.61	190.34	192.97	98.63					
22/06/2022	0.00	0.38	41.05	41.42	0.00	0.06	18.64	18.70	0.00	0.03	29.39	29.42	0.00	0.00	71.02	71.02	0.03	0.03	26.75	26.81	0.00	0.00	0.17	32.00	32.17	0.03	0.67	218.84	219.54	99.68				
23/06/2022	0.00	0.60	78.39	78.99	0.00	0.00	0.00	0.00	0.00	14.18	14.18	0.00	0.00	48.48	48.48	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.34	78.01	78.35	0.00	0.94	219.07	220.01	99.57				
24/06/2022	0.00	0.41	73.93	74.34	0.00	0.00	0.00	0.00	0.00	38.20	38.20	0.00	0.00	30.81	30.81	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.74	75.12	75.86	0.00	1.15	218.06	219.21	99.47			
25/06/2022	0.00	0.37	74.81	75.17	0.00	0.00	0.00	0.00	0.00	69.53	69.53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.75	69.85	70.60	0.00	1.12	214.19	215.30	99.48
26/06/2022	0.00	0.32	77.37	77.89	0.00	0.00	0.00	0.00	0.00	67.71	67.71	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.80	66.43	67.23	0.00	1.12	211.52	212.64	99.47
27/06/2022	0.01	0.50	71.37	71.89	0.00	0.00	0.00	0.00	0.02	47.21	47.24	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.67	64.89	65.58	0.05	1.19	183.47	184.71	99.33
28/06/2022	0.00	0.48	75.74	76.21	0.00	0.00	0.00	0.00	0.00	52.22	52.22	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.90	63.69	64.59	0.00	1.38	191.65	193.02	99.29
29/06/2022	0.00	0.71	77.84	78.56	0.00	0.00	0.00	0.00	0.00	49.93	49.93	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.49	63.05	63.54	0.00	1.20	190.82	192.03	99.37	
30/06/2022	0.00	0.39	77.61	78.00	0.00	0.00	0.00	0.00	0.00	50.66	50.66	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.54	64.41	64.94	0.00	0.92	192.68	193.60	99.52	

**Notes:** 1. UV Comparative Dose: 18.1 mJ/cm<sup>2</sup>

Submitted By (Print): D.Merredew

Signature: Original signed by D.Merredew

Page 1 of 2

**CITY OF WINNIPEG**  
 WATER AND WASTE DEPARTMENT  
 WATER SERVICES

Water System Code: **252.00**  
 Licence Number: **PWS-09-412-02**

Report Period: **June 2022**

Report Created: **Friday, July 01, 2022**

**WATER TREATMENT PLANT UV REPORT**

Date	Transmittance (%)				UVR_D100A			UVR_D200A			UVR_D300A			UVR_D400A			UVR_D500A			UVR_D600A		
	Branch 1		Branch 2		UV Dose [mJ/cm <sup>2</sup> ]																	
01/06/2022	96.3	49.8	96.8	96.1	OL	OL	OL	18.4	22.7	21.1	OL	OL	OL	18.0	23.3	21.3	17.9	23.2	21.2	OL	OL	OL
02/06/2022	96.3	77.9	96.8	96.1	OL	OL	OL	18.5	22.1	21.1	OL	OL	OL	18.5	24.5	21.4	18.1	21.8	21.2	OL	OL	OL
03/06/2022	96.3	89.2	96.8	96.1	OL	OL	OL	18.6	22.7	21.1	OL	OL	OL	18.8	24.4	21.4	18.1	21.9	21.2	OL	OL	OL
04/06/2022	96.3	89.8	96.7	94.9	OL	OL	OL	18.5	23.0	21.1	OL	OL	OL	18.7	24.1	21.4	17.8	21.9	21.2	OL	OL	OL
05/06/2022	96.3	89.9	96.8	96.1	OL	OL	OL	18.5	21.7	21.1	OL	OL	OL	18.7	24.4	21.3	17.9	22.1	21.2	OL	OL	OL
06/06/2022	96.2	84.5	96.7	96.0	OL	OL	OL	18.5	29.4	21.1	OL	OL	OL	18.7	28.2	21.3	17.9	27.0	21.2	OL	OL	OL
07/06/2022	96.3	89.0	96.8	96.3	OL	OL	OL	18.4	29.0	21.4	OL	OL	OL	18.8	22.6	21.3	18.0	22.9	21.1	OL	OL	OL
08/06/2022	95.8	86.0	96.1	93.1	0.0	67.5	24.7	18.4	26.2	21.5	OL	OL	OL	18.6	22.8	21.2	18.1	22.3	21.1	OL	OL	OL
09/06/2022	95.7	84.0	96.0	95.3	OL	OL	OL	18.5	25.6	21.5	OL	OL	OL	18.5	21.8	21.2	17.8	21.7	21.1	OL	OL	OL
10/06/2022	96.0	90.9	96.4	95.3	OL	OL	OL	18.4	30.5	21.5	26.8	62.6	29.0	0.0	29.7	21.2	0.0	26.0	21.1	16.2	84.6	21.3
11/06/2022	96.1	85.4	96.5	96.0	OL	OL	OL	18.4	23.6	21.4	23.6	27.7	25.1	OL	OL	OL	OL	OL	OL	16.4	21.7	21.1
12/06/2022	96.1	82.5	96.5	95.6	OL	OL	OL	18.6	23.3	21.4	22.0	24.4	23.3	OL	OL	OL	OL	OL	OL	16.7	23.5	21.1
13/06/2022	96.0	87.9	96.4	94.8	OL	OL	OL	18.2	24.0	21.4	20.9	22.9	21.8	OL	OL	OL	OL	OL	OL	16.6	24.3	21.1
14/06/2022	96.0	86.1	96.5	96.1	OL	OL	OL	15.8	29.5	21.1	20.9	22.4	21.6	OL	OL	OL	OL	OL	OL	16.2	25.0	21.1
15/06/2022	95.8	85.3	96.2	95.6	OL	OL	OL	18.6	23.6	21.1	21.3	23.3	22.0	OL	OL	OL	OL	OL	OL	16.3	21.7	21.1
16/06/2022	95.5	84.9	95.8	95.3	16.2	75.9	21.3	0.0	32.8	21.4	20.7	37.8	21.4	OL	OL	OL	OL	OL	OL	16.5	31.8	21.1
17/06/2022	95.4	85.8	95.8	95.3	17.4	32.3	21.2	OL	OL	OL	20.5	22.0	21.3	OL	OL	OL	OL	OL	OL	16.5	21.7	21.1
18/06/2022	96.0	78.7	96.3	95.2	17.3	31.9	21.2	OL	OL	OL	20.4	22.2	21.3	OL	OL	OL	OL	OL	OL	16.4	21.8	21.1
19/06/2022	96.1	90.1	96.3	95.3	17.4	31.9	21.2	OL	OL	OL	20.5	22.4	21.3	OL	OL	OL	OL	OL	OL	16.3	21.7	21.1
20/06/2022	96.1	91.7	96.3	95.6	17.5	33.1	21.2	OL	OL	OL	20.4	22.2	21.3	OL	OL	OL	OL	OL	OL	15.7	21.7	21.1
21/06/2022	95.8	70.0	96.0	94.6	0.0	72.2	21.5	OL	OL	OL	0.0	37.1	20.9	0.0	64.9	21.3	0.0	40.8	21.1	0.0	44.4	21.3
22/06/2022	96.1	88.0	96.3	95.7	15.7	73.4	21.3	0.0	63.2	21.3	0.0	38.9	21.7	18.5	28.3	21.4	0.0	30.8	21.2	17.5	84.6	22.2
23/06/2022	96.1	92.7	96.3	95.6	17.3	31.4	21.2	OL	OL	OL	0.0	66.4	28.0	0.0	103.5	21.4	OL	OL	OL	16.9	23.1	21.4
24/06/2022	96.1	91.5	96.4	95.3	17.2	31.4	21.3	OL	OL	OL	21.5	102.0	26.5	0.0	38.6	21.2	OL	OL	OL	16.2	22.6	21.3
25/06/2022	96.2	82.0	96.5	96.0	17.3	39.2	21.3	OL	OL	OL	19.8	51.1	24.8	OL	OL	OL	OL	OL	OL	16.0	40.6	21.1
26/06/2022	96.3	55.0	96.5	95.8	17.1	28.6	21.2	OL	OL	OL	20.0	28.5	24.6	OL	OL	OL	OL	OL	OL	16.1	22.6	21.2
27/06/2022	96.2	0.0	96.5	0.0	0.0	105.2	21.5	OL	OL	OL	0.0	105.9	29.5	OL	OL	OL	OL	OL	OL	0.0	76.3	21.2
28/06/2022	95.9	2.4	96.3	95.3	17.5	28.1	21.2	OL	OL	OL	23.9	31.0	29.6	OL	OL	OL	OL	OL	OL	16.4	23.4	21.2
29/06/2022	96.1	2.7	96.5	95.5	17.3	27.5	21.2	OL	OL	OL	25.2	33.1	31.1	OL	OL	OL	OL	OL	OL	16.0	30.7	21.3
30/06/2022	96.1	2.8	96.6	96.0	17.3	28.3	21.2	OL	OL	OL	25.5	32.5	31.1	OL	OL	OL	OL	OL	OL	15.8	27.7	21.6

**Notes:**

1. UV Comparative Dose: 18.1 mJ/cm<sup>2</sup>
2. OL - Off Line

Submitted By (Print): D.Merredew

Signature: Original signed by D.Merredew

Page 2 of 2