



Water and Waste Eaux et déchets

Kale Black, Sr. Drinking Water Officer
Office of Drinking Water, Manitoba Conservation and Climate
309 – 25 Tupper Street North
Portage La Prairie, MB R1N 3K1

October 7, 2022

RE: SEPTEMBER 2022 WATER QUALITY COMPLIANCE SUBMISSION FOR THE CITY OF WINNIPEG WATER SUPPLY SYSTEM

Please find attached on-line and grab turbidity summary reports, on-line and grab chlorine summary reports and the UV summary report for the Water Treatment Plant for September 2022.

The September on-line and grab sampling turbidity reports include results obtained for the Water Treatment Plant raw water and the eight filters. A grab sample was not collected from Filter 6 on September 28 due to a miscommunication between Lab staff and Operations staff; additional information is provided in CAR-06-2022. The turbidity results for the filter effluent met the licence requirements.

The September on-line and grab sampling chlorine reports include results obtained for the Deacon Booster Pumping Station at the Water Treatment Plant. The free chlorine results at the Water Treatment Plant met the licence requirements.

The September UV summary report includes results obtained for the six UV reactors at the Water Treatment Plant. The UV disinfection results met the licence requirements.

Please let me know of any concerns or questions respecting this submission. I can be reached by telephone at 204-986-8359 or by e-mail at rgrosselle@winnipeg.ca.

Yours sincerely,

R. Grosselle
Manager of Environmental Standards

Enclosures

cc: Dr. L. Richards, Winnipeg Regional Health Authority (email)
Dr. H. Chang, Winnipeg Regional Health Authority (email)
Dr. T. Hilderman, Manitoba Health and Seniors Care (email)
T. Shanks, M. Eng., P. Eng. (e-mail)
M. Szmon, P. Eng. (e-mail)
C. Diduck (email)



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
WATER SERVICES

Water System Code: 252.00
Licence Number: PWS-09-412-02

WATER TREATMENT PLANT TURBIDITY ON-LINE MONITORING REPORT

September 2022	Turbidity (NTU)																								
Date	Raw	Filter #1	Avg	Max	Filter #2	Avg	Max	Filter #3	Avg	Max	Filter #4	Avg	Max	Filter #5	Avg	Max	Filter #6	Avg	Max	Filter #7	Avg	Max	Filter #8	Avg	Max
1/09/2022	2.08	0.04	0.09		0.04	0.09		0.02	0.06		0.09	0.11		0.05	0.10		0.06	0.11		0.05	0.07		0.04	0.09	
2/09/2022	2.13	0.07	0.08		0.04	0.11		0.02	0.04		0.08	0.14		0.07	0.11		0.06	0.13		0.07	0.12		0.04	0.11	
3/09/2022	2.39	0.08	0.14		0.07	0.09		0.03	0.06		0.09	0.14		0.09	0.12		0.06	0.14		0.06	0.13		0.05	0.10	
4/09/2022	2.24	0.09	0.15		0.06	0.12		0.02	0.07		0.09	0.16		0.08	0.13		0.08	0.09		0.06	0.11		0.06	0.08	
5/09/2022	2.56	0.10	0.17		0.07	0.14		0.02	0.07		0.12	0.15		0.08	0.13		0.09	0.14		0.07	0.09		0.05	0.10	
6/09/2022	2.24	0.14	0.16		0.09	0.14		0.02	0.04		0.12	0.16		0.08	0.13		0.09	0.17		0.08	0.13		0.05	0.11	
7/09/2022	2.28	0.11	0.20		0.07	0.14		0.03	0.08		0.10	0.18		0.08	0.13		0.07	0.13		0.07	0.15		0.06	0.08	
8/09/2022	2.05	0.13	0.22		0.06	0.14		0.06	0.14		0.13	0.17		0.07	0.12		0.07	0.09		0.08	0.14		0.08	0.12	
9/09/2022	1.98	0.09	0.18		0.07	0.16		0.07	0.15		0.12	0.21		0.09	0.14		0.07	0.14		0.10	0.22		0.07	0.13	
10/09/2022	1.97	0.10	0.14		0.07	0.10		0.08	0.11		0.09	0.17		0.09	0.18		0.08	0.18		0.10	0.17		0.07	0.12	
11/09/2022	2.12	0.08	0.15		0.09	0.16		0.08	0.15		0.10	0.16		0.11	0.16		0.09	0.16		0.10	0.18		0.07	0.12	
12/09/2022	2.15	0.08	0.13		0.08	0.16		0.08	0.15		0.09	0.16		0.12	0.19		0.11	0.13		0.10	0.16		0.08	0.12	
13/09/2022	2.21	0.08	0.15		0.07	0.14		0.07	0.14		0.10	0.13		0.12	0.19		0.12	0.17		0.10	0.13		0.07	0.11	
14/09/2022	2.12	0.09	0.12		0.07	0.14		0.07	0.10		0.10	0.16		0.12	0.20		0.13	0.21		0.12	0.17		0.06	0.12	
15/09/2022	2.31	0.09	0.15		0.08	0.11		0.07	0.13		0.08	0.17		0.15	0.19		0.14	0.24		0.10	0.17		0.06	0.11	
16/09/2022	2.73	0.07	0.12		0.06	0.14		0.06	0.14		0.08	0.11		0.11	0.21		0.11	0.20		0.07	0.12		0.06	0.10	
17/09/2022	2.32	0.07	0.09		0.04	0.11		0.05	0.07		0.07	0.12		0.09	0.15		0.06	0.12		0.06	0.08		0.05	0.09	
18/09/2022	1.85	0.08	0.13		0.05	0.07		0.07	0.12		0.06	0.12		0.10	0.14		0.07	0.14		0.06	0.12		0.05	0.11	
19/09/2022	1.80	0.08	0.14		0.05	0.11		0.07	0.12		0.05	0.15		0.12	0.16		0.08	0.10		0.07	0.11		0.06	0.08	
20/09/2022	1.89	0.07	0.10		0.05	0.11		0.06	0.13		0.07	0.10		0.11	0.17		0.09	0.16		0.07	0.08		0.06	0.10	
21/09/2022	2.06	0.08	0.15		0.05	0.12		0.06	0.13		0.05	0.19		0.10	0.18		0.08	0.17		0.06	0.13		0.04	0.09	
22/09/2022	2.06	0.09	0.14		0.06	0.12		0.06	0.11		0.05	0.12		0.14	0.18		0.10	0.13		0.07	0.13		0.06	0.07	
23/09/2022	2.10	0.09	0.16		0.06	0.12		0.06	0.12		0.06	0.08		0.14	0.20		0.14	0.17		0.07	0.09		0.05	0.10	
24/09/2022	1.83	0.11	0.13		0.06	0.14		0.06	0.12		0.06	0.11		0.15	0.23		0.13	0.22		0.09	0.14		0.05	0.09	
25/09/2022	1.55	0.10	0.17		0.08	0.10		0.07	0.11		0.05	0.10		0.16	0.21		0.15	0.22		0.09	0.14		0.05	0.09	
26/09/2022	1.55	0.10	0.17		0.08	0.14		0.06	0.12		0.05	0.10		0.17	0.23		0.14	0.20		0.09	0.16		0.06	0.08	
27/09/2022	1.45	0.11	0.18		0.09	0.15		0.06	0.12		0.06	0.09		0.13	0.21		0.10	0.15		0.10	0.12		0.06	0.11	
28/09/2022	1.58	0.14	0.17		0.09	0.17		0.06	0.09		0.05	0.11		0.13	0.20		0.03	0.18		0.12	0.17		0.05	0.13	
29/09/2022	1.54	0.13	0.20		0.10	0.14		0.07	0.12		0.05	0.09		0.13	0.20		OL	OL		0.12	0.19		0.06	0.12	
30/09/2022	1.54	0.14	0.19		0.12	0.19		0.06	0.13		0.06	0.10		0.15	0.21		OL	OL		0.14	0.20		0.07	0.12	

Total Number of Measurements Taken, A: 13531 13719 13492 14347 15383 14205 15067 16148
Turbidity Standard for Monitoring Location (NTU): 0.3 0.3 0.3 0.3 0.3 0.3 0.3 0.3
Number of Measurements Meeting Standard, B: 13531 13719 13492 14347 15383 14205 15067 16148
Compliance with Turbidity Standard, C = B/A X 100%: 100.000% 100.000% 100.000% 100.000% 100.000% 100.000% 100.000% 100.000%
OL: Offline

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Turbidity\2022\09-September

Submitted By (Print): D.Merredew

Signature: Original signed by D.Merredew



Water and Waste
Eaux et déchets

CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENVIRONMENTAL STANDARDS DIVISION

WATER TREATMENT PLANT TURBIDITY GRAB MONITORING REPORT

Water System Code: 252.00	Turbidity (NTU)																	
	Raw Water		Filter 1		Filter 2		Filter 3		Filter 4		Filter 5		Filter 6		Filter 7		Filter 8	
Date	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser
01-Sep-2022	1.82	1.93	0.11	0.05	0.10	0.04	0.11	0.02	0.11	0.09	0.15	0.09	0.13	0.07	0.13	0.04	0.14	0.06
02-Sep-2022	1.74	2.11	0.11	0.07	0.11	0.05	0.11	0.02	0.13	0.11	0.09	0.18	0.11	0.14	0.09	0.12	0.04	
03-Sep-2022	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	
04-Sep-2022	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	
05-Sep-2022	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	
06-Sep-2022	1.81	2.51	0.12	0.15	0.12	0.10	0.12	0.03	0.12	0.14	0.11	0.10	0.16	0.12	0.15	0.08	0.13	0.05
07-Sep-2022	1.78	2.12	0.14	0.18	0.12	0.12	0.13	0.04	0.10	0.13	0.12	0.12	0.10	0.16	0.10	0.12	0.05	
08-Sep-2022	1.84	1.98	0.19	0.16	0.18	0.13	0.17	0.08	0.18	0.16	0.16	0.10	0.14	0.07	0.12	0.08	0.13	0.07
09-Sep-2022	1.73	1.97	0.18	0.16	0.16	0.06	0.17	0.07	0.16	0.15	0.10	0.08	0.15	0.10	0.13	0.09	0.17	0.09
10-Sep-2022	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	
11-Sep-2022	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	
12-Sep-2022	1.70	2.03	0.17	0.08	0.19	0.13	0.17	0.10	0.18	0.12	0.15	0.15	0.14	0.12	0.13	0.10	0.14	0.08
13-Sep-2022	1.45	1.88	0.16	0.08	0.15	0.06	0.16	0.07	0.15	0.09	0.16	0.08	0.14	0.14	0.13	0.10	0.14	0.08
14-Sep-2022	1.41	2.00	0.18	0.10	0.17	0.08	0.17	0.08	0.17	0.11	0.10	0.13	0.17	0.18	0.13	0.11	0.16	0.08
15-Sep-2022	1.44	2.22	0.19	0.12	0.17	0.08	0.18	0.08	0.14	0.09	0.11	0.15	0.12	0.16	0.15	0.12	0.11	0.06
16-Sep-2022	1.45	2.59	0.15	0.08	0.21	0.11	0.19	0.10	0.16	0.11	0.16	0.19	0.13	0.19	0.12	0.10	0.13	0.07
17-Sep-2022	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	
18-Sep-2022	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	
19-Sep-2022	1.12	1.76	0.15	0.08	0.19	0.09	0.20	0.10	0.17	0.08	0.15	0.15	0.15	0.08	0.12	0.06	0.13	0.05
20-Sep-2022	1.21	1.80	0.15	0.09	0.14	0.05	0.14	0.06	0.13	0.07	0.17	0.17	0.14	0.12	0.12	0.07	0.16	0.08
21-Sep-2022	1.26	2.05	0.19	0.13	0.17	0.08	0.17	0.10	0.21	0.13	0.13	0.15	0.11	0.11	0.12	0.07	0.11	0.05
22-Sep-2022	1.22	2.07	0.13	0.09	0.17	0.08	0.17	0.08	0.13	0.06	0.10	0.15	0.12	0.13	0.11	0.07	0.12	0.06
23-Sep-2022	1.24	2.06	0.17	0.10	0.15	0.06	0.16	0.06	0.13	0.06	0.13	0.17	0.13	0.14	0.11	0.07	0.12	0.05
24-Sep-2022	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	
25-Sep-2022	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	0.09	0.17	ns	ns	ns	
26-Sep-2022	1.37	1.88	0.13	0.11	0.17	0.11	0.16	0.08	0.13	0.06	0.12	0.21	0.11	0.19	0.11	0.09	0.12	0.06
27-Sep-2022	1.24	1.51	0.13	0.13	0.13	0.09	0.13	0.06	0.14	0.07	0.12	0.17	0.12	0.11	0.11	0.10	0.12	0.07
28-Sep-2022	1.11	1.41	0.14	0.14	0.13	0.11	0.14	0.07	0.14	0.07	0.09	0.15	o/l	o/l	0.13	0.13	0.13	0.08
29-Sep-2022	1.57	1.52	0.16	0.17	0.14	0.12	0.14	0.08	0.14	0.07	0.09	0.17	o/l	o/l	0.16	0.16	0.11	0.06
30-Sep-2022	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	
Total number of measurements taken, A:	20		20		20		20		20		20		19		20		20	
Turbidity Standard for Monitoring Location (NTU):	0.30		0.30		0.30		0.30		0.30		0.30		0.30		0.30		0.30	
Number of measurements meeting standard, B:	20		20		20		20		20		20		19		20		20	
Compliance with Turbidity Standard, C= B/A X 100%:	100%		100%		100%		100%		100%		100%		100%		100%		100%	

na: not analyzed nr: no result ns: no sample o/l: offline im: instrument maintenance

Comments:

The raw water analyzer is cleaned daily during warm water months because it is susceptible to frequent fouling

Filter 6 was taken offline for scheduled maintenance on September 28, 2022.

Report Date: 4-Oct-2022

**City Of Winnipeg**Water and Waste Department
Water Services**WATER TREATMENT PLANT FREE CHLORINE ON-LINE MONITORING REPORT**
Deacon Booster Pumping Station

Water System Code: **252.00**
Licence Number: **PWS-09-412-02**
Report Created: 01 October 2022

Report Period: September 2022

Date	BRANCH 1 [mg/L]		BRANCH 2 [mg/L]	
	Average	Minimum	Average	Minimum
01/09/2022	1.77	1.51	1.67	1.50
02/09/2022	1.80	1.65	1.71	1.52
03/09/2022	1.84	1.51	1.72	1.38
04/09/2022	1.58	1.32	1.50	1.14
05/09/2022	1.61	1.44	1.55	1.44
06/09/2022	1.55	1.41	1.54	1.42
07/09/2022	1.63	1.38	1.61	1.39
08/09/2022	1.62	1.43	1.63	1.41
09/09/2022	1.62	1.48	1.66	1.54
10/09/2022	1.56	1.30	1.60	1.36
11/09/2022	1.64	1.48	1.66	1.58
12/09/2022	1.59	1.42	1.62	1.49
13/09/2022	1.54	1.40	1.59	1.49
14/09/2022	1.67	1.38	1.69	1.49
15/09/2022	1.51	1.24	1.56	1.41
16/09/2022	1.44	1.33	1.51	1.37
17/09/2022	1.58	1.24	1.59	1.28
18/09/2022	1.74	1.60	1.71	1.60
19/09/2022	1.71	1.56	1.68	1.55
20/09/2022	1.69	1.28	1.59	1.16
21/09/2022	1.74	1.18	1.73	1.49
22/09/2022	1.87	1.77	1.78	1.61
23/09/2022	1.85	1.35	1.80	1.60
24/09/2022	1.66	1.51	1.62	1.49
25/09/2022	1.71	1.38	1.60	1.40
26/09/2022	1.81	1.53	1.77	1.65
27/09/2022	1.71	1.60	1.73	1.62
28/09/2022	1.77	1.68	1.72	1.61
29/09/2022	1.70	1.58	1.66	1.57
30/09/2022	1.61	1.45	1.60	1.47

Total Number of Measurements, A: 20880 20879
Minimum Free Chlorine Standard: 0.5 0.5
Number of Measurements Meeting Standard, B: 20880 20879
COMPLIANCE, C = B/A X 100%: 100.00 100.00

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Chlorine\2022\09-September

Submitted By (Print): D.MerredewSignature: Original signed by D.Merredew



Water and Waste
Eaux et déchets

CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENVIRONMENTAL STANDARDS DIVISION

WATER TREATMENT PLANT CHLORINE GRAB MONITORING REPORT

Water System Code: 252.00	Deacon Booster Pumping Station Branch 1			Deacon Booster Pumping Station Branch 2		
	Date	Free Chlorine (mg/L)	Total Chlorine (mg/L)	Free Chlorine (mg/L)	Total Chlorine (mg/L)	
		Analyser	Grab	Grab	Analyser	Grab
01-Sep-2022		1.73	1.72	1.92	1.72	1.78
02-Sep-2022		1.72	1.72	2.02	1.68	1.77
03-Sep-2022		ns	ns	ns	ns	ns
04-Sep-2022		ns	ns	ns	ns	ns
05-Sep-2022		ns	ns	ns	ns	ns
06-Sep-2022		1.57	1.60	1.83	1.52	1.58
07-Sep-2022		1.63	1.73	1.98	1.61	1.69
08-Sep-2022		1.65	1.71	1.96	1.61	1.69
09-Sep-2022		1.65	1.62	1.85	1.63	1.65
10-Sep-2022		ns	ns	ns	ns	ns
11-Sep-2022		ns	ns	ns	ns	ns
12-Sep-2022		1.59	1.61	1.89	1.62	1.60
13-Sep-2022		1.47	1.51	1.73	1.60	1.61
14-Sep-2022		1.72	1.66	1.90	1.77	1.87
15-Sep-2022		1.56	1.59	1.83	1.55	1.65
16-Sep-2022		1.44	1.55	1.74	1.49	1.52
17-Sep-2022		ns	ns	ns	ns	ns
18-Sep-2022		ns	ns	ns	ns	ns
19-Sep-2022		1.66	1.67	1.92	1.70	1.75
20-Sep-2022		1.77	1.74	1.99	1.60	1.66
21-Sep-2022		1.79	1.81	2.10	1.70	1.79
22-Sep-2022		1.84	1.81	2.15	1.73	1.77
23-Sep-2022		1.93	1.93	2.20	1.74	2.02
24-Sep-2022		ns	ns	ns	ns	ns
25-Sep-2022		ns	ns	ns	ns	ns
26-Sep-2022		1.94	1.85	2.14	1.81	1.84
27-Sep-2022		1.74	1.74	1.98	1.72	1.73
28-Sep-2022		1.73	1.75	2.00	1.75	1.73
29-Sep-2022		1.70	1.69	1.96	1.70	1.72
30-Sep-2022		ns	ns	ns	ns	ns
Total number of measurements taken, A:		20				20
Chlorine Standard for Monitoring Location (mg/L):		0.50				0.50
Number of measurements meeting standard, B:		20				20
Compliance with Chlorine Standard, C= B/A X 100%:		100%				100%

na: not analyzed nr: no result ns: no sample o/l: offline im: instrument maintenance

Comments:

Report Date: 4-Oct-2022



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
WATER SERVICES

Water System Code: 252.00
Licence Number: PWS-09-412-02

WATER TREATMENT PLANT UV REPORT

Report Period: September 2022

Report Created: Saturday, October 01, 2022

Date	UVR-D100A				UVR-D200A				UVR-D300A				UVR-D400A				UVR-D500A				UVR-D600A				Total				% Volume Treated To Dose	
	Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]					
	Untreated	Below	To	Total	Untreated	Below	To	Total																						
01/09/2022	0.00	0.00	61.34	61.34	0.00	0.00	0.00	0.00	0.00	0.00	42.92	42.92	0.00	0.00	25.11	25.11	0.00	0.00	65.66	65.66	0.00	0.00	0.00	0.00	0.00	0.00	195.03	195.03	100.00	
02/09/2022	0.00	0.05	58.64	58.69	0.00	0.00	0.00	0.00	0.00	0.00	66.34	66.34	0.00	0.00	0.00	0.00	0.00	0.00	65.02	65.02	0.00	0.00	0.00	0.00	0.00	0.05	190.01	190.01	99.98	
03/09/2022	0.00	0.63	69.81	70.44	0.00	0.00	0.00	0.00	0.00	0.00	58.28	58.28	0.00	0.00	0.00	0.00	0.00	0.00	65.30	65.30	0.00	0.00	0.00	0.00	0.00	0.63	193.39	194.02	99.68	
04/09/2022	0.00	0.54	75.20	75.74	0.00	0.00	0.00	0.00	0.00	0.00	55.57	55.57	0.00	0.00	0.00	0.00	0.00	0.00	66.19	66.19	0.00	0.00	0.00	0.00	0.00	0.54	196.96	197.50	99.72	
05/09/2022	0.00	0.30	60.13	60.42	0.00	0.00	0.00	0.00	0.00	0.10	68.53	68.63	0.00	0.00	0.00	0.00	0.00	0.00	66.97	66.97	0.00	0.00	0.00	0.00	0.00	0.39	195.62	196.02	99.80	
06/09/2022	0.00	0.48	61.42	61.90	0.00	0.00	0.00	0.00	0.00	0.10	69.68	69.79	0.00	0.00	0.00	0.00	0.00	0.00	68.28	68.28	0.00	0.00	0.00	0.00	0.00	0.58	199.39	199.96	99.71	
07/09/2022	0.00	0.58	63.47	64.05	0.00	0.00	0.00	0.00	0.00	0.25	71.37	71.63	0.00	0.00	0.00	0.00	0.00	0.00	70.33	70.33	0.00	0.00	0.00	0.00	0.00	0.83	205.18	206.01	99.60	
08/09/2022	0.00	0.72	63.74	64.45	0.00	0.00	0.00	0.00	0.00	0.25	71.17	71.42	0.00	0.00	0.00	0.00	0.00	0.00	70.11	70.11	0.00	0.00	0.00	0.00	0.00	0.97	205.02	205.99	99.53	
09/09/2022	0.00	0.72	63.25	63.98	0.00	0.00	0.00	0.00	0.00	0.30	70.84	71.14	0.00	0.00	0.00	0.00	0.00	0.00	69.85	69.85	0.00	0.00	0.00	0.00	0.00	1.02	203.94	204.96	99.50	
10/09/2022	0.00	0.39	62.36	62.75	0.00	0.00	0.00	0.00	0.00	0.35	71.10	71.45	0.00	0.00	0.00	0.00	0.00	0.00	69.85	69.85	0.00	0.00	0.00	0.00	0.00	0.74	203.30	204.04	99.64	
11/09/2022	0.00	0.58	61.80	62.38	0.00	0.00	0.00	0.00	0.00	0.35	71.17	71.52	0.00	0.00	0.00	0.00	0.05	0.00	70.02	70.07	0.00	0.00	0.00	0.00	0.00	0.98	202.99	203.96	99.52	
12/09/2022	0.00	0.61	61.51	62.12	0.00	0.00	0.00	0.00	0.00	0.45	71.31	71.77	0.00	0.00	0.00	0.00	0.00	0.00	70.15	70.15	0.00	0.00	0.00	0.00	0.00	1.06	202.97	204.03	99.48	
13/09/2022	0.00	0.69	61.81	62.50	0.00	0.00	0.00	0.00	0.00	0.50	71.08	71.58	0.00	0.00	0.00	0.00	0.00	0.05	69.90	69.95	0.00	0.00	0.00	0.00	0.00	1.24	202.79	204.03	99.39	
14/09/2022	0.00	0.21	29.81	30.02	0.00	0.00	33.45	33.45	0.00	0.48	68.16	68.64	0.00	0.00	0.00	0.00	0.00	0.29	23.93	24.22	0.00	0.09	43.05	43.14	0.00	1.07	198.39	199.47	99.46	
15/09/2022	0.00	0.00	0.00	0.00	0.19	0.19	33.53	33.92	0.00	0.19	52.96	53.15	0.00	0.00	27.83	27.83	0.00	0.00	50.67	50.67	0.00	0.09	25.24	25.33	0.19	0.47	190.24	190.91	99.65	
16/09/2022	0.00	0.00	0.00	0.00	0.00	0.25	48.75	49.00	0.00	0.03	42.18	42.21	0.00	0.00	17.06	17.06	0.00	0.00	70.31	70.31	0.00	0.00	0.00	0.00	0.00	0.29	178.30	178.58	99.84	
17/09/2022	0.00	0.00	0.00	0.00	0.20	0.20	23.83	24.23	0.00	0.16	54.84	55.00	0.00	0.00	0.00	0.00	0.00	0.30	46.95	46.95	0.00	0.30	47.24	47.54	0.20	0.65	172.87	173.71	99.51	
18/09/2022	0.00	0.00	0.00	0.00	0.00	0.00	0.40	63.15	63.54	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	39.18	39.18	0.00	0.84	70.40	71.24	0.00	1.24	172.73	173.97	99.29		
19/09/2022	0.00	0.00	33.95	33.95	0.00	0.00	0.00	0.00	0.00	0.42	38.97	39.39	0.00	0.00	0.00	0.00	0.00	0.00	39.34	39.34	0.00	0.88	69.44	70.32	0.00	1.30	181.70	183.01	99.29	
20/09/2022	0.00	0.00	83.44	83.44	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	35.08	35.08	0.00	0.70	61.73	62.43	0.00	0.70	180.25	180.96	99.61		
21/09/2022	0.01	0.01	69.34	69.36	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	34.71	34.71	0.00	0.76	60.33	61.09	0.01	0.77	164.38	165.16	99.53		
22/09/2022	0.00	0.00	84.99	84.99	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	44.40	44.40	0.00	1.77	80.73	82.50	0.00	1.77	210.13	211.89	99.17		
23/09/2022	0.00	0.00	64.00	64.00	0.00	0.27	44.44	44.70	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	17.28	17.28	0.00	1.97	79.33	81.30	0.00	2.24	205.05	207.29	98.92		
24/09/2022	0.00	0.00	59.33	59.33	0.16	0.16	28.16	28.48	0.00	0.00	0.00	0.00	0.00	0.36	37.82	38.18	0.00	0.00	0.00	0.00	1.41	69.25	70.65	0.16	1.92	194.56	196.64	98.94		
25/09/2022	0.00	0.57	32.27	32.84	0.00	0.00	42.63	42.63	0.00	0.00	0.00	0.00	0.00	0.60	28.92	29.52	0.00	0.03	19.96	19.99	0.00	1.12	68.79	69.91	0.00	2.31	192.57	194.89	98.81	
26/09/2022	0.00	0.00	0.00	0.00	0.00	0.17	76.97	77.14	0.00	0.00	0.00	0.00	0.00	0.00	23.35	23.35	0.00	0.00	25.65	25.65	0.00	1.66	65.87	67.53	0.00	1.83	191.84	193.68	99.05	
27/09/2022	0.00	0.00	0.00	0.00	0.00	0.00	63.42	63.42	0.00	0.00	0.00	0.00	0.00	0.00	65.10	65.10	0.00	0.00	0.00	0.00	0.99	61.03	62.02	0.00	0.99	189.55	190.55	99.48		
28/09/2022	0.00	0.00	0.00	0.00	0.00	0.00	66.58	66.58	0.00	0.00	0.00	0.00	0.00	0.00	67.07	67.07	0.00	0.00	0.00	0.00	1.30	61.08	62.39	0.00	1.30	194.74	196.04	99.34		
29/09/2022	0.00	0.00	0.00	0.00	0.00	0.00	66.24	66.24	0.00	0.00	0.00	0.00	0.00	0.00	67.12	67.12	0.00	0.00	0.00	0.00	1.13	61.52	62.65	0.00	1.13	194.89	196.02	99.42		
30/09/2022	0.00	0.00	0.00	0.00	0.00	0.00	66.11	66.11	0.00	0.00	0.00	0.00	0.00	0.00	66.89	66.89	0.00	0.00	0.00	0.00	1.13	61.33	62.46	0.00	1.13	194.33	195.46	99.42		

Notes: 1. UV Comparative Dose: 18.1 mJ/cm²

Submitted By (Print): D.Meredew

Signature: Original signed by D.Meredew

Page 1 of 2



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
WATER SERVICES

Water System Code: 252.00
Licence Number: PWS-09-412-02

WATER TREATMENT PLANT UV REPORT

Report Period: September 2022

Report Created: Saturday, October 01, 2022

Date	Transmittance (%)				UVR_D100A			UVR_D200A			UVR_D300A			UVR_D400A			UVR_D500A			UVR_D600A		
	Branch 1		Branch 2		UV Dose [mJ/cm ²]																	
01/09/2022	96.2	75.5	96.6	95.8	18.5	27.1	23.9	OL	OL	OL	20.6	103.9	26.5	0.0	39.0	21.2	18.2	23.2	21.2	OL	OL	OL
02/09/2022	96.0	75.8	96.3	95.6	17.7	25.5	23.3	OL	OL	OL	19.5	26.8	24.7	OL	OL	OL	18.1	22.5	21.2	OL	OL	OL
03/09/2022	95.9	79.9	96.3	95.7	17.1	39.8	21.5	OL	OL	OL	18.8	46.2	25.3	OL	OL	OL	16.6	40.5	21.2	OL	OL	OL
04/09/2022	96.0	76.3	96.4	95.3	17.2	39.0	21.2	OL	OL	OL	18.6	42.4	25.0	OL	OL	OL	18.2	36.3	21.2	OL	OL	OL
05/09/2022	96.0	84.5	96.4	96.0	17.4	23.5	21.2	OL	OL	OL	17.7	24.7	21.3	OL	OL	OL	18.0	22.7	21.2	OL	OL	OL
06/09/2022	95.9	75.6	96.3	95.6	17.4	23.3	21.2	OL	OL	OL	17.4	23.0	21.2	OL	OL	OL	17.9	22.2	21.2	OL	OL	OL
07/09/2022	95.9	72.3	96.3	95.6	17.2	22.5	21.2	OL	OL	OL	17.2	23.9	21.1	OL	OL	OL	18.0	21.8	21.1	OL	OL	OL
08/09/2022	95.6	86.5	96.0	94.9	17.1	22.3	21.2	OL	OL	OL	17.2	22.2	21.1	OL	OL	OL	18.0	22.5	21.1	OL	OL	OL
09/09/2022	95.4	67.6	95.8	95.1	17.0	23.0	21.2	OL	OL	OL	17.3	22.3	21.1	OL	OL	OL	17.9	21.8	21.1	OL	OL	OL
10/09/2022	95.2	77.2	95.6	95.1	17.1	23.6	21.2	OL	OL	OL	17.2	23.3	21.1	OL	OL	OL	17.9	22.4	21.1	OL	OL	OL
11/09/2022	95.2	77.3	95.6	95.0	17.0	22.2	21.2	OL	OL	OL	17.2	22.2	21.1	OL	OL	OL	17.5	23.1	21.1	OL	OL	OL
12/09/2022	95.3	82.4	95.7	94.8	16.0	29.7	21.2	OL	OL	OL	17.2	22.1	21.1	OL	OL	OL	17.5	21.9	21.1	OL	OL	OL
13/09/2022	95.6	86.8	96.0	95.0	16.1	30.1	21.5	OL	OL	OL	17.2	22.3	21.1	OL	OL	OL	17.9	22.7	21.1	OL	OL	OL
14/09/2022	95.5	2.8	96.0	94.9	0.0	28.6	21.6	16.3	92.8	21.4	17.2	23.5	21.1	OL	OL	OL	0.0	36.3	21.1	16.7	84.6	21.9
15/09/2022	95.7	84.8	96.1	95.1	OL	OL	OL	0.0	43.4	21.4	17.3	37.5	21.3	18.4	61.1	21.7	18.1	95.7	22.0	0.0	40.1	21.3
16/09/2022	95.9	90.0	96.4	95.0	OL	OL	OL	15.8	94.8	21.1	17.0	34.0	21.4	0.0	31.5	21.7	17.9	24.7	21.8	OL	OL	OL
17/09/2022	96.0	85.6	96.6	96.0	OL	OL	OL	0.0	21.9	21.5	17.2	24.2	21.3	OL	OL	OL	19.0	34.0	26.3	16.3	84.5	21.2
18/09/2022	95.8	66.4	96.4	96.0	OL	OL	OL	OL	OL	OL	17.2	23.7	21.2	OL	OL	OL	19.7	31.5	24.9	16.1	22.1	21.1
19/09/2022	95.7	64.0	96.3	95.5	19.1	86.6	23.5	OL	OL	OL	0.0	26.7	21.2	OL	OL	OL	19.2	29.9	23.6	16.1	23.5	21.1
20/09/2022	95.6	3.2	96.3	95.5	19.6	43.7	21.5	OL	19.0	34.1	23.4	15.3	32.2	21.2								
21/09/2022	95.2	2.9	95.6	80.1	0.0	95.0	21.9	OL	0.0	65.8	21.7	0.0	82.6	21.4								
22/09/2022	95.6	2.8	96.2	95.1	20.9	29.5	21.2	OL	17.7	28.5	21.4	15.5	22.5	21.3								
23/09/2022	95.8	3.1	96.2	95.3	20.9	40.0	21.7	14.0	93.6	21.4	OL	OL	OL	OL	OL	OL	0.0	28.3	21.4	14.9	23.0	21.3
24/09/2022	95.7	90.4	96.2	95.7	18.9	34.1	21.3	0.0	21.9	21.5	OL	OL	OL	13.1	40.3	20.2	OL	OL	OL	15.9	24.1	21.2
25/09/2022	95.8	76.2	96.3	95.1	0.0	39.7	21.2	18.0	87.5	20.5	OL	OL	OL	0.0	65.0	19.9	15.9	57.3	21.4	15.7	30.3	21.2
26/09/2022	95.8	75.2	96.3	95.7	OL	OL	OL	15.0	29.5	20.6	OL	OL	OL	19.6	105.5	23.2	0.0	26.3	21.4	15.1	23.4	21.3
27/09/2022	95.8	83.9	96.3	95.2	OL	OL	OL	16.5	21.9	21.2	OL	OL	OL	18.8	23.0	21.6	OL	OL	OL	15.4	23.2	21.4
28/09/2022	95.8	75.5	96.3	95.3	OL	OL	OL	18.6	21.7	21.2	OL	OL	OL	18.7	21.7	21.2	OL	OL	OL	15.5	23.7	21.4
29/09/2022	95.8	89.0	96.4	95.5	OL	OL	OL	18.7	21.6	21.2	OL	OL	OL	18.7	21.7	21.2	OL	OL	OL	15.4	23.7	21.4
30/09/2022	95.9	86.9	96.4	94.4	OL	OL	OL	18.8	21.6	21.2	OL	OL	OL	18.7	21.8	21.2	OL	OL	OL	15.1	22.2	21.4

Notes: 1. UV Comparative Dose: 18.1 mJ/cm²

2. OL - Off Line

Submitted By (Print): D.Merredew

Signature: Original signed by D.Merredew

Page 2 of 2