



Water and Waste Eaux et déchets

Kale Black, Sr. Drinking Water Officer
Office of Drinking Water, Manitoba Conservation and Climate
309 – 25 Tupper Street North
Portage La Prairie, MB R1N 3K1

May 7, 2024

RE: APRIL 2024 WATER QUALITY COMPLIANCE SUBMISSION FOR THE CITY OF WINNIPEG WATER SUPPLY SYSTEM

Please find attached on-line and grab turbidity summary reports, on-line and grab chlorine summary reports and the UV summary report for the Water Treatment Plant for April 2024.

The on-line and grab sampling turbidity reports include results obtained for the Water Treatment Plant raw water and the eight filters. On April 16, the turbidity on Filter 3 exceeded 1.00 NTU; the elevated turbidity reading was caused by analyzer maintenance; additional information is provided in CAR-02-2024. The turbidity results for the filter effluent met the licence requirements.

The on-line and grab sampling chlorine reports include results obtained for the Deacon Booster Pumping Station at the Water Treatment Plant. The free chlorine results at the Water Treatment Plant met the licence requirements.

The UV summary reports include results obtained for the six UV reactors at the Water Treatment Plant. The UV disinfection results met the licence requirements.

Please let me know of any concerns or questions respecting this submission. I can be reached by telephone at 204-986-8359 or by e-mail at rgrosselle@winnipeg.ca.

Yours sincerely,

R. Grosselle
Manager of Environmental Standards

Enclosures

cc: Dr. L. Richards, Winnipeg Regional Health Authority (email)
Dr. H. Chang, Winnipeg Regional Health Authority (email)
Dr. T. Hilderman, Manitoba Health and Seniors Care (email)
T. Shanks, M. Eng., P. Eng. (email)
M. Szmon, P. Eng. (email)
H. Buhler, P. Eng. (email)
C. Wiebe, P. Eng. (email)
C. Diduck (email)



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
WATER SERVICES

Water System Code: 252.00
Licence Number: PWS-09-412-02-AA

WATER TREATMENT PLANT TURBIDITY ON-LINE MONITORING REPORT

April 2024 Turbidity (NTU)

Date	Raw		Filter #1		Filter #2		Filter #3		Filter #4		Filter #5		Filter #6		Filter #7		Filter #8	
	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max
1/04/2024	0.94	0.08	0.13	0.06	0.13	0.04	0.12	0.10	0.14	0.01	0.03	0.02	0.04	0.08	0.10	0.01	0.03	
2/04/2024	0.93	0.08	0.13	0.08	0.10	0.05	0.11	0.09	0.15	0.01	0.03	0.01	0.04	0.08	0.11	0.00	0.01	
3/04/2024	0.94	0.08	0.13	0.07	0.13	0.06	0.08	0.09	0.16	0.00	0.03	0.01	0.03	0.08	0.11	0.01	0.03	
4/04/2024	0.93	0.08	0.11	0.06	0.12	0.05	0.14	0.09	0.17	0.00	0.02	0.01	0.03	0.08	0.12	0.00	0.02	
5/04/2024	0.92	0.07	0.11	0.06	0.11	0.05	0.11	0.11	0.14	0.00	0.01	0.01	0.04	0.07	0.10	0.00	0.02	
6/04/2024	0.95	0.07	0.12	0.07	0.08	0.05	0.11	0.09	0.14	0.00	0.01	0.01	0.03	0.09	0.11	0.00	0.02	
7/04/2024	0.96	0.07	0.11	0.06	0.11	0.06	0.10	0.09	0.15	0.00	0.01	0.01	0.02	0.08	0.11	0.01	0.04	
8/04/2024	0.96	0.08	0.09	0.06	0.11	0.06	0.12	0.09	0.14	0.00	0.01	0.01	0.03	0.07	0.11	0.00	0.02	
9/04/2024	0.99	0.07	0.11	0.06	0.11	0.07	0.12	0.10	0.16	0.00	0.00	0.01	0.03	0.08	0.11	0.01	0.03	
10/04/2024	1.00	0.07	0.11	0.07	0.09	0.09	0.16	0.09	0.14	0.02	0.07	0.01	0.04	0.08	0.11	0.01	0.04	
11/04/2024	1.02	0.06	0.12	0.05	0.10	0.12	0.19	0.04	0.10	0.04	0.18	0.01	0.04	0.06	0.11	0.03	0.07	
12/04/2024	1.03	0.07	0.10	0.05	0.11	0.11	0.23	0.05	0.09	0.06	0.09	0.02	0.03	0.07	0.11	0.02	0.07	
13/04/2024	1.03	0.09	0.13	0.06	0.11	0.06	0.12	0.05	0.07	0.05	0.08	0.01	0.04	0.08	0.12	0.03	0.06	
14/04/2024	1.00	0.08	0.12	0.07	0.09	0.06	0.15	0.05	0.09	0.06	0.09	0.01	0.04	0.10	0.11	0.03	0.05	
15/04/2024	0.95	0.09	0.13	0.07	0.11	0.07	0.14	0.05	0.09	0.06	0.08	0.01	0.03	0.08	0.12	0.04	0.06	
16/04/2024	1.26	0.09	0.12	0.07	0.11	0.10	5.00	0.05	0.10	0.06	0.08	0.01	0.03	0.08	0.12	0.04	0.06	
17/04/2024	1.04	0.12	0.14	0.07	0.12	0.05	0.09	0.06	0.13	0.06	0.09	0.02	0.04	0.08	0.11	0.04	0.07	
18/04/2024	1.03	0.13	0.16	0.10	0.12	0.04	0.09	0.05	0.09	0.07	0.10	0.02	0.05	0.10	0.12	0.04	0.07	
19/04/2024	1.08	0.14	0.18	0.09	0.14	0.05	0.12	0.06	0.09	0.07	0.10	0.02	0.05	0.09	0.12	0.05	0.07	
20/04/2024	1.11	0.14	0.21	0.11	0.16	0.05	0.09	0.06	0.10	0.08	0.09	0.03	0.04	0.09	0.13	0.05	0.08	
21/04/2024	1.10	0.12	0.25	0.12	0.18	0.05	0.10	0.06	0.08	0.08	0.12	0.03	0.06	0.10	0.13	0.06	0.10	
22/04/2024	1.20	0.06	0.09	0.09	0.17	0.05	0.20	0.09	0.13	0.05	0.11	0.03	0.07	0.08	0.13	0.06	0.12	
23/04/2024	1.10	0.06	0.09	0.03	0.06	0.06	0.14	0.10	0.15	0.02	0.04	0.03	0.06	0.02	0.04	0.05	0.07	
24/04/2024	1.20	0.05	0.08	0.03	0.06	0.06	0.22	0.09	0.14	0.01	0.03	0.04	0.05	0.02	0.04	0.05	0.08	
25/04/2024	1.14	0.06	0.07	0.03	0.06	0.06	0.13	0.09	0.14	0.01	0.03	0.03	0.06	0.01	0.04	0.05	0.08	
26/04/2024	1.11	0.05	0.09	0.03	0.05	0.06	0.19	0.11	0.15	0.00	0.04	0.03	0.06	0.01	0.03	0.05	0.09	
27/04/2024	1.06	0.05	0.08	0.03	0.07	0.04	0.14	0.10	0.15	0.00	0.02	0.03	0.08	0.01	0.03	0.06	0.08	
28/04/2024	1.07	0.06	0.09	0.03	0.06	0.03	0.19	0.10	0.15	0.00	0.03	0.04	0.06	0.01	0.04	0.06	0.09	
29/04/2024	1.09	0.08	0.10	0.03	0.06	0.03	0.11	0.10	0.15	0.00	0.03	0.03	0.07	0.01	0.03	0.06	0.10	
30/04/2024	1.08	0.08	0.11	0.03	0.07	0.02	0.08	0.12	0.15	0.00	0.02	0.04	0.07	0.01	0.03	0.07	0.10	

Total Number of Measurements Taken, A: 13563 14716 16222 15578 11723 16128 14849 16316
Turbidity Standard for Monitoring Location (NTU): 0.3 0.3 0.3 0.3 0.3 0.3 0.3 0.3
Number of Measurements Meeting Standard, B: 13563 14716 16217 15578 11723 16128 14849 16316
Compliance with Turbidity Standard, C = B/A X 100%: 100.000% 100.000% 99.969% 100.000% 100.000% 100.000% 100.000% 100.000%

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Turbidity\2024\04-April

Submitted By (Print): D. Merredew

Signature: original signed by D. Merredew



Water and Waste
Eaux et déchets

CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENVIRONMENTAL STANDARDS DIVISION

WATER TREATMENT PLANT TURBIDITY GRAB MONITORING REPORT

Water System Code: 252.00 Licence No. PWS-09-412-02 AA	Turbidity (NTU)																	
	Raw Water		Filter 1		Filter 2		Filter 3		Filter 4		Filter 5		Filter 6		Filter 7		Filter 8	
Date	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser	Grab	Analyser
01-Apr-2024	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	
02-Apr-2024	0.56	0.92	0.10	0.09	0.11	0.08	0.12	0.06	0.12	0.12	0.11	0.02	0.07	0.02	0.08	0.08	0.08	
03-Apr-2024	0.70	0.91	0.10	0.09	0.11	0.09	0.13	0.06	0.09	0.09	0.13	0.03	0.07	0.02	0.10	0.10	0.08	
04-Apr-2024	0.67	0.90	0.10	0.08	0.10	0.07	0.14	0.08	0.09	0.10	0.10	<0.02	0.08	0.02	0.07	0.08	0.09	
05-Apr-2024	0.69	0.91	0.12	0.09	0.10	0.07	0.11	0.05	0.10	0.11	0.11	0.02	0.10	0.04	0.09	0.08	0.08	
06-Apr-2024	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	
07-Apr-2024	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	
08-Apr-2024	0.66	0.94	0.09	0.08	0.09	0.07	0.11	0.07	0.09	0.10	0.09	<0.02	0.08	0.02	0.08	0.07	0.09	
09-Apr-2024	0.64	0.96	0.12	0.08	0.10	0.06	0.11	0.08	0.10	0.10	0.15	<0.02	0.11	0.03	0.09	0.08	0.10	
10-Apr-2024	0.68	1.00	0.11	0.10	0.09	0.07	0.11	0.10	0.12	0.13	0.11	<0.02	0.07	0.02	0.08	0.08	<0.02	
11-Apr-2024	0.64	0.98	0.09	0.09	0.12	0.09	0.11	0.12	0.10	0.05	0.12	0.06	0.09	0.02	0.12	0.10	0.03	
12-Apr-2024	0.66	0.96	0.09	0.09	0.12	0.10	0.15	0.18	0.10	0.05	0.11	0.07	0.09	0.02	0.08	0.08	0.03	
13-Apr-2024	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	
14-Apr-2024	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	
15-Apr-2024	0.68	0.93	0.09	0.11	0.10	0.09	0.11	0.07	0.09	0.05	0.13	0.07	0.08	0.02	0.10	0.11	0.08	
16-Apr-2024	1.12	1.21	0.09	0.11	0.09	0.08	0.12	0.08	0.09	0.06	0.12	0.07	0.08	0.02	0.08	0.08	0.10	
17-Apr-2024	0.72	1.00	0.09	0.13	0.08	0.08	0.10	0.05	0.09	0.07	0.12	0.08	0.08	0.03	0.08	0.09	0.03	
18-Apr-2024	0.76	0.98	0.11	0.16	0.09	0.10	0.10	0.05	0.10	0.07	0.08	0.07	0.07	0.02	0.08	0.09	0.04	
19-Apr-2024	0.78	1.05	0.10	0.15	0.11	0.12	0.11	0.05	0.09	0.06	0.09	0.08	0.08	0.03	0.11	0.11	0.05	
20-Apr-2024	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	
21-Apr-2024	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	
22-Apr-2024	0.69	1.26	0.10	0.07	0.10	0.17	0.11	0.05	0.10	0.08	0.14	0.06	0.09	0.04	0.10	0.11	0.06	
23-Apr-2024	0.65	1.11	0.08	0.06	0.09	0.03	0.10	0.06	0.10	0.13	0.09	0.02	0.08	0.04	0.09	<0.02	0.10	
24-Apr-2024	0.71	1.22	0.09	0.07	0.11	0.06	0.11	0.07	0.09	0.10	0.08	0.03	0.09	0.04	0.08	<0.02	0.10	
25-Apr-2024	0.69	1.21	0.09	0.07	0.09	0.03	0.11	0.07	0.09	0.11	0.08	0.02	0.09	0.05	0.08	<0.02	0.08	
26-Apr-2024	0.69	1.06	0.10	0.08	0.09	0.04	0.10	0.06	0.11	0.12	0.11	0.03	0.08	0.05	0.10	<0.02	0.09	
27-Apr-2024	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	
28-Apr-2024	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	ns	
29-Apr-2024	0.68	1.06	0.09	0.08	0.08	0.05	0.12	0.08	0.09	0.12	0.08	<0.02	0.09	0.05	0.08	<0.02	0.10	
30-Apr-2024	0.67	1.09	0.10	0.10	0.09	0.04	0.09	0.02	0.09	0.11	0.09	0.02	0.08	0.04	0.08	<0.02	0.08	
Total number of measurements taken, A:	21		21		21		21		21		21		21		21	21	21	
Turbidity Standard for Monitoring Location (NTU):	0.30		0.30		0.30		0.30		0.30		0.30		0.30		0.30	0.30	0.30	
Number of measurements meeting standard, B:	21		21		21		21		21		21		21		21	21	21	
Compliance with Turbidity Standard, C= B/A X 100%:	100%		100%		100%		100%		100%		100%		100%		100%	100%	100%	

na: not analyzed nr: no result ns: no sample o/: offline im: instrument maintenance

Comments:

Report Date: May 7, 2024



City Of Winnipeg

Water and Waste Department

Water Services

WATER TREATMENT PLANT FREE CHLORINE ON-LINE MONITORING REPORT
Deacon Booster Pumping Station

Water System Code: **252.00**

Licence Number: **PWS-09-412-02-AA**

Report Created: **01 May 2024**

Report Period: April 2024

Date	BRANCH 1 [mg/L]		BRANCH 2 [mg/L]	
	Average	Minimum	Average	Minimum
01/04/2024	1.37	1.28	1.33	1.24
02/04/2024	1.21	1.08	1.21	1.15
03/04/2024	1.20	0.92	1.23	1.06
04/04/2024	1.24	1.17	1.30	1.22
05/04/2024	1.36	1.30	1.43	1.36
06/04/2024	1.31	1.19	1.36	1.21
07/04/2024	1.32	1.22	1.32	1.25
08/04/2024	1.34	1.28	1.31	1.25
09/04/2024	1.33	1.24	1.30	1.23
10/04/2024	1.30	1.25	1.29	1.23
11/04/2024	1.33	1.04	1.31	1.03
12/04/2024	1.43	1.39	1.40	1.35
13/04/2024	1.30	1.18	1.28	1.18
14/04/2024	1.27	1.20	1.27	1.21
15/04/2024	1.21	1.17	1.22	1.18
16/04/2024	1.31	1.23	1.31	1.20
17/04/2024	1.34	1.27	1.34	1.27
18/04/2024	1.31	1.24	1.30	1.23
19/04/2024	1.31	1.24	1.29	1.22
20/04/2024	1.31	1.26	1.30	1.26
21/04/2024	1.27	1.23	1.31	1.25
22/04/2024	1.28	1.23	1.30	1.20
23/04/2024	1.26	1.19	1.27	1.21
24/04/2024	1.24	1.20	1.26	1.22
25/04/2024	1.28	1.22	1.29	1.21
26/04/2024	1.26	1.20	1.27	1.23
27/04/2024	1.24	1.16	1.23	1.17
28/04/2024	1.25	1.19	1.26	1.19
29/04/2024	1.26	1.14	1.28	1.17
30/04/2024	1.27	1.22	1.24	1.17

Total Number of Measurements, A: **20881** 20881

Minimum Free Chlorine Standard: **0.5** 0.5

Number of Measurements Meeting Standard, B: **20881** 20881

COMPLIANCE, C = B/A X 100%: **100.00** 100.00

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Chlorine\2024\04-April

Submitted By (Print): D. Merredew

Signature: original signed by D. Merredew



WATER TREATMENT PLANT CHLORINE GRAB MONITORING REPORT

Water System Code: 252.00	Deacon Booster Pumping Station Branch 1			Deacon Booster Pumping Station Branch 2		
	Date	Free Chlorine (mg/L)	Total Chlorine (mg/L)	Free Chlorine (mg/L)	Total Chlorine (mg/L)	
	Analyser	Grab	Grab	Analyser	Grab	Grab
01-Apr-2024	ns	ns	ns	ns	ns	ns
02-Apr-2024	1.27	1.25	1.53	1.22	1.25	1.55
03-Apr-2024	1.25	1.22	1.55	1.21	1.24	1.54
04-Apr-2024	1.23	1.26	1.54	1.29	1.30	1.63
05-Apr-2024	1.32	1.31	1.57	1.39	1.36	1.64
06-Apr-2024	ns	ns	ns	ns	ns	ns
07-Apr-2024	ns	ns	ns	ns	ns	ns
08-Apr-2024	1.33	1.31	1.52	1.31	1.34	1.50
09-Apr-2024	1.27	1.23	1.43	1.24	1.28	1.46
10-Apr-2024	1.26	1.26	1.46	1.24	1.31	1.50
11-Apr-2024	1.31	1.27	1.45	1.31	1.33	1.46
12-Apr-2024	1.42	1.43	1.68	1.38	1.41	1.67
13-Apr-2024	ns	ns	ns	ns	ns	ns
14-Apr-2024	ns	ns	ns	ns	ns	ns
15-Apr-2024	1.20	1.19	1.42	1.20	1.18	1.42
16-Apr-2024	1.30	1.31	1.48	1.28	1.30	1.54
17-Apr-2024	1.40	1.34	1.54	1.38	1.38	1.57
18-Apr-2024	1.33	1.30	1.49	1.30	1.31	1.51
19-Apr-2024	1.29	1.28	1.49	1.24	1.31	1.51
20-Apr-2024	ns	ns	ns	ns	ns	ns
21-Apr-2024	ns	ns	ns	ns	ns	ns
22-Apr-2024	1.35	1.30	1.51	1.32	1.33	1.49
23-Apr-2024	1.26	1.31	1.48	1.24	1.30	1.49
24-Apr-2024	1.27	1.30	1.47	1.25	1.29	1.45
25-Apr-2024	1.33	1.32	1.50	1.33	1.32	1.49
26-Apr-2024	1.29	1.30	1.44	1.29	1.28	1.43
27-Apr-2024	ns	ns	ns	ns	ns	ns
28-Apr-2024	ns	ns	ns	ns	ns	ns
29-Apr-2024	1.25	1.27	1.47	1.29	1.27	1.47
30-Apr-2024	1.27	1.31	1.49	1.21	1.30	1.48
Total number of measurements taken, A:	21			21		
Chlorine Standard for Monitoring Location (mg/L):	0.50			0.50		
Number of measurements meeting standard, B:	21			21		
Compliance with Chlorine Standard, C= B/A X 100%:	100%			100%		

na: not analyzed nr: no result ns: no sample o/l: offline im: instrument maintenance

Comments:

Report Date: May 7, 2024



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
WATER SERVICES

Water System Code: 252.00
Licence Number: PWS-09-412-02-AA

WATER TREATMENT PLANT UV REPORT

Report Period: April 2024

Report Created: Wednesday, May 01, 2024

Date	UVR-D100A		UVR-D200A		UVR-D300A		UVR-D400A		UVR-D500A		UVR-D600A		Total		% Volume Treated To Dose
	To	Total	To	Total	To	Total	To	Total	To	Total	To	Total	To	Total	
01/04/2024	101.34	101.34	0.00	0.00	83.54	83.54	0.00	0.00	0.00	0.00	0.00	0.00	184.88	184.88	100.00
02/04/2024	103.82	103.82	0.00	0.00	85.82	85.82	0.00	0.00	0.00	0.00	0.00	0.00	189.64	189.64	100.00
03/04/2024	47.49	47.49	10.52	10.52	38.54	38.60	39.90	39.90	54.46	54.46	0.00	0.00	190.91	190.97	99.97
04/04/2024	0.00	0.00	0.00	0.00	0.00	0.00	92.20	92.20	99.59	99.59	0.00	0.00	191.79	191.79	100.00
05/04/2024	0.00	0.00	0.00	0.00	0.00	0.00	93.09	93.09	100.53	100.53	0.00	0.00	193.62	193.62	100.00
06/04/2024	0.00	0.00	0.00	0.00	0.00	0.00	89.50	89.50	96.94	96.94	0.00	0.00	186.44	186.44	100.00
07/04/2024	0.00	0.00	0.00	0.00	0.00	0.00	89.67	89.67	97.26	97.26	0.00	0.00	186.93	186.93	100.00
08/04/2024	0.00	0.00	0.00	0.00	0.00	0.00	91.97	91.97	99.76	99.76	0.00	0.00	191.72	191.73	100.00
09/04/2024	0.00	0.00	0.00	0.00	0.00	0.00	93.11	93.11	98.90	98.90	0.00	0.00	192.01	192.01	100.00
10/04/2024	0.00	0.00	0.00	0.00	0.00	0.00	92.33	92.33	96.94	96.94	0.00	0.00	189.26	189.27	100.00
11/04/2024	43.10	43.10	0.00	0.00	0.16	0.19	53.69	53.75	96.96	96.96	0.00	0.00	193.91	194.00	99.95
12/04/2024	97.05	97.05	0.00	0.00	0.00	0.00	0.00	0.00	95.35	95.35	0.00	0.00	192.40	192.40	100.00
13/04/2024	94.11	94.11	0.00	0.00	0.00	0.00	0.00	0.00	92.90	92.90	0.00	0.00	187.01	187.01	100.00
14/04/2024	94.06	94.06	0.00	0.00	0.00	0.00	0.00	0.00	92.98	92.98	0.00	0.00	187.04	187.04	100.00
15/04/2024	94.07	94.07	0.00	0.00	0.00	0.00	0.00	0.00	92.91	92.91	0.00	0.00	186.98	186.98	100.00
16/04/2024	93.94	93.94	0.00	0.00	0.00	0.00	0.24	0.27	92.68	92.68	0.09	0.12	186.95	187.01	99.97
17/04/2024	94.16	94.16	0.00	0.00	0.00	0.00	0.00	0.00	92.85	92.85	0.00	0.00	187.01	187.01	100.00
18/04/2024	94.13	94.13	0.00	0.00	0.00	0.00	0.00	0.00	92.87	92.87	0.00	0.00	187.00	187.00	100.00
19/04/2024	92.30	92.30	0.00	0.00	0.00	0.00	0.00	0.00	94.60	94.60	0.00	0.00	186.90	186.90	100.00
20/04/2024	90.31	90.31	0.00	0.00	0.00	0.00	0.00	0.00	96.04	96.04	0.00	0.00	186.35	186.35	100.00
21/04/2024	89.05	89.05	0.00	0.00	0.00	0.00	0.00	0.00	94.93	94.93	0.00	0.00	183.98	183.98	100.00
22/04/2024	89.10	89.10	0.00	0.00	0.00	0.00	0.00	0.00	94.90	94.90	0.00	0.00	184.00	184.00	100.00
23/04/2024	91.58	91.66	0.00	0.00	0.00	0.00	0.00	0.00	93.83	93.83	0.00	0.00	185.41	185.49	99.96
24/04/2024	90.15	90.15	0.00	0.00	0.00	0.00	0.00	0.00	95.85	95.85	0.00	0.00	186.00	186.00	100.00
25/04/2024	90.11	90.11	0.00	0.00	0.00	0.00	0.00	0.00	95.90	95.90	0.00	0.00	186.01	186.01	100.00
26/04/2024	89.86	89.86	0.00	0.00	0.00	0.00	0.00	0.00	95.76	95.76	0.00	0.00	185.62	185.62	100.00
27/04/2024	91.26	91.26	0.00	0.00	0.00	0.00	0.00	0.00	97.03	97.03	0.00	0.00	188.29	188.29	100.00
28/04/2024	93.13	93.13	0.00	0.00	0.00	0.00	0.00	0.00	98.69	98.69	0.00	0.00	191.82	191.82	100.00
29/04/2024	93.11	93.11	0.00	0.00	0.00	0.00	0.00	0.00	98.79	98.79	0.00	0.00	191.90	191.90	100.00
30/04/2024	93.19	93.19	0.00	0.00	0.00	0.00	0.00	0.00	98.69	98.69	0.00	0.00	191.88	191.88	100.00

Total [ML]: 2050.42 2050.50 10.52 10.52 208.07 208.15 735.70 735.79 2648.89 2648.89 0.09 0.12 5653.68 5653.98

Water Volume [%]:

To Dose per reactor	100.00 %	100.00 %	99.96 %	99.99 %	100.00 %	76.93 %
To Dose Total	99.99 %					

Notes:

1. Target Log value: 2.00

Submitted By (Print): D. Merredew

Signature: original signed by D. Merredew

Page 1 of 2



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
WATER SERVICES

Water System Code: 252.00
Licence Number: PWS-09-412-02-AA

WATER TREATMENT PLANT UV REPORT

Report Period: April 2024

Report Created: Wednesday, May 01, 2024

Date	Transmittance (%)				UVR_D100A		UVR_D200A		UVR_D300A		UVR_D400A		UVR_D500A		UVR_D600A	
	Branch 1		Branch 2		Avg.	Min.										
01/04/2024	92.5	91.7	93.1	92.8	2.3	1.9	OL	OL	2.3	2.1	OL	OL	OL	OL	OL	OL
02/04/2024	92.5	91.5	93.1	92.9	2.4	2.2	OL	OL	2.4	2.2	OL	OL	OL	OL	OL	OL
03/04/2024	92.5	91.6	93.1	92.7	2.5	0.0	3.9	0.0	2.5	0.0	2.6	2.3	2.5	2.2	OL	OL
04/04/2024	92.5	91.6	93.1	92.9	OL	OL	OL	OL	OL	OL	2.4	2.3	2.4	2.3	OL	OL
05/04/2024	92.5	91.7	93.1	92.8	OL	OL	OL	OL	OL	OL	2.4	2.3	2.4	2.3	OL	OL
06/04/2024	92.6	91.8	93.2	93.0	OL	OL	OL	OL	OL	OL	2.4	2.3	2.4	2.3	OL	OL
07/04/2024	92.7	92.0	93.3	92.2	OL	OL	OL	OL	OL	OL	2.4	2.3	2.4	2.3	OL	OL
08/04/2024	92.8	92.2	93.5	93.1	OL	OL	OL	OL	OL	OL	2.4	2.2	2.5	2.2	OL	OL
09/04/2024	92.9	91.9	93.5	92.7	OL	OL	OL	OL	OL	OL	2.5	2.2	2.5	2.2	OL	OL
10/04/2024	92.9	91.6	93.6	93.4	OL	OL	OL	OL	OL	OL	2.4	2.2	2.4	2.1	OL	OL
11/04/2024	92.8	92.1	93.5	93.3	2.5	0.0	OL	OL	2.2	0.0	2.5	0.0	2.5	2.2	OL	OL
12/04/2024	92.8	92.0	93.5	93.0	2.4	2.2	OL	OL	OL	OL	OL	OL	2.5	2.2	OL	OL
13/04/2024	92.9	92.1	93.7	93.4	2.4	2.2	OL	OL	OL	OL	OL	OL	2.4	2.3	OL	OL
14/04/2024	93.1	92.4	93.9	93.7	2.5	2.2	OL	OL	OL	OL	OL	OL	2.4	2.3	OL	OL
15/04/2024	93.3	92.6	94.1	93.8	2.4	2.2	OL	OL	OL	OL	OL	OL	2.4	2.3	OL	OL
16/04/2024	93.6	92.8	94.5	94.1	2.4	2.2	OL	OL	OL	OL	2.5	0.0	2.4	2.2	2.6	0.0
17/04/2024	93.9	93.1	94.9	94.4	2.4	2.2	OL	OL	OL	OL	OL	OL	2.4	2.3	OL	OL
18/04/2024	94.0	93.3	95.1	94.7	2.5	2.3	OL	OL	OL	OL	OL	OL	2.4	2.3	OL	OL
19/04/2024	94.0	93.1	94.9	94.4	2.5	2.0	OL	OL	OL	OL	OL	OL	2.4	2.3	OL	OL
20/04/2024	94.0	93.1	95.0	94.8	2.5	2.2	OL	OL	OL	OL	OL	OL	2.4	2.3	OL	OL
21/04/2024	94.0	93.2	95.1	94.8	2.5	2.2	OL	OL	OL	OL	OL	OL	2.4	2.3	OL	OL
22/04/2024	93.9	93.3	94.9	94.6	2.4	2.2	OL	OL	OL	OL	OL	OL	2.4	2.3	OL	OL
23/04/2024	93.8	93.2	94.7	94.1	2.4	1.8	OL	OL	OL	OL	OL	OL	2.4	2.1	OL	OL
24/04/2024	93.8	93.1	94.6	94.3	2.4	2.2	OL	OL	OL	OL	OL	OL	2.5	2.2	OL	OL
25/04/2024	93.8	93.2	94.6	94.2	2.4	2.2	OL	OL	OL	OL	OL	OL	2.5	2.2	OL	OL
26/04/2024	93.7	93.1	94.4	94.1	2.4	2.2	OL	OL	OL	OL	OL	OL	2.5	2.2	OL	OL
27/04/2024	93.7	93.1	94.4	94.1	2.4	2.2	OL	OL	OL	OL	OL	OL	2.5	2.3	OL	OL
28/04/2024	93.6	92.9	94.3	94.1	2.4	2.2	OL	OL	OL	OL	OL	OL	2.4	2.3	OL	OL
29/04/2024	93.6	93.0	94.3	94.0	2.4	2.2	OL	OL	OL	OL	OL	OL	2.4	2.3	OL	OL
30/04/2024	93.6	93.0	94.3	94.0	2.4	2.2	OL	OL	OL	OL	OL	OL	2.4	2.3	OL	OL

Notes: 1. UV target value is 2.00 [Log]
2. OL - Off Line

Submitted By (Print): D. Merredew

Signature: original signed by D. Merredew

Page 2 of 2