



Water and Waste Department • Service des eaux et des déchets

June 7, 2013

Our File: 040-18-18-55-00

Melanie Betsill
Office of Drinking Water
Manitoba Conservation and Water Stewardship
1007 Century Street
Winnipeg, Manitoba
R3H 0W4

Dear Ms. Betsill:

**RE: TOTAL TRIHALOMETHANE SUMMARY REPORT
FOR THE CITY OF WINNIPEG WATER SUPPLY SYSTEM FOR QUARTER 2 - 2013**

Please find attached the Total Trihalomethane Summary Report for the second quarter of 2013 for the Winnipeg water supply system for your review and records.

Please let me know of any concerns or questions respecting this submission. I may be reached at the below address, by telephone at 204-986-4807 or by e-mail at kkjartanson@winnipeg.ca.

Thanks for your ongoing cooperation and understanding in this matter.

Yours sincerely,

Original signed by:

K.J.T. Kjartanson, P.Eng.
Manager of Environmental Standards

KJTK/rg
Attachments

c: Dr. L. Richards, Winnipeg Regional Health Authority
Dr. S. Roberecki, Manitoba Health
D.P. Sacher, P.Eng.(e-mail)
G. Patton, P.Eng.
T. Josephson, P.Eng.(e-mail)
S. Fletcher (e-mail)

N:\Compliance Reporting\Submittal Letters\2013\THM\Quarter 2-2013 THM Submittal Letter.doc

Embrace the spirit • Vivez l'esprit

Environmental Standards Division • Division des normes environnementales
2230 Main Street • 2230, Rue Main • Winnipeg • Manitoba R2V 4T8
tel/tél. (204) 986-4684 • fax/télec. (204) 339-2147 • www.winnipeg.ca

**CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENVIRONMENTAL STANDARDS DIVISION**

Total Trihalomethane Summary Report

Reporting Period: Quarter 2 2013

SAMPLE DATE	DISTRIBUTION SYSTEM THM RESULTS (ug/L)					
	[REDACTED]					
Monday, August 13, 2012	42	46	49	50	50	48
Monday, November 05, 2012	19	20	20	22	22	19
Monday, February 11, 2013	24	27	25	26	27	25
Monday, May 06, 2013	21	22	21	24	24	22
RUNNING AVERAGE THM	27	29	29	31	31	29

COMMENTS:

NS - NO SAMPLE
NR - NO RESULT

Methodology

Trihalomethanes analyzed by GC-ECD, Standard Methods for the Examination of Water and Waste Water, 21st Edition, Method 6232

Report Compiled by: H.Demchenko

Approved in LIMS by: S.Fletcher

File: WQR4

Date Approved: May 15, 2013

N:\Environmental Standards\Analytical Services\WQ Data\Routine Water Quality\2013\Quarterly THM\[Quarterly THM 2013.xls]THM Q2