

ID	Equipment Tag	Description	Lamacoid	Shop Drawings	Specification Section	Drawing Number	Training Required
1	MCC-R740	Motor Control Centre 600V, 3Ø, 3W, 400A	Yes	Yes	26 24 19	1-0630R-E0001-001 1-0630R-E0004-001 to 1-0630R-E0006-001	Yes
2	PNL-R741	120/208V, 225A, 3 Ø, 4W, 42CCT	Yes	Yes	26 24 19	1-0630R-E0001-001 1-0630R-E0003-001	Yes
3	LCP-R800	Local Control Panel	Yes	Yes	29 10 01	1-0630P-A0082-001 to 1-0630P-A0087-001	Yes
4	LRV-1	Butterfly Valve Actuator	Yes	Yes	25 30 02	1-0630U-A0088-001	Yes
5	LRV-2	Butterfly Valve Actuator	Yes	Yes	25 30 02	1-0630U-A0089-001	Yes
6	LAV-1	Butterfly Valve Actuator	Yes	Yes	25 30 02	1-0630U-A0090-001	Yes
7	LAV-2	Butterfly Valve Actuator	Yes	Yes	25 30 02	1-0630U-A0091-001	Yes
8	LSV-1	Butterfly Valve Actuator	Yes	Yes	25 30 02	1-0630U-A0092-001	Yes
9	LSV-2	Butterfly Valve Actuator	Yes	Yes	25 30 02	1-0630U-A0093-001	Yes
10	LSV-3	Butterfly Valve Actuator	Yes	Yes	25 30 02	1-0630U-A0094-001	Yes
11	JBA-LRV1	Junction Box	Yes	Yes	26 05 31	1-0630U-A0088-001	No
12	JBA-LRV2	Junction Box	Yes	Yes	26 05 31	1-0630U-A0089-001	No
13	JBA-LAV1	Junction Box	Yes	Yes	26 05 31	1-0630U-A0090-001	No
14	JBA-LAV2	Junction Box	Yes	Yes	26 05 31	1-0630U-A0091-001	No
15	XFMR-R741	Transformer 600-208/120V, 30 kVA	Yes	Yes	26 12 17	1-0630R-E0001-001	No
16	DS-P010	Dewatering Pump P010 Disconnect Switch	Yes	Yes	26 28 23	1-0630R-E0001-001	No
17	DS-P020	Dewatering Pump P020 Disconnect Switch	Yes	Yes	26 28 23	1-0630R-E0001-001	No
18	DS-HE1	Heater HE1 Disconnect Switch	Yes	Yes	26 28 23	1-0630R-E0001-001	No
19	DS-HE3	Heater HE2 Disconnect Switch	Yes	Yes	26 28 23	1-0630R-E0001-001	No
20	Type 1 Lighting	Vapour Tight, Wet Location Listed, 5,115 Lumens, Qty: See Dwgs	No	Yes	26 50 00	1-0630R-E0003-001	No
21	Type 2 Lighting	Low Bay LED, Round, IP 65 Lens, 13,134 Lumens, Qty: See Dwgs	No	Yes	26 50 00	1-0630R-E0003-001	No
22	Type 3 Lighting	Emergency Light, Qty: See Dwgs	No	Yes	26 50 00	1-0630R-E0003-001	No
General Notes							
1. This Appendix A - Major Equipment List is intended to provide a summary of the major equipment noted throughout the Contract Documents. However, this Appendix A - Major Equipment List should not be considered an exhaustive list as only select major equipment has been identified. This Appendix A - Major Equipment List is for informational purposes only and the Contractor shall be responsible to conform to the requirements of the Contract Documents, including verification of equipment quantities. In the case of a discrepancy between this Appendix A - Major Equipment list and other Contract Documents, other Contract Documents shall govern.							