



A SPECIAL EVENTS PANEL 'OPC-P' LAYOUT
SCALE: NTS

BILL OF MATERIALS	
ITEM NO.	DESCRIPTION
1	ENCLOSURE, TYPE 3R, MINIMUM 1/4" THICK 304 STAINLESS STEEL FREE STANDING.
2	STAINLESS STEEL HEAVY DUTY RATED 3 POINT LATCH C/W PADLOCK RINGS
3	HINGED COVER RECEPTACLE BOX C/W 8x20A 5-20R, T-SLOT DUPLEX RECEPTACLES, 4x20A 120V RATED SWITCHES, 1x30A, 120V 5-30R RECEPTACLE, 1x30A, 120V RATED SWITCH, 1x50A, 240V 6-50R RECEPTACLE AND 1x50A, 240V RATED SWITCH. BOX CONSTRUCTION TO MATCH REMAINDER OF ENCLOSURE WITH 3 POINT LATCH C/W PAD LOCK RINGS.
4	DUAL NEMA 3R RATED, MINIMUM 1/4" THICK 304 STAINLESS STEEL DOORS C/W GASKETTING. DOOR TO INCLUDE FULL LENGTH CONCEALED PIANO HINGE. DOOR ON METERING TO INCLUDE VIEWING WINDOW TO METER.
5	200A NEMA 3R HEAVY DUTY SERVICE ENTRANCE RATED FUSIBLE DISCONNECT SWITCH C/W VIEWING WINDOW. FUSES TO BE 100KA RATED CURRENT LIMITING TYPE. MOUNTED WITHIN ENCLOSURE
6	200A RATED METER SOCKET WITHIN ENCLOSURE
7	LIFTING POINTS
8	SLOPED TOP
9	42 CIRCUIT, 200A, 120/208V/30/4W NEMA 3R PANEL BOARD SERIES RATED WITH MAIN FUSIBLE DISCONNECT SWITCH.
10	CONDENSATE STRIP HEATER
11	LIGHTING CONTROL EQUIPMENT. REFER TO LIGHTING CONTROL SCHEMATIC.
12	GROUND BAR
13	VOLTAGE BARRIER

NOTES:



REV	YY / MM / DD	DESCRIPTION	BY
0	24 / 02 / 09	ISSUED FOR TENDER	PL

A. SECTION LETTER OR DETAIL NUMBER.
B. DRAWING WHERE SECTION OR DETAIL IS DRAWN.
OR
DRAWING WHERE SECTION OR DETAIL IS INDICATED
--- SECTION OR DETAIL SHOWN ON SAME DRAWING.

PROFESSIONAL'S SEAL

SCATLIFF + MILLER + MURRAY
visionary urban design + landscapes

CONSULTANT FILE NAME AIR CANADA PARK REDEVELOPMENT

CLIENT
CITY OF WINNIPEG
PLANNING, PROPERTY & DEVELOPMENT



AIR CANADA WINDOW PARK REDEVELOPMENT

CITY DRAWING NUMBER	SHEET	OF
	24	28

ELECTRICAL
PANEL ELEVATION DETAILS

DESIGN	DRAWN	DATE - Y / M / D	SCALE
PL	RD	24/02/09	NTS
CHECKED	APPROVED	PROJECT No.	DRAWING No.
DAL	PL	23-0109-004	E5.0



BID OPPORTUNITY No. 78-2024