


SECOND FLOOR PLAN - SPRINKLER SYSTEM
SCALE: 1/8"=1'-0"

NEW SPRINKLER
HEAD LOCATION

1

2

EXISTING SPRINKLERS HEADS TO REMAIN IN HATCHED AREA



SPRINKLER SYSTEM NOTE:

1 REMOVE UPRIGHT SPRINKLER HEADS AND RECONFIGURE & SUPPLY WITH QUICK RESPONSE HEADS AS PER LAYOUT SHOWN.

2 SPRINKLER WORK NOT INCLUDED IN HATCHED AREA.

PROVIDE FIRE PROTECTION VERIFICATION CERTIFICATE AFTER SYSTEM IS COMPLETED & TESTED.

FOR REFERENCE ONLY
NOT TO BE USED FOR CONSTRUCTION.
SEE RJ BARTLETT ENGINEERING LTD. DRAWING FP1-2

1 ADD SPRINKLER VERIFICATION CERTIFICATE NOTE. SEE MECHANICAL NOTE 1 FOR REVISION. RCP 2005 1130

NO.	REVISION/DESCRIPTION	BY	DATE
SEALS			

DRAWN BY	RCP	CHECKED BY	APPROVED
DATE	2005.11.16	USER APPROVAL	

CITY OF WINNIPEG
PLANNING, PROPERTY &
DEVELOPMENT DEPARTMENT
CIVIC ACCOMMODATIONS DIVISION
300 - 65 GARRY ST. R3C 4K4

PROJECT
ADMINISTRATION BUILDING
2ND FLOOR RENOVATIONS
CONVERSION TO OFFICE AREA
510 MAIN STREET

SHEET TITLE
SECOND FLOOR PLAN
SPRINKLER SYSTEM

SCALE	PROJECT NO.	SHEET NO.
AS SHOWN	2004-180-6	M3R1