



## 602-2006 ADDENDUM No. 4

### NATURAL GAS ENGINE UPGRADES TO MACLEAN AND MCPHILLIPS PUMPING STATIONS

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY**

ISSUED: September 18, 2007  
BY: Claude Courchaine, P. Eng.  
TELEPHONE NO. (204) 284-0580

**THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS**

Template Version: A20070419

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.**

---

#### **PART E – SPECIFICATIONS**

- Revise: E7.6.3 to read: Heaters are to be CSA approved, 120VAC single phase. Connect via a new Junction Box to existing wiring from existing lighting panel A, circuits 30 and 38.
- Revise: E7.9.2 to read: The pump is to be 120VAC, single phase. Connect via a new Junction Box to existing wiring from existing lighting panel B, circuits 10 and 14.

#### **NMS SPECIFICATIONS**

- Revise NMS Specification Section 260534 – Conduits, Conduit Fastenings and Conduit Fittings:
- Clause 2.2.1 to read: Rigid aluminum conduit: to CSA C22.2, threaded.
- Clause 3.2.4 to read: Use rigid aluminum threaded conduit except where specified otherwise.