




REV.	CABLE TAG	CABLE SPECIFICATIONS	LENGTH (m)	FROM	TO	DESCRIPTION	REMARKS
9	C-LCP-L11A-C01	24-Strand 50/125/250 um Multi-mode		CP-D21A	LCP-L11A Dewatering Pump Station Control Panel	Plant Communication	In Contract 34-2006.
9	C-LCP-L11A-C02	24-Strand 50/125/250 um Multi-mode		CP-D21A	LCP-L11A Dewatering Pump Station Control Panel	Plant Communication	In Contract 34-2006.
9	C-WTPWSD21 01-C01	4-Pair #24 AWG - Cat 5E		CP-D21A	WTPWSD21 01	Interface to DBPS PLC's	In Contract 37-2006.
9	P-CP-D21A	4-C #14 AWG		CP-D21	CP-D21A	UPS & non-UPS Panel Power	In Contract 35-2006.
10	C-CP-CF01A-C01	24-Strand 50/125/250 um Multi-mode		CP-D21A	CP-CF01A Chemical Feed Building Communication Panel	Plant Communication	In Contract 37-2006.
10	C-CP-CF01A-C02	24-Strand 50/125/250 um Multi-mode		CP-H11A Generator Communication Panel	CP-CF01A Chemical Feed Building Communication Panel	Plant Communication	In Contract 742-2005. DELETED - redundant.

NOTES:  <p>Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2006.</p>	B.M. ELEV.			 		ENGINEER'S SEAL		THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION				
	7	FOR CONSTRUCTION	06/12/01	BT	DESIGNED BY SWT	CHECKED BY SWT	ORIGINAL SIGNED BY S.W. TORMEY 2006/03/29			WATER TREATMENT PLANT		CITY FILE NUMBER
	6	498-2006 ADDENDUM 6	06/10/13	BT						PLANT UTILITIES		SHEET 11 OF 11
	5	498-2006 ADDENDUM 2	06/09/22	BT	DRAWN BY SWT	APPROVED BY AHL	CONSULTANT DRAWING NO. WH-A0711	MECHANICAL AND ELECTRICAL				
	4	FOR CONSTRUCTION	06/07/28	BT				AUTOMATION / I AND C		CITY DRAWING NUMBER		
	3	GENERAL REVISIONS	06/07/13	BT	SCALE: NTS	RELEASED FOR CONSTRUCTION BY: R. SOROKOWSKI		PLANT COMMUNICATION CABLES				
	10	792-2006 ADDENDUM 5	06/04/11	BT				CABLE LIST		1-0601H-K-A0711-001-10B		
	9	FOR TENDER (35-2006)	07/03/19	BT								
	8	ISSUED FOR TENDER	07/01/22	BT								
	NO.	REVISIONS	DATE	BY	DATE	2006/03/29	DATE	2006/03/29				

Wednesday, April 11, 2007