



NO

- ALLOW FOR 16 HOURS OF SITE INVESTIGATION TO DETERMINE IF CONTROL PANEL CP-400 AND DOWNSTREAM LOADS CAN BE DEMOLISHED (REFER TO SINGLE LINE CDP-300). ADVISE CONTRACT ADMINISTRATOR OF RESULTS OF INVESTIGATION. CP-400 FEEDS FAN #322.
- 2. REMOVE THE CONTROL PANELS FOR AH2 AND AH3 IN SOUTH MECHANICAL ROOM AS SHOWN IN DETAIL 1. ANY CONTROL DEVICES FOR THESE UNITS ARE TO BE RELOCATED IN EASILY ACCESSIBLE LOCATION, KEPT OPERATIONAL, AND LABELLED TO INDICATED WHICH EQUIPMENT THEY ARE CONTROLLING. PROVIDE NEW SIDE PANEL FOR CONTROL PANEL AH4. BE AWARE THAT INTERIOR BARRIERS IN THIS CONTROL PANELS CONTAIN ASBESTOS AND MUST BE REMOVED AND DISCARDED IN A MANNER COMPLIANT WITH ALL REGULATIONS AND REQUIREMENTS.
- 3. THE LOADS IN MCC-200 AND MCC-300 WILL BE TRANSFERRED TO NEW MCC-200N AND MCC-300N RESPECTIVELY. MCC-200N AND MCC-300N SHALL INCLUDE MOTOR STARTERS/CIRCUIT BREAKERS TO RE-FED THESE EXISTING LOADS.

2

