



## 844-2007 ADDENDUM 1

### CITY OF WINNIPEG FORT ROUGE TRANSIT GARAGE WELDING EXHAUST UPGRADE

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: December 12, 2007  
BY: Peter Gryc, M.Sc., P.Eng.  
TELEPHONE NO. (204) 789-2346

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20070419

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.**

---

#### **PART E – SPECIFICATIONS**

Delete: Section 15900, 1.2, .5:

Division 15900 shall provide an individual Johnson Metasys DDC unit controller for new fan unit.

Revise: Section 15900, 1.2, .6:

This building has an existing Johnson Metasys B.M.S. (Building Management System). Division 15900 shall provide new control wiring for new equipment and run back to existing DDC panel as required. The existing DDC panel has spare points and shall be used to monitor and control the new exhaust fan system. DDC programming shall be performed by the City.

#### **DRAWINGS**

Replace: 844-2007\_Drawing\_ME-1-R3 with 844-2007\_Addendum\_1-Drawing\_ME-1-R4