



548-2008 ADDENDUM 3

Supply and Installation of Underground Fuel Storage Tanks and All
Associated Equipment at 735 Assiniboine Park Drive

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: 2008-08-15
BY: Ben Vipond
TELEPHONE NO. (204) 986-8370

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph B5.3 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, August 20, 2008

PART E – BIDDING PROCEDURES

Revise: E2.6 (g) vii to read: Electrical service to the site is to be single phase with an independent meter to the kiosk. Bidders are requested to provide an estimate of the cost for the independent electrical meter in a covering letter to the Contract Administrator, however the cost estimate shall not be included in the Total Bid Price (i.e. do not include the estimate on the Bid Submission Form B Prices). The electrical service may or may not be exercised as part of the work to be completed for this bid opportunity.

Revise: E2.1 (g) to read Each tank compartment shall be wired for a ¾ hp submersible turbine type pump. Wiring is to be capped for potential future use.

DRAWINGS

Replace: 548-2008_Drawing_207-001-S1-R0.pdf with 548-2008_Addendum_3-Drawing_207-001-S1-R2.pdf