



## 548-2008 ADDENDUM 4

Supply and Installation of Underground Fuel Storage Tanks and All  
Associated Equipment at 735 Assiniboine Park Drive

### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: 2008-08-18  
BY: Ben Vipond  
TELEPHONE NO. (204) 986-8370

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20070419

---

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph B5.3 of Form A: Bid may render your Bid non-responsive.

---

### **PART B – BIDDING PROCEDURES**

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, August 21, 2008

### **PART E – SPECIFICATIONS**

Revise: E2.1 (e) to read: The fuel tanks shall be capable of burial to a depth of 2.13 meters below grade, but are to be buried 1 meter below grade.