

GENERAL NOTES: (APPLIES TO ALL DRAWINGS)

- DO NOT SCALE OFF DRAWINGS. CONTRACTOR SHALL VERIFY ALL DIMENSIONS PRIOR TO INSTALLATION AND REPORT ANY DISCREPANCY TO THE CONTRACT ADMINISTRATOR.
- THE DRAWING ONLY SHOWS A GENERAL SCHEMATIC OF NEW SYSTEMS. ROUTING OF CONDUIT OR CABLES AND LOCATIONS SHALL SUIT SITE CONDITIONS AND MAY HAVE TO BE CHANGED TO AVOID CONFLICTS WITH EXISTING STRUCTURE AND SERVICES. WHEN A CONFLICT CANNOT BE AVOIDED, THE EXISTING SERVICES SHALL BE MODIFIED AS REQUIRED.
- DIVISION 16 SHALL INCLUDE FOR AND PROVIDE ALL COORDINATION WITH CONTRACTOR, DIVISION 15, MANITOBA HYDRO AND THE CONTRACT ADMINISTRATOR ON AND OFF SITE AS REQUIRED FOR INSTALLATION OF ELECTRICAL SYSTEMS. WHERE REROUTING OF ELECTRICAL SERVICES OR ADDITIONAL WORK REASONABLY INCIDENTAL TO ORIGINAL DESIGN INTENT IS REQUIRED DUE TO COORDINATION, IT SHALL BE PERFORMED AT NO ADDITIONAL COST TO THE CITY.
- DIVISION 16 TO BE RESPONSIBLE FOR ALL CORE DRILLING/CUTTING AND PATCHING FOR DIVISION 16 WORKS. SCAN BEFORE PENETRATIONS ARE MADE. DO NOT CUT REINFORCING STEEL. FOLLOW SPECIFIC CITY'S RULES ON CUTTING, CORING AND PATCHING.
- ENSURE ALL CONDUIT/CABLE PENETRATIONS THROUGH FLOOR AND EXTERNAL WALLS ARE WATERTIGHT.
- EXISTING EQUIPMENT THAT IS BEING REMOVED AND ABANDONED SHALL REMAIN PROPERTY OF THE CITY AND BE TURNED OVER TO THE CITY. LEGALLY DISPOSE OF ANY EQUIPMENT THE OWNER DOES NOT WANT.
- REFILL AND RETURN ANY DISTURBED EXTERIOR TO A LEVEL STATE, LESS SODDING.
- THOROUGHLY EXAMINE EXISTING ELECTRICAL EQUIPMENT AND WIRING. INFORM THE CONTRACT ADMINISTRATOR WHERE EXISTING EQUIPMENT, WIRING, RACEWAYS, FITTINGS OR TERMINATIONS SHOWN TO BE RE-USED ARE UNSUITABLE FOR ONE OR MORE OF THE FOLLOWING REASONS :
 - ITEM NOT SUITABLE FOR INSTALLATION IN CLASS 1, ZONE 1 ENVIRONMENT.
 - ITEM NOT SUITABLE FOR USE IN WET/IMMERSED/CORROSIVE LOCATION IN ACCORDANCE WITH SECTION 22 OF C.E.C.
 - ITEM IS DAMAGED.
 - ITEM HAS REACHED OR IS ABOUT TO REACH THE END OF ITS SERVICE LIFE.

THE CONTRACT ADMINISTRATOR WILL PROVIDE DIRECTION TO THE CONTRACTOR.

SYMBOL LEGEND	
	JUNCTION BOX
	SWITCH
	2 GANG SWITCH
	TELEPHONE OUTLET
	WALL MOUNTED LIGHT FIXTURE
	CEILING MOUNTED LIGHT FIXTURE
	FLUORESCENT FIXTURE
	MOTOR
	DISCONNECT
	TRANSFORMER
	UTILITY METERING
	DUPLEX RECEPTACLE
	SINGLE RECEPTACLE 30A/208V, 2W PLUS GROUND, NON LOCKING
	SURFACE MOUNTED PANEL
	EXISTING TO BE RELOCATED
	MANUAL STARTER
	GROUNDING ELECTRODE

**** NOTE ****

- ELECTRICAL SHOWN DASHED IS EXISTING TO BE DISCONNECTED AND DELETED UNLESS OTHERWISE NOTED.
- ELECTRICAL SHOWN FADED BACK IS EXISTING TO REMAIN OR BE RELOCATED UNLESS OTHERWISE NOTED.



G.B.M. ELEV.	 SMS Engineering Ltd. Consulting Engineers 770 Brandon Street Winnipeg MB Canada R2H 0K3 Telephone: 204.773.0291 Fax: 204.772.2153 sme@smseng.com				ENGINEER'S SEAL 	THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT Winnipeg	CONSULTANT ACAD DWG. No.:
							E0.1
	DESIGNED BY SB	CHECKED BY SB	SHEET				
	DRAWN BY IN	APPROVED BY BDL	6 OF 14				
4 HYDRO CHARGES DELETED 15.04.09 BDL	HOR. SCALE AS NOTED	RELEASED FOR CONSTRUCTION	CITY DWG. NO.				
3 ISSUED FOR BID OPPORTUNITY (REV.) 31.03.09 SB	VERT. SCALE AS NOTED	SIGNED BY: K.ZUREK		8751			
2 ISSUED FOR BID OPPORTUNITY 27.03.09 SB							
1 ISSUED FOR 99% OWNER REVIEW 24.02.09 SB							
No. REVISIONS	DATE BY	DATE MARCH 2009	DATE MARCH 27, 2009	BID OPPORTUNITY # : 901-2008 PLOT DATE : MARCH 27, 2009			