



107-2009 ADDENDUM 1

SUPPLY AND INSTALLATION OF A NEW IRRIGATION SYSTEM, AT THE JOHN BLUMBERG RECREATION COMPLEX

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: February 23, 2009
BY: Ken Rech
TELEPHONE NO. (204) 489-6616

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, March 5, 2009

PART E – SPECIFICATIONS

Revise: E11.2 to read: Sprinkler heads shall be one of the following makes and models:

- a. Hunter I-35 , rubber cover, stainless steel riser with No: 15 Nozzle
- b. Toro S2001, 25 mm full circle c/w rubber cover and stainless steel riser (54 l/min @3.4 bar).

Revise:: E11.4 to read: Swing joints riser assemblies shall be one of the following makes and models:

- a. Spears model #5807-01008, 25 mm pre-fabricated (mipt x mipt).
- b. Lasco G132-208, both 25 mm mipt inlet and outlet by 200 mm lay length.
- c. Provide positive drainage back into the HDPE lateral lines.