



921-2009 ADDENDUM No. 1

2009 MAGER COMBINED SEWER DISTRICT SEWER SEPARATION CONTRACT NO. 1

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: February 12, 2010
BY: Hartley Katz, C.E.T., P. Eng.
TELEPHONE NO. (204) 489-5900

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

3-2009-02-12-09-01-001

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Bid may render your Bid non-responsive.

PART A – BID SUBMISSION

Replace: 921-2009 Bid Submission with 921-2009 Addendum No. 1- Bid Submission. The following is a summary of changes incorporated in the replacement Bid Submission:

- Form B(R1): Revise Item C. 2 b) i) to read 1200 diameter base
- Add Items No. H. 18 to H. 20 inclusive.

PART E – SPECIFICATIONS

- Add: **E8. BUILDING SERVICE CONNECTIONS**
- E8.1 The Contractor shall expose the sewer and water building service connections to confirm the elevations of the sewer service and water service pipes, at locations as agreed to by the Contractor and the Contract Administrator, prior to the installation of the land drainage sewer. The land drainage sewer installation excavations should be located such that they will coincide with the exposure of the service pipes.
- E8.2 There will be no measurement or separate payment for exposing the sewer and water building service connections. Cost of exposing the sewer and water building service connections shall be included in the unit price bid for the installation of the land drainage sewer.