


**NOTES:**

1. WIRE AND CONNECT HOOD SUPPRESSION SYSTEM AS SUPPLIED BY MECHANICAL. COORDINATE REQUIREMENTS WITH EQUIPMENT SHOP DRAWINGS.
2. INTERCONNECT HOOD SUPPRESSION SYSTEM TO SEPARATE ZONE IN FIRE ALARM SYSTEM. PROVIDE ISOLATION MODULES AS REQUIRED. COORDINATE REQUIREMENTS WITH EQUIPMENT SHOP DRAWINGS.
3. PROVIDE RELAY/CONTACTOR CONTROL FOR ELECTRICAL DEVICES LOCATED BELOW AND WITHIN 1500mm OF HOOD SUCH THAT ALL SHUT DOWN UPON INITIATION OF FIRE SUPPRESSION SYSTEM. COORDINATE REQUIREMENTS WITH EQUIPMENT SHOP DRAWINGS.
4. WIRE AND CONNECT EXISTING DEEP FRYER AS SUPPLIED BY OWNER C/W 100A FUSIBLE DISCONNECT C/W 100A FUSES. CONFIRM BREAKER AND FUSE SIZES WITH EQUIPMENT NAMEPLATE RATINGS.
5. PROVIDE ONE(1) 14-50R RECEPTACLE FOR EXISTING COOKTOP. CONFIRM REQUIREMENTS WITH EQUIPMENT NAMEPLATE RATINGS.
6. ITEMS IDENTIFIED IN NOTES 1,2, AND 3 SHALL BE INCLUDED IN SEPARATE PRICE #10.

<p>5878</p>  <p><b>MCW / AGE</b> Consulting Professional Engineers 210-1821 Wellington Avenue Winnipeg, Manitoba, R3H 0G4 Phone - (204) 779-7900 Fax - (204) 779-1119 E-Mail: mcw_wpg@mcw.com</p>	PROJECT:		SINCLAIR COMMUNITY CENTRE ADDITION & RENOVATIONS		REF. DWG. NO.	E3.1		
	DESCRIPTION:		KITCHEN LAYOUT		DWG. NO.	RE-5		
	DATE:	2010-03-31	DRAWN BY:	PCS	SCALE:	1:100	ISSUED WITH:	ADD#01E