



NOTES:

10. PROVIDE EMPTY OUTLET BOX C/W ONE(1) 41mm CONDUIT TO MAIN MTS DEMARCATION POINT C/W PULLWIRE AND PLASTIC BUSHINGS FOR FUTURE INTERCOM SYSTEM.

11. PROVIDE 208V/1Ø,1500W EXCEL DRYER XLERATOR SERIES XL-M HAND DRYER.

PLOTTED ON 2010-03-31 BY RUFINO SANTOS
 DOCUMENT SAVED IN H:\5800\5878\ELEC\RE-6_5878-EP2.0_B_R1.DWG

5878



MCW / AGE
 Consulting Professional Engineers
 210-1821 Wellington Avenue
 Winnipeg, Manitoba, R3H 0G4
 Phone - (204) 779-7900 Fax - (204) 779-1119
 E-Mail: mcw_wpg@mcw.com

PROJECT:
**SINCLAIR COMMUNITY CENTRE ADDITION
 AND RENOVATIONS**

DESCRIPTION:
HAND DRYER SPECS

DATE:
2010-03-31

DRAWN BY:
PCS

SCALE:
1:100

REF. DWG. NO.
EP2.0

DWG. NO.
RE-6

ISSUED WITH:
ADD#01E