

GENERAL NOTES:

1. THIS DRAWING IS DIAGRAMMATIC ONLY. DO NOT SCALE.
2. CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING EXACT LAYOUTS, ROUTING, ETC.
3. HUMIDIFIER SHALL BE INCLUDES SEPARATE PRICE # 11.

DRAWING NOTES:

- ① 300X200 EXHAUST AIR DUCT RISER UP.
- ② 350X300 EXHAUST AIR DUCT RISER UP.
- ③ 300X200 COMBUSTION AIR DUCT.
- ④ DHWT VENT, DUCT SIZED BY DHWT SUPPLIER.
- ⑤ BOILER VENT, DUCT SIZED BY BOILER SUPPLIER
- ⑥ 1000X750 RETURN AIR DUCT FROM ABOVE.
- ⑦ 1000X750 OUTDOOR AIR DUCT FROM ABOVE.
- ⑧ 1100X710 SUPPLY AIR DUCT RISER UP.
- ⑨ 400X150 TRANSFER DOOR GRILLE. PRICE STG-1 SERIES.
- ⑩ MOTORIZED DAMPERS ON AIR HANDLING UNIT (AHU-2) TO BE INTERLOCKED WITH EF-2.
- ⑪ 550X450 TRANSFER DOOR GRILLE. PRICE STG-1 SERIES.
- ⑫ 12Ø COLD WATER SUPPLY. REFER TO PLUMBING DRAWING M3.1 FOR CONTINUATION OF PIPING.
- ⑬ 50Ø CONDENSATE PIPE TO NEAREST FLOOR DRAIN. REFER TO PLUMBING DRAWING M1.1 FOR LOCATION.
- ⑭ 400X250 RATED TRANSFER DOOR GRILLE. PRICE STG-1 SERIES.
- ⑮ 32Ø SNOW MELT DRAIN TO NEAREST FD-2

PLOTTED ON 2010-4-5 BY MARIO GICANA
 DOCUMENT SAVED IN H: \5800\5878\MILESTONE\2010-03-31_ISSUED FOR ADD 02
 H:\5800\5878\BASEMENT VENTILATION.DWG

5878



MCW / AGE

Consulting Professional Engineers

210-1821 Wellington Avenue

Winnipeg, Manitoba, R3H 0G4

Phone - (204) 779-7900 Fax - (204) 779-1119

E-Mail: mcw_wpg@mcw.com

PROJECT:

SINCLAIR PARK COMMUNITY CENTER

REF. DWG. NO.

M5.1

DESCRIPTION:

BASEMENT-VENTILATION LAYOUT

DWG. NO.

RM-07

DATE:

2010-31-03

DRAWN BY:

MG

SCALE:

1:100

ISSUED WITH:

02-ME