



760-2010 ADDENDUM 3

MARION WASTEWATER PUMPING STATION - INSTALLATION OF PUMPING UNITS AND BUILDING UPGRADES, CONTRACT NO. 23

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: October 19, 2010
BY: Curtis Reimer
TELEPHONE NO. (204) 786-8080

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Add: 05 50 00 Clause 2.11.7

Provide jib crane stops to prevent the crane from hitting nearby obstructions including walls.

Add: 26 05 34 Clause 2.4

Conduit Spacers

.1 PVC coated malleable iron spacers, CSA approved for the purpose.

Add: 26 05 34 Clause 3.2.6

Install spacers as required to provide a space between the conduits and the supporting surface, with a minimum space as follows:

.1 Above grade spaces not classified as CEC Category 1 or 2:

- .1 Drywall / Wood surfaces: no space required
- .2 Masonry / concrete surfaces: 6 mm

.2 Below grade spaces: 12 mm

Revise: 26 29 23 Clause 2.1.4 to read:

VFDs to be a six-pulse or better design.

Revise: 26 29 23 Clause 2.1.14 to read:

Input frequency setting signal will be 0-10 VDC and 4-20 mA. Output speed and current monitoring signals will be 4-20 mA.

Revise: 26 29 23 Clause 2.1.16.3.1 to read:

Manual/Off/Auto three position maintained selector switch

Revise: 27 30 00 Clause 3.1.1 to read:

Demolish the existing telephone installation in the wastewater pumping station, ensuring continued operation of the telephone service to both the wastewater and the flood pumping stations. Coordinate with the Contract Administrator to ensure operation of the system.

Add: 27 30 00 Clause 3.1.1.1:

The telephone service for Marion Flood Pumping Station is provided from the Marion Wastewater Pumping Station.

Revise: 27 30 00 Clause 3.2.7.1 to read:

Service to be a dual analog telephone line. One line will be for for the wastewater pumping station and the other for the flood pumping station.

Add: 40 94 43 Clause 3.3

3.3 PLC Commissioning Services

- .1 Provide all required PLC commissioning services as per section 40 80 11.
- .2 Upon completion of commissioning, load latest software onto spare card in spare processor. Test spare prior to turning over to City.

Add: E.4.8 (b) (viii)

Demolish the existing telephone wire including underground connection to the Marion Flood Pumping Station. Provide a new dual line telephone service, with one line for the Marion Wastewater Pumping Station and the second line for the Marion Flood Pumping Station. Install communications cables between the wastewater and flood pumping stations.

DRAWINGS

Replace: 760-2010_Drawing_1-0159L-E0015-001-00 with 760-2010_Addendum_3_Drawing_1-0159L-E0015-001-01

Replace: 760-2010_Drawing_1-0159L-E0017-001-00 with 760-2010_Addendum_3_Drawing_1-0159L-E0017-001-01