



760-2010 ADDENDUM 5

MARION WASTEWATER PUMPING STATION - INSTALLATION OF PUMPING UNITS AND BUILDING UPGRADES, CONTRACT NO. 23

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: October 21, 2010
BY: Curtis Reimer
TELEPHONE NO. (204) 786-8080

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Clarification of E4.6(a)(i): All rectangular ductwork to be metallic as per the Specifications. All round ductwork to be PVC as per the Specifications. Transitions from rectangular to round ductwork may be metallic.

Revise: 23 38 18 Clause 2.1.9.1 to read:

.1 Round elbows: centreline radius at least 2 x diameter.

OTHER DOCUMENTS

The following document is intended as a clarification of the scope of required instrument supply.

Add: 760-2010_Addendum_5_Instrument_List.pdf