



LIGHTING & SYSTEMS PLAN
SCALE: 1:25

DRAWING NOTES

- ① COORDINATE LUMINAIRE CONNECTIONS WITH MECHANICAL PIPING AND DUCTWORK. WHERE REQUIRED SUSPEND LUMINAIRES BELOW SUCH EQUIPMENT.
- ② CONNECT NEW EMERGENCY LIGHTS TO EXISTING EMERGENCY LIGHTING CIRCUIT SEAA-4 AT EXISTING LUMINAIRE IN CORRIDOR AS SHOWN ON DRAWING.

GENERAL NOTES

- 1. COORDINATE WITH OTHER TRADES TO PREVENT CONFLICTS.
- 2. USE PVC JACKETED HITECK CABLE FOR ALL POWER WIRING.
- 3. WIRING FOR LIGHTING, RECEPTACLES AND COMMUNICATIONS TO IN RGID ALUMINUM CONDUIT.
- 4. ALL CONDUIT TO BE 21mm ϕ MINIMUM UNLESS OTHERWISE NOTED.



B.M. ELEV.			
DESIGNED BY	GSN	CHECKED BY	PS
DRAWN BY	ERC	APPROVED BY	JEH
HOR. SCALE:	NTS	RELEASED FOR CONSTRUCTION BY:	J. VEILLEUX
VERTICAL SCALE:		DATE	2005/11/22
NO. REVISIONS		DATE	2006/04/26

EarthTech
A Tyco International Ltd. Company

ENGINEER'S SEAL

ORIGINAL SIGNED BY
P. STRYK
2006/04/26

CONSULTANT DRAWING NO.
SE2.01

THE CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENGINEERING DIVISION

WEWPC
BIOLOGICAL NUTRIENT REMOVAL UPGRADE
CONTRACT 3

ELECTRICAL
AREA S - BIOREACTORS
ELECTRICAL ROOM LIGHTING AND SYSTEMS PLAN

CITY FILE NUMBER
SHEET OF
CITY DRAWING NUMBER