



MAIN FLOOR - LIGHTING & SYSTEMS PLAN
SCALE: 1:100

DRAWING NOTES

- ① COORDINATE LUMINAIRE CONNECTIONS WITH MECHANICAL PIPING AND DUCTWORK. WHERE REQUIRED SUSPEND LUMINAIRES BELOW SUCH EQUIPMENT.
- ② CONDUCTOR TO PANEL SAA IN SECONDARY CLARIFIER ELECTRICAL ROOM.

GENERAL NOTES

- 1. COORDINATE WITH OTHER TRADES TO PREVENT CONFLICTS.
- 2. USE PVC JACKETED HITECK CABLE FOR ALL POWER WIRING.
- 3. WIRING FOR LIGHTING, RECEPTACLES AND COMMUNICATIONS TO IN RGD ALUMINUM CONDUIT.
- 4. ALL CONDUIT TO BE 21mm ϕ MINIMUM UNLESS OTHERWISE NOTED.



B.M. ELEV.				ENGINEER'S SEAL	
				ORIGINAL SIGNED BY P. STRYK 2006/04/26	
DESIGNED BY	GSN	CHECKED BY	PS	CONSULTANT DRAWING NO. SE3.01	
DRAWN BY	ERC	APPROVED BY	JEH		
HOR. SCALE: AS NOTED		RELEASED FOR CONSTRUCTION BY: J. VEILLEUX			
VERTICAL SCALE:					
NO. REVISIONS	DATE	BY	DATE	2005/12/19	2006/04/26

THE CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENGINEERING DIVISION

WEWPCB BIOLOGICAL NUTRIENT REMOVAL UPGRADE CONTRACT 3

ELECTRICAL
AREA S - SECONDARY CLARIFIER 3
MAIN FLOOR LIGHTING AND SYSTEMS PLAN

CITY FILE NUMBER
SHEET OF
CITY DRAWING NUMBER