



ADDENDUM #1 BID OPPORTUNITY NO. 41-2011

BEAUMONT BAY PARK PLAYGROUND REDEVELOPMENT

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: February 10, 2011
BY: Christina Harris
TELEPHONE NO. (204) 986-7436

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Add: E8.5.5 Emitter

- (a) Shall be a 3" polyolefin pop-up drainage emitter with elbow joint, product reference no. NDS# 620 or approved substitute in accordance with B6. Multiflow, or approved substitute, shall be connected to emitter by using manufacturer's adaptor for connecting drainage pipe to 75mm or 100mm round orifice on appropriate hardware.

- (i) Contact for Emitter:
Consolidated Turf
986 Powell Avenue
Winnipeg, Manitoba
R3H 0H6
Tel: 1-204-633-7276
Fax: 1-204-633-3447

Revise: E8.5.4(b) to read:

- (b) The layout of the subdrain is to be marked on Site and approved by the Contract Administrator prior to trenching. Optimum location for extending subdrain beyond the play area limits to be determined on site. Bidder shall include approximately 10m of drainage pipe beyond play area limits in cost for sub-surface drainage. Drainage pipe to be capped with emitter as described herein. Cost for emitter shall be included in cost for sub-surface drainage.

DRAWINGS

Replace: 41-2011_Drawing_ 41-2011_Drawing_SCD 650a with 41-2011_Addendum_1 Drawing_SCD 650a-R1