



680-2011 ADDENDUM No. 1

SUPPLY AND DELIVERY OF LARGE DIAMETER BUTTERFLY VALVES WITH ACTUATORS – CONTRACT NO. 25

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: August 25, 2011
BY: Doug Berg, C.E.T.
TELEPHONE NO. (204) 986-4452

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Bid may render your Bid non-responsive.

PART A – BID SUBMISSION

Replace: 680-2011 Bid Submission with 680-2011 Addendum No. 1 - Bid Submission. The following is a summary of changes incorporated in the replacement Bid Submission:

Form B (R1): Delete Item No. 3: Supply and Delivery of 2100mm Blind Testing Flange (Approx. Quantity 1)

PART E – SPECIFICATIONS

Revise: E4.6.2(a)(ii) to read: The City will provide the Contractor with a blind testing flange for testing the 1200mm diameter butterfly valve; the blind flange will remain property of the City upon successful completion of testing. The Contractor shall be responsible for providing a gasket(s) and all bolting hardware for testing.

Revise: E4.6.2(a)(iii) to read: The City will provide the Contractor with a blind testing flange for testing the 2100mm diameter butterfly valve; the blind flange will remain property of the City upon successful completion of testing. The Contractor shall be responsible for providing a gasket(s) and all bolting hardware for testing.