



785-2011 ADDENDUM 1

ASSINIBOINE RIVERWALK ELECTRICAL UPGRADES

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: September 26, 2011
BY: Derek Murray
TELEPHONE NO. (204) 986-2491

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

Clarifications

1. Circuit #8 on distribution C (drawing E02) feeds lighting fixtures to the east of circuit # 7 shown on drawing E05. Contractor to provide a new branch feeder to a Junction point pass circuit #7 and pick up the existing circuit #8 wiring.
2. If the contractor chooses to push the Teck branch feeders, the contractor is responsible of coordinating with all the existing underground services. All existing power feeders that can not be removed shall be cut back, made safe and buried in a manner as to not allow the cables to be exposed in the future.