

THIS DRAWING MUST NOT BE SCALED.

THE GENERAL CONTRACTOR SHALL VERBY ALL DIMENSIONS, DATUMS, AND LEVELS PRO
COMMENCEMENT OF WORK. ALL ERRORS AND OMISSIONS TO BE REPORTED TO NUMB
ADMINISTRATION. CROWN DESCRIPTION.

VARIATIONS AND MODIFICATIONS TO WORK SHOWN ON THESE DRAWINGS SHALL NOT BE CARD
OUT WITHOUT WRITTEN PERMISSION OF NUMBER TEN ARCHITECTURAL GROUP.

THIS DRAWING IS THE EXCLUSIVE PROPERTY OF NUMBER TEN ARCHITECTURAL GROUP AND T

REVISED/ PLOTTED DATE

Rev. 1- RE-ISSUED FOR TENDER MARCH 7/2012

Rev. 0 - ISSUED FOR TENDER NOVEMBER 21/2012

## NOTES:

COORDINATE WITH MANITOBA HYDRO FOR NEW SERVICE ENTRANCE WORK. CONTRACTOR IS RESPONSIBLE FOR FEEDER CABLES FROM HYDRO PADMOUNT TO NEW SERVICE ENTRANCE LOCATION. CONTRACTOR IS TO TAKE ALL MEASURES TO MINIMIZE DISRUPTIONS FOR THIS INSTALLATION WHICH INCLUDES:

FEEDER TO BE INSTALLED USING DIRECTIONAL DRILLING

ANY CONCRETE WORKS REQUIRED TO BE REMOVED SHALL BE KEPT TO A MINIMUM AND SHALL BE PROPERLY REPAIRED UPON COMPLETION OF THE INSTALLATION

ALL EXISTING UTILITY LOCATES ARE THE RESPONSIBILITY OF THE CONTRACTOR.

ANY EXISTING SERVICES THAT MUST BE CROSSED, SHALL BE DONE USE SOFT EXPOSURE/HYDRO/VAC TECHNIQUES. IT IS THE CONTRACTORS RESPONSIBILITY TO REPAIR ALL DISTURBED PAVING AND SOILS.

## numberTEN architectural group

winnipeg MB regina SK victoria BC 204 942.0981 306 721.1501 250 360.2106 architecture = interior design = graphic design

PEGUIS PAVILION
UPGRADES AND ENTRY ADDITION
BIDDING #913-2011

ELECTRICAL SERVICE SITE PLAN

sheet ti

KGS GROUP CONSULTING

onsultant

Certificate of Authorize
KGS Group



n by: GCN ked by:

scale: 3/16"=1"-0"

date: November 09, 2

sheet no. E2.0