



## 160-2014 ADDENDUM 1

### MCFADYEN PLAYGROUND TENNIS COURT RESURFACING

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: JUNE 2, 2014  
BY: Tonni Buus  
TELEPHONE NO. (204) 986-3781

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20131129

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.**

---

#### **PART A – BID SUBMISSION**

Replace: 160-2014 Bid Submission with 160-2014 Addendum 1-Bid Submission. The following is a summary of changes incorporated in the replacement Bid Submission.

Form B: Prices Item 5. Revised.

#### **PART B – BIDDING PROCEEDURE**

Revise: B2.1 Submission deadline is 4:00 pm Winnipeg time, June 5, 2014.

#### **PART E – SPECIFICATIONS**

Revise E13.1.1 to read:

This specification shall cover all aspects of the supply and installation of tennis court nets and cutting and replacement of the posts to accommodate the new asphalt height. The existing net poles shall be cut and new ones shall be installed as per DETAIL C on dwg. M.9-H-R1. Centre strap anchors shall be installed into the asphalt.

Revise E13.3.1 to read:

The tennis net posts shall be adjusted so as to be 1070 mm (43") above the height of the new tennis court surface

Replace 160-2014\_Drawing\_M.9-H with 160-2014\_Addendum\_1\_Drawing\_M.9-H-R1.