

LUMINAIRE SCHEDULE

TYPE	MANUFACTURER	CATALOGUE NO.	VOLTS	LAMPS	REMARKS
1	CFI LITHONIA METALUX PEERLESS	AA348-AA 2GT8332A12125-GEB 2GR8-332A125-EB82 LACH-24G-332-12.125-120EL	347	3-F32T8	2 x 4 RECESSED IN T-BAR CEILING C/W FRAMED .125" K12 LENS AND ELECTRONIC BALLAST. MIDDLE LAMP BALLASTED SEPARATELY FROM OUTER LAMP.
1A	CFI LITHONIA METALUX PEERLESS	AA248-AA GT232A12125 GEB GR8-232A125-EB81 LACH-14G-232-12.125-120EL	347	2-F32T8	1 x 4 RECESSED IN T-BAR CEILING C/W FRAMED .125" K12 LENS AND ELECTRONIC BALLAST.
2	CFI LITHONIA METALUX PEERLESS	AA248-AA GTF232A12125 GEB GR8-232A125-EB81-DF-14-W LACH-14F-232-12.125-120-EL	347	2-F32T8	1 x 4 RECESSED IN DRYWALL CEILING C/W FRAMED .125" K12 LENS AND ELECTRONIC BALLAST.
3	LITHONIA	2PM2GB33218LD GEB	347	3-F32T8	2X4 DEEP CELL PARABOLIC.
4	LITHONIA LIGHTOLIER	L3RCSA301AZ 2003RS-CAN/2005CL	120	1-50W PAR20	3" HOUSING C/W CLEAR ALZAK REFLECTOR.
5	LITHONIA PRESCOLITE HALO LIGHTOLIER	AF2/26DTT6AR 120 GEB CFR626-ST372EB PD6-H226E-6HC 7226HT120/8056CL	347	2-26W QUAD	6" - 7 3/8" APERATURE CLEAR ALZAK, ELECTRONIC BALLAST.
6	TBA				WALL MOUNTED LUMINAIRE C/W INTEGRAL SWITCH ALLOW BUDGET PRICE OF \$60.00
7	NOT USED				
8	LITHONIA	CB-2-32-GEB	347	2-F32T8	SUSPENDED FLUORESCENT
8A	LITHONIA	TCB-2-32-GEB	347	2-F32T8	SUSPENDED FLUORESCENT (TANDEM UNIT)
9	EUREKA	4042-SC-WD-SC-50W	120	1-50W MR16	METAL SHADE PENDANT C/W SITE ADJUSTABLE STEM

MOTOR SCHEDULE:

NO	DESCRIPTION	KW/HP/AMPS	VOLTS/Ø	CONDUCTOR	COND SIZE	BREAKER	CIRCUIT
5.1	HEAT PUMP	12.6A	208/1	2#10	1/2"	30A/2P	EXIST PNL
5.2	HEAT PUMP	15.7A	208/1	2#10	1/2"	25A/2P	EXIST PNL
***	5.3	HEAT PUMP	19.5A	2#8	1/2"	40A/2P	E. EMER PNL
***	5.4	HEAT PUMP	19.5A	2#8	1/2"	40A/2P	E. EMER PNL
***	5.5	HEAT PUMP	19.5A	2#8	1/2"	40A/2P	E. EMER PNL
***	5.6	HEAT PUMP	19.5A	2#8	1/2"	40A/2P	E. EMER PNL
***	5.7	HEAT PUMP	19.5A	2#8	1/2"	40A/2P	E. EMER PNL
	5.8	HEAT PUMP	19.5A	2#8	1/2"	40A/2P	EXIST PNL
	5.9	HEAT PUMP	19.5A	2#8	1/2"	40A/2P	EXIST PNL
	5.10	HEAT PUMP	27.1A	2#6	3/4"	60A/2P	EXIST PNL
*	5.11	HEAT PUMP	27.1A	2#6	3/4"	60A/2P	EXIST PNL
**	HWIP	HOT WATER PUMP	3 HP	3#12	1/2"	25A/3P	EXIST PNL
	HD	HUMIDIFIER	16 KW	2#12	1/2"	20A/3P	EXIST PNL
	ECO	TO BE CONFIRMED					

NOTES:
 * CONFIRM HP5.11 ON SITE WITH DIV. 15 PRIOR TO ROUGH IN
 ** PROVIDE MAG STARTER, FVNR C/W HOA.
 *** WIRE AND CONNECT TO 208V EMERGENCY PANEL

THIS DRAWING MUST NOT BE SCALED.
 THE GENERAL CONTRACTOR SHALL VERIFY ALL DIMENSIONS, DATINGS, AND LEVELS PRIOR TO COMMENCEMENT OF WORK. ALL ERRORS AND OMISSIONS TO BE REPORTED TO NUMBER TEN ARCHITECTURAL GROUP BEFORE PROCEEDING.
 VARIATIONS AND MODIFICATIONS TO WORK SHOWN ON THESE DRAWINGS SHALL NOT BE CARRIED OUT WITHOUT WRITTEN PERMISSION OF NUMBER TEN ARCHITECTURAL GROUP.
 THIS DRAWING IS THE EXCLUSIVE PROPERTY OF NUMBER TEN ARCHITECTURAL GROUP AND THE COPYRIGHT IN THE SAME BEING RESERVED TO THEM. IT MAY BE REPRODUCED ONLY WITH THE PERMISSION OF NUMBER TEN ARCHITECTURAL GROUP, IN WHICH CASE THE REPRODUCTION MUST BEAR THEIR NAME.

No.	REVISED/ ISSUED/ PLOTTED	DATE
1	ISSUED FOR 90% REVIEW	MAY 3, 2008
2	ISSUED FOR CONSTRUCTION	MAY 5, 2008
3		
4		
5		
6		

numberTEN
 architectural group

204 942.0981 victoria BC 250 360.2106

architecture = interior design = graphic design

CITY OF WINNIPEG
 311 CONTACT CENTRE
 500 - 234 DONALD ST.
 WINNIPEG, MB.

project
 SCHEDULES

sheet title

MCW / AGE
 Consulting Professional Engineers
 210-1521 Wellington Avenue
 Winnipeg, Manitoba R3M 1G4
 Phone: (204) 778-7800 Fax: (204) 778-1118
 E-Mail: mcw_age@mcw.com

consultant

APECM
 Certificate of Authorization
 MCW/AGE Consulting
 Professional Engineers
 No. 589 Expiry: April 30, 2008

6315

PROVINCE OF MANITOBA
 APR 30 2008
 K.E. ISAAK
 REGISTERED PROFESSIONAL ENGINEER

scale: N.T.S.
 date: MAY 5, 2008
 drawn by: DG/AJ
 checked by: DG
 project no. 2007128
 sheet no. E5.0