

LEGEND Q

- LIGHTING POLE WITH FIXTURE

NOTES:

- LIGHTING POLE WITH FIXTURE REFER TO DRAWING NUMBER E0002 DETAIL '5' AND '6'.
- 2. CABLE ROUTES SHOWN ARE APPROXIMATE. SITE CONDITIONS MAY REQUIRE MODIFICATION OF ROUTE.
- 3. EXISTING UNDERGROUND POWER AND CONTROL CABLES FROM DECHLORINATION BUILDING TO EXISTING GASOLINE AND DESEL FUEL STORAGE TANK SHALL BE REMOVED. WIRKS SHALL BE DISCONNECTED FROM BREAKERS AND BREAKERS MARKED AS SPARE.
- 4. EXISTING SERVICE AND CONTROL FROM WASTE WATER HOLDING TANK TO REMAIN.
- CONTRACTOR TO BE RESPONSIBLE FOR ALL DAMAGED CABLES AND SERVICES.

REFER TO MECHANICAL DRAWING MODOG DETAIL 'A'	
Winnipeg WATER AND WASTE DEF	
SHOAL LAKE INTAKE FUEL STORAGE AND DELIVERY SYSTEM REHABILITATION ELECTRICAL	SHEET OF 23 CITY DRAWING NUMBER REV
SITE PLAN	1-0600A-E0001-001 1