



284-2015 ADDENDUM 2

REMOVAL OF EXISTING UPS AND SUPPLY AND INSTALLATION OF A NEW POWERWARE 9390-80/80 UPS

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: August 6, 2015
BY: Evan Wiebe
TELEPHONE NO. (204) 986-2570

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20150105

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART D – SUPPLEMENTAL CONDITIONS

Revise: D2.3(c) to read: supply and install the necessary electrical infrastructure to support the new UPS installation **complete with two spare 3-pole 225 breakers**

Add: D4.2(a): The alternate Contract Administrator is

Evan Wiebe
Project Officer
Telephone No. 204 986-2570
E-mail: ewiebe@winnipeg.ca